




THE UNIVERSITY OF
TEXAS
— AT AUSTIN —

WHAT STARTS HERE CHANGES THE WORLD

PEER and LEED

- Through LEED, USGBC created a common language, standard, and framework for advancing knowledge, technology and innovation in sustainable buildings
- We now aim to do the same in the power and energy delivery sector with PEER



Four critical categories of power system performance


**RELIABILITY, POWER
QUALITY AND SAFETY**

**ENERGY EFFICIENCY
AND ENVIRONMENT**

**OPERATIONAL
EFFECTIVENESS**

CUSTOMER ACTION

PEER is a learning system and continuous improvement process for designing and operating sustainable energy delivery systems







Vital Signs

July, 2014




Campus Peak Energy Use



Weather

Degree-days

compare the outdoor temperature to a standard temperature (65 degrees for the winter season and 50 degrees for the summer season). The more extreme the temperature, the higher the degree day number and the more energy required to cool or heat a building.




Vital Signs


July, 2014




Efficiency, FYTD
86.7% Actual
84.3% Budget



Power Plant Efficiency




Chilling Station Efficiency



Gas Prices



Daily Gas Use
July, 2014



Monthly Energy

Vital Signs

July, 2014

Water Usage




Power Plant Water Usage per kWh



Chilling Station Water Usage per Ton-hr

Industry Standards for water usage metrics are from U. S. Dept. of Energy's Argonne National Lab and the National Renewable Energy Lab (NREL).



Power Plant and Chilling Station Water Usage

Alternative water sources:

34% FYTD


Conventional Sources (City Domestic and Irrigation Water)




Chilling Station 5 Water Sources
Year to Date

Projected net savings of \$200,000 annually through use of reclaimed water.

SUSTAINABLE ENERGY DELIVERY FRAMEWORK




MICROGRID ARCHITECTURE



PRIVATE MICROGRID/RESILIENT FACILITY

Technology Suite



Total CO2 emissions can approach **300 lb./MWh** vs. state/regional average of about **~ 1,000 lb./MWh** (with methane leakage)

SYSTEM ENERGY EFFICIENCY OR INDEX (SEE)

$$\text{SEE} = \frac{\text{Metered Load, MMBtu}}{\text{Total Fuel Consumed, MMBtu}}$$

Performance Metric	Base Case	Cogen, 50%	District Energy	UT Austin 100%
Efficiency Gen	NA	52%/6.6	61%/5.6	46%/7.4
Electricity SEI, MMBtu/MWh	10.1	8.5	7.8	7.4
Cooling, kW/ton	1.3	1.3	1.0	0.75
SEE %	59%	68%	77%	86%
SEE Index	1.7	1.5	1.3	1.15

$$\text{SEE Index} = 1 / \text{SEE}$$

ENERGY EFFICIENCY AND ENVIRONMENT

Criteria	Metric/Basis	Max Points	UT Austin Points
CORE		100	68
Source Energy Intensity	7.4 MMBtu/MWh	50	35
CO2 Intensity	1,130lb./MWh	20	13
NOx Intensity	1.4 lb./MWh	10	0.0
SO2 Intensity	0 lb./MWh	10	10.0
Water Consumption	73 gal/MWh	5	5.0
Solid Waste Recycled	100%	5	5.0
BONUS		15 Max	8.0
Renewable Energy Credits	0.0%	10	0.0
District Energy	Checklist	2	2.0
Local Renewables	0.0%	2	0.0
Cogeneration / CHP	100.0%	2	2.0
Environmental Impacts	Checklist	5	4.4
Innovations		5	0
Subtotal		100	76

SAFETY, RELIABILITY, AND POWER QUALITY

Criteria	Methodology	Max Points	UT Austin Points
CORE		100	67
SAIDI – Downtime in minutes	9.7 minutes	1	1.0
SAIFI - Frequency	0.1 interruptions	1	1.0
Availability - Uptime	0.99998%	23	23.0
Damage and Exposure Prevention	Checklist	5	3.3
Alternative Sources of Supply	Site generation	5	5.0
Distribution Redundancy and Automated Restoration	44%	10	5.9
Island Capability	Checklist	20	20.0
Backup Power for Critical Loads	1%	10	0.1
Resiliency through Recovery	100%	5	5.0
Risk Mitigation	Checklist	20	3.0
Bonus		15 max	13
Power Quality Measurement	50%	5	3.7
Capabilities for Power Quality	Checklist	5	3.9
Momentary Outages	0.06 interruptions	10	3.0
Innovations		5	2.3
Subtotal		100	80

OPERATIONAL EFFECTIVENESS


Criteria	Metric/Basis	Max Points	UT Austin Points
CORE		100	63.0
Load Duration Curve	0%	20	10.0
Waste Identification and Elimination	Checklist	20	10.0
Failure Identification and Elimination	Checklist	20	3.0
Demand Response Capability	223%	20	20.0
Value Determination	\$22 million	20	20
Innovations		15 max	10.0
System Energy Efficiency	87%	3	3.0
Gap Determination	\$3,000,000	14	5
Innovations	Checklist	5	2.0
Subtotal		100	73.0

CUSTOMER ENGAGEMENT

Criteria	Max Points	UT Austin Points
Prerequisites		
Advanced Metering Infrastructure	Pass/Fail	Pass
Data Privacy/Cyber Security	Pass/Fail	Pass
Customer Engagement Programs	Pass/Fail	Pass
CORE	100	62.5
Local Renewable Capability	25	0.0
Local Cleaner Power Capability	30	30.0
Local Demand Response Capability	30	30.0
Access to Dynamic Pricing	5	0.0
Energy Management Systems	5	2.5
Electricity Supply Choice	5	0.0
Bonus	12	12.0
Innovations	12	12.0
Subtotal	100	75
Total	400	304/76%



CLOSING THE POWER SUPPLY GAP



	Baseline	Current	Upper Limit
Reliability and Power Quality			
SAIDI	60.7	9.67	0.0
SAIFI	0.77	0.10	0.00
ASAI	0.99988	0.99998	1.00000
Environmental and Efficiency			
SEI (mmBTU/MWh)	9.20	7.40	5.50
CO2I (lb/MWh)	1,560	1,130	750
NOxI (lb/MWh)	1.10	1.40	0.20
SO2I (lb/MWh)	2.20	0.00	0.00
Water (gal/MWh)	330	75	50
Waste (% Recycle)	43	100	100
Operations and Customer			
Demand % of Peak	71%	154%	0%
Demand Response %	0%	446%	446%
Cooling, kW/ton	1.2	0.8	0.7
Local Power %	0.0%	100.0%	100.0%
Energy Cost (000)	43,000	21,000	15,000

	Upper Limit
100%	- Electricity Cost OC, \$
95%	3,000,000 Electricity Energy Efficiency OC, \$
90%	- Distribution OC, \$
85%	- Demand Charge Reduction OC, \$
80%	- Ancillary Service OC, \$
75%	
70%	TOTAL GAP, \$
65%	\$3,000,000
60%	
55%	Usage = 360,000 MWh
50%	Peak = 60 MW
45%	
40%	TOTAL VALUE, \$
35%	\$22,240,000
30%	
25%	6,000,000 Electricity Cost Savings
20%	3,000,000 Electricity Energy Efficiency Savings
15%	4,000,000 Chiller System Efficiency
10%	9,000,000 Demand Charge Reduction Savings
5%	240,000 Reliability and PQ Savings
0%	- Ancillary Service Savings
	Baseline

USING PEER TOOLS TO IMPROVE PRIVATE MICROGRIDS

