# STEAM IS MORE EFFICIENT THAN MOST PEOPLE THINK





#### **SPEAKERS:**

Patrick Lach - Maxi-Therm Jacek Grob - Boilersource

## **AGENDA**

- Hydronic vs Steam
- What is Wrong with Steam?
- Steam Basics
- Vertical Condensing Design
- Steam Close Loop Network
- Why Consider Steam?
- Questions?



# **ENERGY CAPACITY OF WATER VS STEAM**

#### **WATER**

1 lb. of water increased1°F

**= 1 BTU** 

#### **STEAM**

1 lb. of steam at 0 psig that condenses into 1 lb. of water at 212°F

= 970.3 BTU



### HYDRONIC vs STEAM

# Primary/Secondary Loop System Primary Loop of 35,140,000 BTU/HR

#### Hydronic Schedule for High Temperature Hot Water System (HTHW)

<b>BOILER S</b>	OILER SCHEDULE - HOT WATER - GAS																			
					MAXIMUM	MAXIMUM		ENT.	LVG.		MIN. EFF	. REQ.	BLOWE	R	ELEC. CH	ARACTE	RISTICS	MANUFACTU	RER & MODEL No.	
UNIT NO.	LOCATION	SERVICE	TYPE	BOILER HP	INPUT MBH	OUTPUT MBH	FLUID	WATER TEMP. (DEG. F)	WATER TEMP. (DEG. F)	WORKING PRESSURE (PSI)	EFF %	TEST PROC.	HP	RPM	VOLTS	HZ	PHASE	BOILER	BURNER	REMARKS
B-1	MECH RM	HEATING	FLEX TUBE	525	20670	17570	WATER	165	240	250	85	DOE	10	3450	460	60	3		POWERFLAME LNICMR10B-G-30	
B-2	MECH RM	HEATING	FLEX TUBE	525	20670	17570	WATER	165	240	250	85	D0E	10	3450	460	60	3	UNILUX AM ZF2000-W-GO	POWERFLAME LNICMR10B-G-30	1, 2, 3, 4
B-3	MECH RM	HEATING	FLEX TUBE	525	20670	17570	WATER	165	2.0	250	85	DOE	10	3450	460	60	3	UNILUX AM ZF2000-W-GO	POWERFLAME LNICMR10B-G-30	1, 2, 3, 4

#### REMARKS:

- BOILER SHALL BE DESIGNED TO 275 DEG.F. AT 250 PSI.
- BOILER SHALL BE FITTED WITH RELIEF VALVE FOR 250 DEG.F. AND 150 PS
- BOILER SHALL BE FITTED WITH FIELD INSTALLED REAR LADDER TO ACCESS RELIEF VALVES AT TOP OF BOILER
- 4. BOILER SHALL BE EQUIPED WITH IFGR PIPING AND BURNER WITH 10" LCD TOUCH SCREEN DISPLAY.



Steam is our Passion

### HYDRONIC vs STEAM

#### GPM & PPH of water for 35,140,000 BTU/HR

8.33 lbs./gallon of water 60 minutes = 1 hour

# **HYDRONIC**

Water @ 75  $\Delta T$ 

 $35,140,000 / 75 \Delta T = 468,533 PPH$ 468,533 PPH / (8.33 x 60) = 937 GPM

## **STEAM**

Steam @ 100 PSI

35,140,000 / 1019 BTU/lb. = 34,485 PPH 34,485 PPH / (8.33 x 60) = 69 GPM




# HYDRONIC vs STEAM

#### **Properties of Saturated Steam**

Pressure	Temp.		Heat (BTU/lb)	Volume (ff <sup>3</sup> /lb)			
	(°F)	Sensib <b>l</b> e	Total	Condensate	Steam		
(Hg vac)							
25	133	101	1018	1119	0.01626	143.3	
20	161	129	1002	1131	0.01640	75.41	
15	179	147	991	1138	0,01650	51.41	
10	192	160	983	1143	0.01659	39.22	
5	203	171	976	1147	0.01666	31.82	
(PSIG)							
0	212	180	970	1151	0.01672	26.80	
1	215	184	968	1152	0.01674	25.21	
2	219	187	966	1153	0.01676	23.79	
3	222	190	964	1154	0.01679	22.53	
4	224	193	962	1155	0.01681	21.40	
5	227	195	961	1156	0,01683	20.38	
6	230	198	959	1157	0.01685	19.46	
7	232	201	957	1158	0.01687	18.62	
8	235	203	956	1159	0.01689	17.85	
9	237	206	954	1160	0.01690	17.14	
10	239	208	953	1160	0.01692	16.49	
12	244	212	950	1162	0.01696	15.33	
14	248	216	947	1163	0.01699	14.33	
16	252	220	944	1165	0.01702	13.45	
100	338	309	881	1190	0.01785	3.891	
105	341	312	878	1190	0.01789	3.736	
110	344	316	876	1191	0.01792	3.594	
115	347	319	873	1192	0,01796	3,462	
120	350	322	871	1192	0.01799	3.340	
125	125 353 325 868		1193	0.01803	3.226		



# TYPICAL HYDRONIC SYSTEM





# 937 GPM HYDRONIC vs 69 GPM STEAM

PUMP SC	PUMP SCHEDULE																				
PUMP NO.	LOCATION	PUMP NAME	SERVICE	UNIT TYPE & DESCRIPTION	PUMP CA FLOW (GPM)		MAX WWP		T		TERISTIC PHASE	STARTER	IMPELLER SIZE (DIA. In.)	FLUID TEMP. (Deg.F)	MIN, PUMP EFF. (%)	MAX. BHP	SUCTION & DISCHARGE SIZES	TRIPLE DUTY VALVE SIZE	SUCTION DIFFUSER SIZE	MANUFACTURER & MODEL No.	REMARKS
P-1	MECH ROOM	P-1	DIST. PUMPS	BASE-HIGH TEMP	1150	160	300	1800	60	460	3	ASD	14.125	350	75	55.9	6x4	6	6	DEAN PUMP R4180-4X6X15.5	2, 3
P-2	MECH ROOM	P-2	DIST, PUMPS	BASE-HIGH TEMP	1150	160		1000			3	ASD	14.125	350	75	55.9	6x4	6	6	DEAN PUMP R4180-4X6X15.5	2
CAP-1	MECH ROOM	CAP-1	COMB AIR	HORZ INLINE	34	25	175	1760	1/2	460	3	COMBO	5.4	240	52	.41	1.5x1.5	2	-	TACO 1915 - SEALIDE C SEAL	3
BP-1	MECH ROOM	BP-1	BOILER LOOP	BASE-HIGHTEMP AC	700	45	300	1800	15	460	3	ASD	8.5	350	81	14.2	6x4	6	6	DEAN PUMP RWA 4166 4x6x10 •2	1, 3
BP-2	MECH ROOM	BP-2	BOILER LOOP	BASE-HIGH TEMP AC	700	45	300	1800	15	460	3	ASD	8.5	350	81	14.2	6×4	6	6	DEAN PUMP RWA 4166 4x6x10 *2	1
BP-3	MECH ROOM	BP-3	BOILER LOOP	BASE-HIGH TEMP AC	700	45	300	1800	15	460	3	ASD	8.5	350	81	14.2	6x4	6	6	DEAN PUMP RWA 4166 4x6x10 •2	1
CHWP-1	MECH ROOM	CHWP-1	CHILLED WATER	BASEMOUNT	1730	90	125	1750	50	460	3	ASD	10.64	60	84	45	8x6	6	8	TACO FI6011	3
CHWP-2	MECH ROOM	CHWP-2	CHILLED WATER	BASEMOUNT	1730	90	125	1750	0 50	460	3	ASD	10.64	60	84	45	8x6	6	8	TACO FI6011	
CP-1	MECH ROOM	CP-1	CHILLER 1	INLINE	865	25	125	1160	10	460	3	ASD	8.25	60	80	6.8	8x8	8	-	TACO KS8011	3
CP-2	MECH ROOM	CP-2	CHILLER 2	INLINE	865	25	125	1160	10	460	3	ASD	8.25	60	80	6.8	8x8	8	-	TACO KS8011	

#### REMARKS:

FAN COOLED, HORIZONTAL, SINGLE STAGE, END SUCTION, ENCLOSED IMPELLER, CENTRIFUGAL, HIGH TEMPERATURE HOT WATER PUMP.
 WATER COOLED OIL BEARING, HORIZONTAL, SINGLE STAGE, END SUCTION, ENCLOSED IMPELLER, CENTRIFUGAL, HIGH TEMPERATURE HOT WATER PUMP.

PROVIDE SPARE SEAL KIT WITH PUMP





Two Boiler Pumps 15 HP Each System Pump 60 HP Total Pumping 90 HP



15 HP




The pumps represent 3% of the overall energy needed for the hydronic loop

# So What is Wrong with Steam?



# REDUCING STEAM PRESSURE














# CONDENSATE PUMPS, TRAPS AND VENTS









# **VACUUM BREAKERS**








#### TYPICAL STEAM DESIGN

(5)




# USING VERTICAL, CONDENSING STEAM HEAT EXCHANGERS

#### **Properties of Saturated Steam**


Pressure	Temp.		Heat (BTU/lb)	Volume (ft <sup>3</sup> /lb)		
	(°F)	Sensib <b>l</b> e	Latent	Total	Condensate	Steam
(Hg vac)						
25	133	101	1018	1119	0.01626	143.3
20	161	129	1002	1131	0.01640	75.41
15	179	147	991	1138	0,01650	51.41
10	192	160	983	1143	0.01659	39.22
5	203	171	976	1147	0.01666	31.82
(PSIG)						
0	212	180	970	1151	0.01672	26.80
1	215	184	968	1152	0.01674	25.21
2	219	187	966	1153	0.01676	23.79
3	222	190	964	1154	0.01679	22.53
4	224	193	962	1155	0.01681	21.40
5	227	195	961	1156	0,01683	20.38
6	230	198	959	1157	0.01685	19.46
7	232	201	957	1158	0.01687	18.62
8	235	203	956	1159	0.01689	17.85
9	237	206	954	1160	0,01690	17.14
10	239	208	953	1160	0.01692	16.49
12	244	212	950	1162	0.01696	15.33
14	248	216	947	1163	0.01699	14.33
16	252	220	944	1165	0.01702	13,45
100	338	309	881	1190	0.01785	3.891
105	341	312	878	1190	0.01789	3.736
110	344	316	876	1191	0,01792	3.594
115	347	319	873	1192	0,01796	3,462
120	350	322	871	1192	0.01799	3.340
125	353	325	868	1193	0.01803	3.226





# 170 - 180°F with 100 psi steam - 50% Load























Steam is our Passion

1 = Less Make-Up

2 = 0% Flash

3 = No Steam PRV

4 = No Safety Relief to Roof

5 = No Condensate Receiver Pump

6 = Smaller Pipe Size

7 = Smaller Control Valve

8 = No Vacuum Breaker

9 = Energy Savings of Over 5.4% up to 20%


10 = Stability of Set Point 2°F

11 = Less Maintenance cost


12 = 50:1 turndown

13 = Less blowdown on boiler

14 = Less chemicals for the boiler & return lines









Steam is our Passion

Objet: Corrosion Question

Bonjour,

Lately we add a few questions from customers asking if our flooded design is more corrosive on return lines?

Attached is a resume of a corrosion test made by an independasnt firm in 2007 @ a Hospital in Montreal.

The test was performed comparing an existing conventional horizontal heat exchanger and a new Maxi-therm installation.

This test was made by a chemist consultant using typical black iron (alloy C1010) corrosion coupons. After 94 days of exposure the measured corrosion rated 2.36 mills per year were the conventional method was @ 14.63 MPA.

Per industry standards any result below 3 mills per year shows a good protection in a condensate system. More over a visual surface observation of the coupopn does not denote any pitting corrosion mechanism, which is also a positive point.

Let's not forget that we are a constant steam pressure design therefore no vacuum breaker is required, on a conventiant method the vacuum breaker injects room air to break the vacuum, on low loads cooler condensate absorbs the air creates a corrosif return line.

Test result from a Hospital (2007)

	MAXI-THERM	CONVENTIONAL
Metallurgie	Black Iron	Black Iron
Days Exposed	94	94
Corrosion MPA	2.36	14.63

MPA= Mills per year



# **BUILDING HEAT BASE UNIT**





Steam is our Passion

550 usgpm of 40% propylene glycol from 146 to 180°F using 125 psig steam.

**OVERALL DIMENSIONS (L X W X H):** 

76" x 51" x 76"

# **BUILDING HEAT BASE UNIT**





Steam is our Passion

#### **CAPACITY** (each):

2200 usgpm of water from

150 to 180°F using

125 psig steam.

#### **OVERALL DIMENSIONS (L X W X H):**

87" x 46" x 99"

# **BUILDING HEAT BASE UNIT**





Steam is our Passion

#### **CAPACITY** (each):

1900 usgpm of water from 93 to 120°F using

80 psig steam.

#### **OVERALL DIMENSIONS (L X W X H):**

89" x 52" x 86"


# **4MMBTU Redundant system**





# Why use STEAM?

#### Community Energy Diagram





- Greenhouses
- Farm plant
- Algae Bio diesel
- Plastic process
- Storage

# It is a Safe Device!































#### SUMMARY OF USING A VERTICAL, CONDENSING STEAM HEAT EXCHANGER

- Energy Savings & Maintenance Savings
- Steam is the SAFEST and Most Reliable Energy Transfer Media
- Takes Between 40 to 60% LESS SPACE in Mechanical Rooms
- Possibility to Have a Building Without Vents or Chimneys
- Only a ½ in. Control Valve up to 10 MMBTU/HR Process
- Simple Automated Control System (Start-up, Shut Down and Restart)
- No Manual Valves to Touch, No Water Hammer
- Longer Life of the Condensate Return Lines and Less Chemical Use
- High Turndown Ratio, 50:1
- Reliable Energy Readings Via Condensate Flow Meter
- Possibility to have a condensing steam boiler and Cogeneration...
- Keeping Stationary Engineer is an Asset to the Facility



### **Patrick Lach**

Steam Specialist
International Sales Manager
Offering Steam Heat Exchanger Solutions
Montreal, Canada Area | Machinery

https://ca.linkedin.com/in/steamspecialist





## Jacek Grob

Representing Maxi-Therm in Illinois and Indiana
Vice President of Business and Corporate Delevopment
<a href="mailto:jacek@boilersource.com">jacek@boilersource.com</a>

Off: 847.253.1040

http://www.boilersource.com







maxi-therm.net