### districtCOOLING2016 A CLIMATE SOLUTION


NOVEMBER 13-15 | JUMEIRAH BEACH HOTEL | DUBAI, UAE

### Energy -Water – Air Conditioning Nexus In Southern Arizona

Presented By:


Henry W. Johnstone, P.E.

President and Director of Mechanical Engineering GLHN Architects & Engineers, Inc.







## Energy Water Air Conditioning Cooling Tower Water Consumption Nexus









### **ENERGY**

Figure 3: Nonrenewable Power Plants by Fuel Type in the Basin Boise Los Angeles Wyoming Cheyenne Salt Lake City San Diego Nevada Utah Upper Basin Denver San Francisco Colorado San Jose California Santa Fe Arizona Other Fossil Los Angeles Oil Lower Basin Nuclear New Mexico Natural Gas Phoenix Denver Net MWh San Diego 10001 - 100000 El Paso 100001 - 500000 500001 - 1000000 1000001 - 7500000 57500001 Source: United States Environmental Protection Agency. eGrid Survey. Year 2009 eGRID2012 Boiler, Generator, Plant, State, PCA,

eGRID Subregion, NERC Region, U.S., and Grid Gross Loss (%) Data Files. eGRID plant year 2009 data (4/27/12). 2012.



### HOW THE PORTFOLIO MAY CHANGE COMPOSITION OF ENERGY MIX BY RESOURCE (GWH) 2014 9,297 11,872 6,749 3,182 2,509

### Improves Environmental Performance:

CO2 Intensity

**V** 14%

Water Intensity

**724**%







Figure ES-2 - 2014 vs. 2029 Energy Mix

### Water Intensity of Electricity Generation








Figure 41 - Forecast of Water Consumption and Intensity


Source: Arizona Public Service Integrated Resource Plan 2012






### **WATER**















Values based on Arizona Department of Water Resources ABC's of Water http://www.azwater.gov/AzDWR/PublicInformationOfficer/ABCofWater.htm









Source: City of Phoenix Water Services Department 2011 Water Resource Plan




### SCHEMATIC CROSS SECTION OF UPPER SANTA CRUZ VALLEY SUBBASIN WITH SIMILAR VERTICAL AND HORIZONTAL SCALES















### Annual Load Profile





### **Building Cooling Load**

 $\mathsf{Q}_\mathsf{h}$ 










### Chiller Efficiency






110 °F

Air Cooled Condenser






### Air Cooled Chiller

1.0 kW/Ton COP 3.5 0.0 Gal/Tonhr


0.54 gal/Tonhr

450 Gal/MWH 0.54 Gal/Tonhr






Heat Engine



Water Cooled Condenser






COP 5.4 0.6 kW/Ton 2.25 Gal/Tonhr

2.52 Gal/Tonhr

450 Gal/MWH 0.27 Gal/Tonhr



### Water- Air Conditioning




Evaporation: 1.8 Gal/Ton

Makeup:


2.25 Gal/Tonhr

Blowdown: 0.45 Gal/Tonhr

### **Cooling Tower Water Consumption**








Routes to Air Conditioning Water Conservation



### Life Cycle Cost Factors


# Capital Cost – primary & ancillary equipment construction- installation real estate environmental mitigation utility connection fees major renewal replacement

### **Operating Cost**






### 28 thousand megawatts




Source: CallSO




Chart 9 - Impact of Increased Solar Production (Duck Curve)



TEP plans to continue with its utility scale build out of its current renewable energy standard implementation plans. TEP anticipates that an additional 1100 MW of new renewable capacity will be inservice by the end of 2030 raising the total distributed generation and utility scale capacity on TEP's system to approximately 1500 MW. By the end of 2016, renewable resources will make up close to 13% of TEP's total nameplate generation capacity. As a result, TEP is currently investing its time and resources into a number of research and development activities that will determine the future need for storage and smart grid technologies to support the grid, including two 10MW energy storage projects slated for in service by 2018.



Results assume the exit from San Juan Unit 1 in 2022. Utility Scale Renewables and Distributed Generation reflect 20% of Retail Sales



Results assume the exit from Navajo Generating Station in 2030 and the Four Corners Power Plant in 2031. Utility Scale Renewables and Distributed Generation reflect 30% of Retail Sales







### Larger Capacity 14 Condenser Unit TSC Module









mail or mail and \$1.4 CCP is call candensate cooling blowdown: 16.5 **Evolving Resource Considerations** SITE site power canal evaporation: 4.1 Climate Change, Scarcity, Cost Inter-related, Complex Question DISTRIBUTION Regionally Unique **Questions?** hjohnsto@glhn.com SOURCE

