

A photograph of a large industrial building, likely a combined heat and power (CHP) plant, situated along a river. The building is multi-story with a mix of brick and light-colored siding. A tall, dark smokestack is visible. In the background, there are several large, multi-story brick buildings, possibly university dormitories or administrative buildings. A bridge with a steel truss structure spans the river in the foreground. The water in the river is dark and reflects the sky. The sky is blue with some light clouds.

Effective Plant O&M: Integrating CHP at the University of Minnesota


University of Minnesota

- Established in 1851 in the Twin Cities (Minneapolis and St. Paul)
- Minnesota's flagship, land grant university
- 18 major colleges
- 30,500 undergraduate students study on the Twin Cities campus
- 16,300 graduate and professional students
- 7,000 international students, from 135 countries



University of Minnesota Existing Steam Plant Infrastructure

- Two Separate Steam Plants
 - Southeast Plant
 - Sole steam production facility
 - 4 boilers
 - Gas, coal, No.2 fuel oil
 - 1 steam backpressure turbine (16 MW)
 - Saint Paul Plant
 - 6 boilers
 - Gas, coal, No.2 fuel oil
- Two separate distribution systems




University of Minnesota

Southeast Plant Infrastructure

Boiler/STG	Type	Age	Conditions	Capacity (pph)	Fuel(s)
SG-201	Fluidized Bed	2000	900 psig 900 F	200,000	Gas/Coal
SG-202	LP Package	2000	265 psig 420 F	250,000	Gas/No.2
SG-203	HP Package	2000	900 psig 900 F	200,000	Gas/No. 2
Boiler 4	Stoker	1948	440 psig 600 F	80,000	Coal
TG-101	Back Pressure STG	2000	900 psig 200 psig	16 MW Net	Steam

University of Minnesota Southeast Plant - Flow Diagram




University of Minnesota

St. Paul Plant Infrastructure

Boiler/STG	Type	Age	Conditions	Capacity (pph)	Fuel(s)
No. 1	Pulverized Coal	1956	150 psig Saturation	25,000	Gas/Coal
No. 2	Pulverized Coal	1956	150 psig Saturation	25,000	Gas/Coal
No. 5	Stoker	1970	150 psig Saturation	60,000	Gas/Coal/ No. 2
No. 6	Stoker	1978	150 psig Saturation	60,000	Gas/Coal/ No. 2
No. 7	LP Packaged	1991	150 psig Saturation	80,000	Gas/No. 2
No. 8	HP Packaged	1999	265 psig Superheated	250,000	Gas/No. 2

University of Minnesota St. Paul Plant - Flow Diagram



University of Minnesota System Challenges

- *From the Operations & Maintenance perspective:*
 - *The campuses are 5 miles apart*
 - *Fuel flexibility creates challenges:*
 - *Natural gas is the primary fuel*
 - *Coal and No. 2 Fuel Oil are back-up fuels*
 - *Potential for natural gas curtailment (non-firm)*
 - *Coal is also limited by environmental permits (30%)*
 - *Coal use is managed accordingly*
- Plant operations are executed with the University's long term best interest in mind.....

University of Minnesota

Recent History

- Long Range Planning has led to recent accomplishments:
 - Existing Steam Plant efficiency evaluations
 - (Boiler tests, meter upgrades, control system optimization)
 - Refined dispatch models for boilers
 - For all seasons, load profiles, and fuel choices
 - Controls upgrade projects in planning stages at both plants to support integration with the CHP Plant
- ... and led the way for the current path ...


University of Minnesota

CHP Project


- CHP Plant Description
 - GE LM 2500
 - Dual fuel
 - EIT HRSG with duct firing
 - 90,000 pph on LM 2500
 - 250,000 pph with duct firing
 - 200 psig/400 F
- Economics
 - \$7 million annual savings
 - \$176 million over 30 year horizon
 - Partially shields university from increased electric rates
- Sustainability
 - 10-13% reduction in carbon footprint

University of Minnesota CHP Project – Environmental Benefits


Emissions Comparison



University of Minnesota CHP Project – Project Team



University of Minnesota CHP Project – Project Site



University of Minnesota – Key Performance Indicators

System Pressure Maintenance

- KPI(s)
 - Less than 4 preventable pressure drops per plant (< 90% of system rated pressure)
- Action Plan
 - Updated P&IDs, as built drawings, equipment numbering
 - Much of the work being performed by University engineering students
 - Maintaining N+1 redundancy on most major equipment
 - Major equipment is spared and planned maintenance is well scheduled
 - Responsive controls and monitoring systems
 - Upgraded controls with common systems
 - Cross-trained operators
 - The ability to monitor the CHP and SE Steam Plant from each control room

University of Minnesota – Key Performance Indicators

Plant Maintenance

- KPI(s)
 - Critical Asset Maintenance Plan within 6 months of taking over
 - 90% on-time completion rate of Critical Asset Maintenance
- Action Plan
 - Utilizing Maximo to execute outages efficiently

University of Minnesota – Key Performance Indicators

Key Equipment Availability

- KPI(s)
 - Veolia to conduct a material assessment of existing equipment within 6 months
 - 95% availability of boilers, generators and air compressors
- Action Plan
 - Maximo efficiently planning scheduled maintenance
 - Stocking needed spare parts
 - Scheduling equipment outages effectively
 - Utilize OEM and Veolia Technical resources

University of Minnesota – Key Performance Indicators

Plant Operational Efficiency

- KPI(s)
 - Veolia will complete a plant efficiency review with 6 months of taking over
 - Veolia will propose an operational profile for University approval that establishes a plant dispatch profile and theoretical operational profile
 - Maintain overall plant efficiency within 15% of theoretical values
- Action Plan
 - Phase 1 of the plant efficiency plan is complete with dispatch profiles and energy conservation improvements
 - Control system upgrades are underway
 - Defining dispatch based on season loads
 - Plant energy and utility reports are issued monthly

University of Minnesota – Key Performance Indicators

Safety and Housekeeping

- KPI(s)
 - Maintain an acceptable level of cleanliness based on walkthroughs by a University Representative, the Plant Manager and Veolia Representative
 - Maintain a reportable injury rate at no more than 4 per calendar year for both plants
- Action Plan
 - EH&S polices are thoroughly enforced including ongoing training opportunities
 - Cleanliness is practiced and embraced
 - Root Cause Analyses (RCA) are performed as needed

University of Minnesota – Key Performance Indicators

Operational Analysis

- KPI(s)
 - Veolia will conduct an event critique for each unplanned event that results in a reportable safety infraction and any reduction in pressure to less than 90%
 - Same critique for any event as agreed to between Veolia and the University
- Action Plan
 - Maintain stand by equipment in ready condition to minimize startup
 - Control system upgrades
 - Common control architecture at all plants to facilitate cross training
 - Backup fuel systems ready in case of curtailment or supply loss

University of Minnesota

Integrating Future Infrastructure

- Integrating the New CHP Plant enhances:
 - The intention is to operate the CHP plant to the greatest extent practical
 - Dispatch planning incorporates
 - Seasonal load profiles
 - Fuel choices
 - Enhanced reliability
 - Timely execution of planned maintenance activities
 - Economics
 - Controls upgrades at the SE and St. Paul plants promote improved interface between plants, data gathering, and efficiency
 - Cross training O&M staff provides operating flexibility as well as staff growth and satisfaction

University of Minnesota

Integrating Future Minneapolis Campus Infrastructure

Existing Capacity:


Boiler	Steam Capacity
SG-201	200,000 pph
SG-202	250,000 pph
SG-203	200,000 pph
Boiler 4	80,000 pph
Total	730,000 pph

Future Capacity, (with CHP):


Boiler	Steam Capacity
SG-201	200,000 pph
SG-202	250,000 pph
SG-203	200,000 pph
Boiler 4	Retired
	HRSG-fired
	250,000 pph
Total	900,000 pph

Generators	Electricity
BP ST-Gen, G-101	16 MWe
	GE LM 2500
	22 MWe
Total	38 Mwe

University of Minnesota – Future Infrastructure



University of Minnesota – Future Infrastructure



University of Minnesota Questions

Name	Title	Email	Phone
Tom McCarthy	Director of Sales	thomas.mccarthy@veolia.com	(603) 715-7797
Matthew Duffy	Director of Sales	matthew.duffy@veolia.com	(713) 447-4097
Gary Wilkinson	Director of Energy Structuring	gary.wilkinson@veolia.com	(312) 519-7437