

University of Illinois Utility Master Plan and Dispatch Model

Presented by:

Mike Larson, University of Illinois


Andy Price, Affiliated Engineers, Inc.

Aaron Wickersham, Affiliated Engineers, Inc.



University of Illinois, Urbana - Champaign

- **Abbott Power Plant (APP)**
 - 760,000 pph steam production
 - 89 MW electric production
- **APP generates 275,000 MWH or roughly 50% of campus electricity**
- **APP produces electricity at a carbon dioxide rate of 0.87 lb/kWh**
 - Below EPA standard of 1.0 lb/kWh
 - Under the MACT limits by factor of 15
- **New 5.8 MW photovoltaic facility**
- **DOE Large Scale Testing of Post-Combustion Carbon Capture Technology**
- **Distributed Central Chilled Water System**
 - Six plants producing 58,400 tons chilled water
 - Thermal energy storage
- **Energy consumption dropped more than 24% since 2007**




Utilities Production and Distribution Master Plan




Utility Master Plan Approach


- Detailed Condition Assessment
- Modeling
- Multiple Loading Scenarios
- Initial Screening Analysis
- Stakeholder Involvement
- Detailed Optimization




Chilled Water Capacity Vs Future Load



Steam Capacity Vs Future Load



Electrical Capacity Vs Future Load



Future System Global Approaches

- **Theme 1 Options – NG (with oil backup) and continued power production**
- **Theme 2 Options – NG as primary fuel and no power production**
- **Theme 3 Options – NG as primary fuel with partial renewables**
- **Theme 4 Options – Full renewables and alternative fuels**



LIFE CYCLE COST SUMMARY (\$ MILLIONS)

OPT. NO.	DESCRIPTION				NO CAMPUS GROWTH					150,000 GSF/YEAR GROWTH				
	ABBOTT PP			NEW PLANT	PV CAPEX	\$0 PER TON GHG		\$10 PER TON GHG		PV CAPEX	\$0 PER TON GHG		\$10 PER TON GHG	
	COAL	GAS	BIO			TOTAL PRESENT VALUE	TPV BAU DIFF.	TOTAL PRESENT VALUE	TPV BAU DIFF.		TOTAL PRESENT VALUE	TPV BAU DIFF.	TOTAL PRESENT VALUE	TPV BAU DIFF.
BAU	•	•			269	1,704	---	1,769	---	288	1,842	---	1,919	---
1.1		•			221	1,638	(66)	1,694	(75)	236	1,767	(75)	1,835	(84)
1.2		•		CHP	250	1,720	16	1,768	(1)	255	1,825	(17)	1,884	(36)
1.3		•		BLR	226	1,663	(41)	1,719	(50)	230	1,780	(62)	1,849	(70)
2.1		•			212	1,820	116	1,902	133	223	1,951	109	2,047	127
2.2		•		BLR	216	1,826	123	1,908	140	216	1,946	104	2,041	122
2.3				CBLR	454	2,124	421	2,203	435	454	2,277	435	2,368	449
3.1			•		294	1,726	22	1,779	10	305	1,846	4	1,909	(10)
3.2		•		HRC	266	1,673	(30)	1,729	(39)	281	1,817	(25)	1,884	(35)
3.3		•		WIND	299	1,725	22	1,777	8	314	1,853	11	1,916	(3)
3.4		•		PHV	413	1,851	147	1,906	137	428	1,976	134	2,043	124
3.5		•	•		274	1,793	89	1,842	74	285	1,924	82	1,984	65
4.1			•		265	2,004	300	2,047	278	273	2,137	295	2,189	270
4.2				GHRC	468	1,912	208	1,993	224	476	2,058	215	2,149	230

NOTES: 1. CHP - COMBINED HEAT AND POWER

BLR - BOILERS

CBLR - BUILDING CONDENSING BOILERS

HRC - HEAT RECOVERY CHILLERS

GHRC - GEOTHERMAL HEAT RECOVERY CHILLERS

PHV - PHOTOVOLTAIC SOLAR


PV - PRESENT VALUE

TPV - TOTAL PRESENT VALUE


GHG - GREEN HOUSE GAS



APP Steam Production Curve



Carbon Footprint for Various Heating Technologies



- GROUND SOURCE HEAT PUMP
- COMBINED HEAT & POWER
- STANDARD BOILER
- ILLINOIS GRID (LOW)
- CONDENSING BOILER
- ILLINOIS GRID (HIGH)



Utility Master Plan Recommendations

- Increase campus electrical import to 120 MW
- Install three new gas/oil superheated steam boilers
- Install additional backpressure steam turbine generator capacity
- Commit to net zero GSF growth
- Continue with best-in-class diversified fuel cogeneration
- Apply heat-recovery-chiller technologies
- Develop renewable energy projects
- Re-evaluate APP technologies before 2030



Implemented Projects




Illustration © Affiliated Engineers, Inc.



OPTION 1.1 INFRASTRUCTURE IMPROVEMENT SCHEDULE (TOTAL PROJECT COSTS in 2014 dollars)
UNIVERSITY OF ILLINOIS - URBANA CHAMPAIGN

**OPTION 1.1 INFRASTRUCTURE IMPROVEMENT SCHEDULE (TOTAL PROJECT COSTS in 2014
UNIVERSITY OF ILLINOIS - URBANA CHAMPAIGN**

SYSTEM	NO.	DESCRIPTION	TOTAL COST (\$)	YEAR											
				2014 (\$)	2015 (\$)	2016 (\$)	2017 (\$)	2018 (\$)	2019 (\$)						
STEAM	H-1	ANCILLARY EQUIPMENT REPAIRS	3,375,000	750,000	750,000	650,000	125,000	600,000	500,000						
	H-2	ADDITIONAL BP STG	4,660,000	---	4,660,000	---	---	---	---						
	H-3	REPLACEMENT OF HRSG 1 AND 2	27,228,000	---	---	---	---	---	---						
	H-4	THIRD GAS BOILER	9,500,000	---	---	9,500,000	---	---	---						
	H-5	COMBUSTION TURBINE INLET COOLING	1,250,000	---	---	---	---	1,250,000	---						
MECH	STEAM TURBINE AND VALVE REPAIRS	5,990,000	---	9,552,000	1,425,000	---	105,000	2,505,000	---	105,000	3,002,000	105,000	2,420,000		
MECH	C-8	ASCP CODE AND LIFE SAFETY	32,000	---	---	18,000	7,000	---	---	---	---	---	---	7,000	
	C-9	CLSCP REPLACEMENT CHILLERS/TOWERS	8,506,000	1,742,000	1,742,000	5,022,000	---	---	---	---	---	---	---	---	
	C-11	CLSCP CODE AND LIFE SAFETY	22,000	---	---	11,000	---	---	---	---	---	---	---	11,000	
	C-12	VMCP REPLACEMENT CHILLERS/TOWERS	4,489,000	---	---	576,000	---	1,159,000	---	---	---	---	2,724,000	---	
	C-14	VMCP PIPING/PUMP UPGRADES	65,000	---	---	---	65,000	---	---	---	---	---	---	---	
	C-15	VMCP CODE AND LIFE SAFETY	6,000	---	---	6,000	---	---	---	---	---	---	---	---	
	C-16	TES PRESSURE SUSTAINING VALVE MODIFICATIONS	50,000	25,000	25,000	---	---	---	---	---	---	---	---	---	
	C-17	UPGRADE PORTIONS OF DISTRIBUTION PIPING	850,000	---	400,000	150,000	150,000	150,000	---	---	---	---	---	---	
	---	SUBTOTAL	39,972,000	3,495,000	4,170,000	12,727,000	222,000	150,000	1,159,000	3,002,000	1,589,000	4,271,000	9,020,000	167,000	
	ELECT.	E-1	MV DISTRIBUTION EQUIPMENT	9,509,000	---	1,694,000	391,000	496,000	761,000	391,000	939,000	783,000	1,172,000	2,190,000	692,000
		E-2	MV DISTRIBUTION CABLING	5,533,000	---	695,000	695,000	695,000	695,000	695,000	411,600	411,600	411,600	411,600	411,600
		E-3	HV TRANSFORMERS, CIRCUIT BREAKERS, RELAYS	927,000	---	---	---	---	927,000	---	---	---	---	---	---
		E-4	INCREASE IMPORT CAPACITY TO 120 MW	16,287,000	---	---	---	8,287,000	8,000,000	---	---	---	---	---	---
		---	SUBTOTAL	32,256,000	---	2,389,000	1,086,000	9,478,000	9,456,000	2,013,000	1,350,600	1,194,600	1,583,600	2,601,600	1,103,600
	OTHER	O-1	ENERGY EFFICIENCY PROGRAM	22,000,000	2,000,000	2,000,000	2,000,000	2,000,000	2,000,000	2,000,000	2,000,000	2,000,000	2,000,000	2,000,000	
		O-2	RENEWABLE ENERGY PROJECT/PURCHASE	5,500,000	500,000	500,000	500,000	500,000	500,000	500,000	500,000	500,000	500,000	500,000	
		---	SUBTOTAL	27,500,000	2,500,000	2,500,000	2,500,000	2,500,000	2,500,000	2,500,000	2,500,000	2,500,000	2,500,000	2,500,000	
TOTAL			178,040,000	8,427,250	17,273,850	32,857,850	15,129,850	16,203,600	10,744,600	10,077,400	7,425,400	10,496,400	43,491,400	5,912,400	




Dispatch Model



UIUC Dispatch Model

- Two models were developed:
 - TOPS (Thermal Optimization Plant Software)
 - CHAMP (Chiller Activity Modeling Program)
- Mission:
 - Assist in Operational Decisions
 - Reduce Annual Operating Costs
- Phase 1:
 - Model Point in Time Operation
- Phase 2:
 - Incorporate Real Time Utility Pricing
 - Real Time Utility Demands



TOPS User Screen

INPUTS				EQUIPMENT										OUTPUTS					
UTILITY DEMAND				OPERATION										STEAM					
ELECTRIC	60.0	MW		DEVICE	AVAIL (YES / NO)	STATUS (ON / OFF)	FUEL	STEAM PROD. (KPPH)	ELECT. PROD. (MW)	150 PSIG EXTRACT (KPPH)	50 PSIG EXTRACT (KPPH)	COND. STEAM (KPPH)	STEAM (\$/KPPH)	ELECT. (\$/MWH)	PRODUCED	439.1	KPPH	5.86	\$/KPPH
STEAM (50 PSIG)	300.0	KPPH		BOILER 2	YES	OFF									DESUPERHEATED	0.0	KPPH		
STEAM (150 PSIG)	60.0	KPPH		BOILER 3	YES	OFF									IN-PLANT	37.1	KPPH		
FUEL COSTS				UNITARY COST										ELECTRIC					
AVAIL. COST				TOTAL										PRODUCED					
ELECTRIC		60.0	\$/MWH	BOILER 5	YES	ON	COAL	90.2					5.11		PURCHASED	44.3	MW	42.66	\$/MWH
GAS	YES	6.0	\$/DT	BOILER 6	YES	ON	COAL	90.2					5.11		TOTAL	15.7	MW	60.00	\$/MWH
COAL	YES	75.0	\$/TON	BOILER 7	YES	ON	COAL	99.9					5.11		UTILITIES (FUEL) PURCHASED				
OIL	NO	2.0	\$/GALLON	TOTAL				280.3					5.66		ELECTRIC	15.7	MW	942	\$/HR
AMBIENT CONDITIONS				BOILER DESUP. (50 PSIG)										GAS					
DRY BULB	51.0	°F		BOILER DESUP. (150 PSIG)											COAL	368.6	DT	2,211	\$/HR
WET BULB	42.0	°F		TOTAL				0							OIL	16.5	TONS	1,240	\$/HR
CONDENSATE RETURN				CT 1										TOTAL					
TEMPERATURE	160.0	°F		CT 2	YES	ON	GAS	42.0	12.4				5.11	60.91	MAINTENANCE COST (BOILERS / CT / STG)				
AMOUNT	85.0	%		TOTAL				84.0	24.8				5.11	60.91	COAL PARASITIC COSTS	319	\$/HR		
EMISSION FACTORS				DB 1										TOTAL					
ELECTRIC	0.731818	MTCO2e/MMWH		DB 2	YES	ON	GAS	37.4					7.83		BOILER AUXILIARY ELECTRIC COSTS	118	\$/HR		
GAS	0.053182	MTCO2e/MMBTU		TOTAL				74.8					7.83		TOTAL	5,116	\$/HR		
COAL	0.094091	MTCO2e/MMBTU		STG 1	YES	OFF							7.83		AVERAGE COST PER DAY	122,783	\$/DAY		
OIL	0.074091	MTCO2e/MMBTU		STG 2	YES	ON		3.9	0	103.2	0			2.00	CARBON DIOXIDE EMISSIONS				
				STG 3	YES	OFF									APP	55.1	MTCO2e/HR		
				STG 4	YES	OFF									GRID	11.5	MTCO2e/HR		
				STG 6	YES	ON		4.2	0	60.8	24.0			35.76	TOTAL	66.6	MTCO2e/HR		
				STG 7	YES	OFF									DEFERRED GRID	32.4	MTCO2e/HR		
				STG 8	YES	ON		4.6	50.0	0	28.0			38.35	NET	34.1	MTCO2e/HR		
				STG 9	YES	OFF													
				STG 10	YES	ON		6.9	0	136.0	0			2.00					
				TOTAL				19.6	50.0	300.0	52.0			19.53					

- User Friendly
- Real Time Calculations
- Input and Output on Same Screen



TOPS Input Screen

INPUTS			
UTILITY DEMAND			
ELECTRIC	60.0	MW	
STEAM (50 PSIG)	300.0	KPPH	
STEAM (150 PSIG)	50.0	KPPH	
FUEL COSTS			
	AVAIL.	COST	
ELECTRIC		60.0	\$/MWH
GAS	YES	6.0	\$/DT
COAL	YES	75.0	\$/TON
OIL	NO	2.0	\$/GALLON
AMBIENT CONDITIONS			
DRY BULB	51.0	°F	
WET BULB	42.0	°F	
CONDENSATE RETURN			
TEMPERATURE	160.0	°F	
AMOUNT	85.0	%	
EMISSION FACTORS			
ELECTRIC	0.731818	MTCO ₂ e/MWH	
GAS	0.063182	MTCO ₂ e/MMBTU	
COAL	0.094091	MTCO ₂ e/MMBTU	
OIL	0.074091	MTCO ₂ e/MMBTU	

DEVICE	AVAIL (YES / NO)
BOILER 2	YES
BOILER 3	YES
BOILER 5	YES
BOILER 6	YES
BOILER 7	YES
TOTAL	
BOILER DESUP. (50 PSIG)	
BOILER DESUP. (150 PSIG)	
TOTAL	
CT 1	YES
CT 2	YES
TOTAL	
DB 1	YES
DB 2	YES
TOTAL	
STG 1	YES
STG 2	YES
STG 3	YES
STG 4	YES
STG 6	YES
STG 7	YES
STG 8	YES
STG 9	YES
STG 10	YES
TOTAL	

Input Data:

- Utility Loads
- Fuels Costs and Availability
- Ambient Conditions (Combustion Turbine)
- Condensate Return (In-Plant Steam Usage)
- Emission Factors (EPA Based Data)
- Equipment Availability



TOPS Output Screen

Output Data:


- Most Cost Effective Plant Operation
- Individual Equipment:
 - Steam and Electric Production
 - Unitary Costs
- Total Plant:
 - Utility Generation
 - Utility / Fuel Purchase
 - Hourly and Daily Costs
- CO₂ Emissions
 - Plant Output
 - Purchased / Deferred Utility Electric
 - Net Emissions

EQUIPMENT						
OPERATION						UNITARY COST
STATUS (ON / OFF)	FUEL	STEAM PROD. (KPPH)	ELECT. PROD. (MW)	150 PSIG	50 PSIG	COND. STEAM (KPPH)
				EXTRACT STEAM (KPPH)	EXTRACT STEAM (KPPH)	
		STEAM	ELECT.	STEAM	ELECT.	STEAM
		(\$/KPPH)	(\$/MWH)	(\$/KPPH)	(\$/MWH)	(\$/KPPH)
OFF		0				0
OFF		0				0
ON	COAL	90.2				5.11
ON	COAL	90.2				5.11
ON	COAL	99.9				5.11
		280.3				5.56
		0				
		0				
		0				
ON	GAS	42.0	12.4			5.11 60.91
ON	GAS	42.0	12.4			5.11 60.91
		84.0	24.8			5.11 60.91
ON	GAS	37.4				7.83
ON	GAS	37.4				7.83
		74.8				7.83
OFF		0	0	0	0	0
ON		3.9	0	103.2	0	2.00
OFF		0	0	0	0	0
OFF		0	0	0	0	0
ON		4.2	0	60.8	24.0	35.75
OFF		0	0	0	0	0
ON		4.5	50.0	0	28.0	38.35
OFF		0	0	0	0	0
ON		6.9	0	136.0	0	2.00
ON		19.5	50.0	300.0	52.0	19.53

OUTPUTS			
STEAM			
PRODUCED	439.1	KPPH	5.86 \$/KPPH
DESUPERHEATED	0.0	KPPH	
IN-PLANT	37.1	KPPH	
CONDENSED	52.0	KPPH	
EXPORTED (60 PSIG)	300.0	KPPH	
EXPORTED (150 PSIG)	50.0	KPPH	
ELECTRIC			
PRODUCED	44.3	MW	42.66 \$/MWH
PURCHASED	15.7	MW	60.00 \$/MWH
TOTAL	60.0	MW	
UTILITIES (FUEL) PURCHASED			
ELECTRIC	15.7	MW	942 \$/HR
GAS	368.6	DT	2,211 \$/HR
COAL	16.5	TONS	1,240 \$/HR
OIL	0.0	GALLONS	0 \$/HR
MAINTENANCE COST (BOILERS / CT / STG)			319 \$/HR
COAL PARASITIC COSTS			286 \$/HR
BOILER AUXILIARY ELECTRIC COSTS			118 \$/HR
TOTAL			5,116 \$/HR
AVERAGE COST PER DAY			122,783 \$/DAY
CARBON DIOXIDE EMISSIONS			
APP	55.1	MTCO ₂ e/HR	
GRID	11.5	MTCO ₂ e/HR	
TOTAL	66.6	MTCO ₂ e/HR	
DEFERRED GRID	32.4	MTCO ₂ e/HR	
NET	34.1	MTCO ₂ e/HR	

TOPS Logic Diagram

- Compares Several Operational Scenarios
- Detailed Part Load Modeling of Components
- Multiple Iterations of Calculations
- Overrides:
 - Maximum Import of 60MW
 - Fuel Availability



TOPS Carbon Emission Sensitivity

- Most Cost Effective Operation May Not Result in Least Amount of Carbon Emissions
- Alternate Approach is Provided with Reduction in Carbon Emissions
- Particularly Useful if Carbon Tax is Implemented

CARBON DIOXIDE EMISSIONS		
APP	40.8	MTCO ₂ e/HR
GRID	36.0	MTCO ₂ e/HR
TOTAL	76.8	MTCO ₂ e/HR
DEFERRED GRID	7.9	MTCO ₂ e/HR
NET	68.8	MTCO ₂ e/HR
POTENTIAL W/ ON-SITE POWER GENERATION		
NET	39.8	MTCO ₂ e/HR
DIFFERENTIAL	29.0	MTCO ₂ e/HR



CHAMP User Screen

INPUTS				EQUIPMENT								OUTPUTS					
GENERAL												CHILLED WATER					
OUTDOOR AIR TEMP	86.0	°F DB		PLANT	DEVICE	TYPE	AVAIL (YES / NO)	STATUS (ON / OFF)	LOAD (TONS)	PART LOAD (%)	WITH STEAM (\$/MMBTU)	WITH ELECT. (\$/MMBTU)	PRODUCED	20,000	TONS	2.09	\$/MMBTU
OUTDOOR AIR TEMP	70.0	°F WB		OAK STREET	CHILLER 1	S	YES	OFF	0	0	0.00	0.00	TES	6,000	TONS	0.04	\$/MMBTU
TIME OF DAY	4:00 AM			OAK STREET	CHILLER 2	S	YES	OFF	0	0	0.00	0.00	TOTAL	26,000	TONS	1.62	\$/MMBTU
DAY	SUN			OAK STREET	CHILLER 3	E	YES	ON	2,000	100.0		1.86					
UTILITY COSTS				OAK STREET	CHILLER 4	E	YES	ON	2,200	100.0		1.83					
ELECTRIC	AVAIL.	COST		OAK STREET	CHILLER 5	D	YES	ON	4,412	88.2		1.69					
STEAM	YES	4.0	\$/MWH \$/KPPH	OAK STREET	CHILLER 6	V	YES	ON	1,791	64.0		1.46					
				OAK STREET	CHILLER 7	D	YES	ON	5,197	92.3		1.66					
				OAK STREET	TOTAL				15,600			1.67					
CHILLED WATER				NORTH	CHILLER 1	V	YES	ON	1,200	100.0		1.89					
DEMAND	26,000	TONS		NORTH	CHILLER 2	E	YES	ON	1,000	100.0		1.92					
SUPPLY WATER TEMP	40	°F		NORTH	CHILLER 3	E	YES	ON	1,000	100.0		1.92					
RETURN WATER TEMP	52	°F		NORTH	CHILLER 4	E	YES	OFF	0	0		0.00					
CHW FLOW	52,000	GPM		NORTH	CHILLER 5	E	YES	OFF	0	0		0.00					
THERMAL ENERGY STORAGE				NORTH	CHILLER 6	E	YES	OFF	0	0		0.00					
DISCHARGE RATE	6,000	TONS		NORTH	CHILLER 7	V	YES	ON	1,200	100.0		1.89					
CHARGE RATE		TONS		NORTH	TOTAL				4,400			1.91					
EMISSION FACTOR				LIBRARY	CHILLER 4	E	YES	OFF	0	0		0.00					
ELECTRIC	0.000732	MTCO2e/KWH		LIBRARY	CHILLER 5	E	YES	OFF	0	0		0.00					
				LIBRARY	CHILLER 6	E	YES	OFF	0	0		0.00					
				LIBRARY	CHILLER 7	A	YES	OFF	0	0	0.00	0.00					
				LIBRARY	TOTAL				0		0.00	0.00					
				ANIMAL SCIENCES	CHILLER 3	E	YES	OFF	0	0		0.00					
				ANIMAL SCIENCES	CHILLER 4	E	YES	OFF	0	0		0.00					
				ANIMAL SCIENCES	TOTAL				0			0.00					
				CHEM LIFE	CHILLER 1	E	YES	OFF	0	0		0.00					
				CHEM LIFE	CHILLER 2	E	YES	OFF	0	0		0.00					
				CHEM LIFE	CHILLER 3	E	YES	OFF	0	0		0.00					
				CHEM LIFE	TOTAL				0			0.00					
				TOTAL					20,000								
								UTILITIES PURCHASED				CARBON DIOXIDE EMISSIONS					
								ELECTRIC				GRID					
								STEAM				MTCO2e/HR					
								MAINTENANCE COST				EFFICIENCY					
								TOTAL				COP					
												CHILLER DESIGNATION KEY					
												E - ELECTRIC CENTRIFUGAL					
												D - DUPLEX					
												V - VARIABLE SPEED DRIVE					
												S - STEAM DRIVEN					
												A - LPS ABSORPTION					

- Similar Design
- Real Time Calculations
- Input and Output on Same Screen



CHAMP Input Screen

INPUTS			
GENERAL			
OUTDOOR AIR TEMP	85.0	°F DB	
OUTDOOR AIR TEMP	70.0	°F WB	
TIME OF DAY	4:00 AM		
DAY	SUN		
UTILITY COSTS			
	AVAIL.	COST	
ELECTRIC	YES	30.0	\$/MWH
STEAM	YES	4.0	\$/KPPH
CHILLED WATER			
DEMAND	26,000	TONS	
SUPPLY WATER TEMP	40	°F	
RETURN WATER TEMP	52	°F	
CHW FLOW	52,000	GPM	
THERMAL ENERGY STORAGE			
DISCHARGE RATE	0	TONS	
CHARGE RATE	0	TONS	
EMISSION FACTOR			
ELECTRIC	0.000732	MTCO ₂ e/KWH	
INPUT DATA TABLE			
PLANT	DEVICE	TYPE	AVAIL (YES / NO)
OAK STREET	CHILLER 1	S	YES
	CHILLER 2	S	YES
	CHILLER 3	E	YES
	CHILLER 4	E	YES
	CHILLER 5	D	YES
	CHILLER 6	V	YES
	CHILLER 7	D	YES
TOTAL			
NORTH	CHILLER 1	V	YES
	CHILLER 2	E	YES
	CHILLER 3	E	YES
	CHILLER 4	E	YES
	CHILLER 5	E	YES
	CHILLER 6	E	YES
	CHILLER 7	V	YES
TOTAL			
LIBRARY	CHILLER 4	E	YES
	CHILLER 5	E	YES
	CHILLER 6	E	YES
	CHILLER 7	A	YES
TOTAL			
ANIMAL SCIENCES	CHILLER 3	E	YES
	CHILLER 4	E	YES
TOTAL			
CHEM LIFE	CHILLER 1	E	YES
	CHILLER 2	E	YES
	CHILLER 3	E	YES
TOTAL			
TOTAL			

Input Data:

- Ambient Conditions (Cooling Tower Performance)
- Fuels Costs and Availability
 - Steam Cost Developed from TOPS
- Chilled Water Load and Temperatures
- Thermal Energy Storage
 - Independent Program was Previously Developed
 - Can be Integrated in CHAMP in Phase 2
- Emission Factors (EPA Based Data)
- Equipment Availability



CHAMP Output Screen

EQUIPMENT				
OPERATION			UNITARY CHW COST	
STATUS (ON / OFF)	LOAD (TONS)	PART LOAD (%)	WITH STEAM (\$/MMBTU)	WITH ELECT. (\$/MMBTU)
OFF	0	0	0.00	0.00
OFF	0	0	0.00	0.00
ON	2,000	100.0		1.86
ON	2,200	100.0		1.83
ON	4,412	88.2		1.69
ON	1,791	64.0		1.45
ON	5,197	92.3		1.66
15,600			1.67	
ON	1,200	100.0		1.89
ON	1,000	100.0		1.92
ON	1,000	100.0		1.92
OFF	0	0		0.00
OFF	0	0		0.00
OFF	0	0		0.00
ON	1,200	100.0		1.89
4,400			1.91	
OFF	0	0		0.00
OFF	0	0		0.00
OFF	0	0		0.00
OFF	0	0	0.00	0.00
0			0.00	
OFF	0	0		0.00
OFF	0	0		0.00
0			0.00	
OFF	0	0		0.00
OFF	0	0		0.00
OFF	0	0		0.00
0			0.00	
20,000				

OUTPUTS				
CHILLED WATER				
PRODUCED	20,000	TONS	2.09	\$/MMBTU
TES	6,000	TONS	0.04	\$/MMBTU
TOTAL	26,000	TONS	1.62	\$/MMBTU
UTILITIES PURCHASED				
ELECTRIC	14.8	MWH	445	\$/HR
STEAM	0.0	KPPH	0	\$/HR
MAINTENANCE COST			56	\$/HR
TOTAL			501	\$/HR

CARBON DIOXIDE EMISSIONS	
GRID	10.8 MTCO2e/HR

EFFICIENCY	
COP	6.2

CHILLER DESIGNATION KEY	
E - ELECTRIC CENTRIFUGAL	
D - DUPLEX	
V - VARIABLE SPEED DRIVE	
S - STEAM DRIVEN	
A - LPS ABSORPTION	

Output Data:

- Most Cost Effective Plant Operation
- Model Includes Chiller, Cooling Tower and Pump Performance
- Hydraulic Modeling was Utilized to Determine Plant Staging
- Individual Equipment:
 - Chilled Water Production
 - Unitary Costs
- Total System:
 - Chilled Water Generation
 - Utility Purchase
 - Hourly Costs
- CO₂ Emissions



Questions?

