



Performance Analysis on CHP Plant Using Back Pressure Turbine According to Return Temperature Variation

IDEA 2016(107th Annual Conference & Trade show) – Embracing Change

June 20 ~ 23, St. Paul River Centre, St. Paul, MN

Jong Jun Lee, Shin Young Im
Korea District Heating Corporation

Contents

♠ ***Introduction***

♠ ***System Modeling***

♠ ***Results***

♠ ***Conclusion***



Introduction

System Modeling




Results

Conclusion

● Definition of CHP(Combined Heat & Power)

➤ One of the Power generation system which can generate electricity and heat



- Source : <http://www.dynamicenergyusa.com/solutions/combined-heat-power/>

● Combined Heat & Power(CHP) System is one of the solution for using energy more efficiently

➤ High efficiency and low emissions comparing to conventional Electricity and heat generation







Figure 2: Equivalent Separate Heat and Power Efficiency
Assumes 40 percent efficient electric and 80 percent efficient thermal generation




CHP Can Avoid 60 Percent of the Potential Growth in Carbon Dioxide Emissions Between 2006 and 2030

- Catalog of CHP Technologies, U.S. Environmental protection Agency CHP Partnership, 2008
- A decade of progress Combined Heat and Power, U.S. Department of Energy, 2009


● Condensing Turbine & Back pressure turbine




Back-pressure
turbine



Extracting and
back-pressure
turbine



Condensing
turbine



Extracting and
condensating
turbine



● Back pressure type


- Single(Double) pressure system
- Narrow range Control Heat & Power ratio
- More easy control system than Condenser type

● Condensing type


- Multi pressure system
- Wide range Control Heat & Power ratio(Mode Operation)
- High initial investment
- Complex control system
- Condenser required

● Mode Operations


MODE - I (Heat Demand mode)



MODE - III (Elec. Demand mode)



MODE - V (Complex demand mode)




● Benefits of Mode Operations

- **Wide range control of Heat-Electricity ratio**
- **Possible to respond for seasonal heat/electricity demands**
- **Possible to maximize revenue**
- **Securing Reliability of Heat & Power generation**



Steam Rankine Cycle

- Performance of SRC(Steam Rankine Cycle) may changing depends on the Condenser(District Heater) cooling water temperature variations
 - Condensing pressure varied by cooling water temperature difference
 - Heat drop of turbine inlet and exit are changed when the condensing pressure varied
 - In CHP system, DH return temperature(Consumer's return) replace the cooling water



Need to clarify that the end user's heat consuming pattern may influenced to the performance of CHP Plant

- ***Modeling Commercial CHP Power Plant
(Using commercial program : GateCycle)***
- ***Analyzing CHP performance by DH return temperature variations***

Introduction

System Modeling




Conclusion

System Modeling

CHP Plant System Configuration



KOREA DISTRICT HEATING CORP.






System Modeling

CHP Plant System Configuration



KOREA DISTRICT HEATING CORP.



- GateCycle R6.1.2, GE Energy, 2014

System Modeling

Gas Turbine Modeling



KOREA DISTRICT HEATING CORP.

		Reference	Modeling	Error(%)
Ambient	Temperature (°C)	5		Set
	Pressure (Bar)	1.013		Set
	Relative humidity (%)	60		Set
Compressor	Inlet Pressure Drop (mmH ₂ O)	76.2		Set
	Pressure Ratio	Unknown*(12.8)	12.8	-
	Total Coolant bleed fraction (%)	Unknown	23.5	-
	Isentropic efficiency (%)	Unknown	87.00	-
Combustor	Fuel flow rate (kg/hr)	Unknown(20400@Curved model)	20410	(0.049)
	Pressure loss (%)	Unknown	5	-
	Combustion efficiency (%)	Unknown	98.7	-
	Turbine Inlet Temperature (°C)	Unknown	1261.23	-
Turbine	Turbine Rotor Inlet Temperature (°C)	Unknown*(1149)	1149	-
	Exhaust temperature (°C)	540.4		Set
	Nozzle Cooling Flow (kg/hr)	Unknown	136400(52.57%)	-
	Rotor Cooling Flow (kg/hr)	Unknown	123310(47.43%)	-
	Isentropic efficiency (%)	Unknown	86.48	-
Exhaust gas	Gas flow rate (kg/hr)	1125500	1125570	0.001
	Exit Pressure Drop (mmH ₂ O)	333.7		Set
Performance	Power (MW)	91.825	91.824	0.001
	Thermal efficiency (%)	32.786	32.760	0.067
Fuel	Temperature (°C)	0		Set
	Lower heating Value (kJ/kg)	49427		Set
Generator	Efficiency	Unknown	97	-

System Modeling

HRSG Modeling – Gas side



KOREA DISTRICT HEATING CORP.

		Reference	Modeling	Error(%)
HRSG Inlet	Gas Temperature(°C)	540.4	540.4	0.000
	Flue Gas Flow(kg/hr)	1,125,600	1,125,599	0.000
Duct Burner	Outlet Gas Temperature(°C)	807.5	807.5	0.000
	Fuel Gas Flow(kg/hr)	7,580	7,676	1.266
HPSH2	Outlet Gas Temperature(°C)	761.3	761.3	0.000
	Flue Gas Flow(kg/hr)	1,333,180	1,333,275	0.007
	Energy loss fraction	Unknown	0.0482	-
HPSH1	Outlet Gas Temperature(°C)	660.9	660.9	0.000
	Energy loss fraction	Unknown	0.0221	-
HPEV	Outlet Gas Temperature(°C)	321.2	321.2	0.000
	Energy loss fraction	Unknown	0.0135	-
HPEC2	Outlet Gas Temperature(°C)	211.7	211.71	0.000
	Energy loss fraction	Unknown	0.0085	-
LPEV	Outlet Gas Temperature(°C)	168.3	168.13	0.100
	Energy loss fraction	Unknown	0.000	-
HPEC1	Outlet Gas Temperature(°C)	149.7	149.66	0.027
	Energy loss fraction	Unknown	0.01	-
DH ECO	Outlet Gas Temperature(°C)	82.1	82.1	0.000
	Energy loss fraction	Unknown	0.0071	-

System Modeling

HRSG Modeling – Steam side



KOREA DISTRICT HEATING CORP.

		Reference	Modeling	Error(%)
HPSH2	Steam Outlet Pressure(kg/cm ²)	100	100	0.000
	Steam Outlet Temperature(°C)	515	515	0.000
	Steam Flow Rate(ton/hr)	283.7	283.7	0.000
	Steam Outlet Enthalpy(kcal/kg)	815.6	815.61	0.001
	Surface Area(m ²)	Unknown	1254.5	-
HP DSH	Steam Outlet Temperature(°C)	433.9	432.89	0.235
	Steam Flow Rate(ton/hr)	283.7	283.7	0.000
	Cooling Water Flow(ton/hr)	1.1	1.1	0.000
HPSH1	Steam Outlet Pressure(kg/cm ²)	101.5	101.5	0.000
	Steam Outlet Temperature(°C)	436.5	436.49	0.002
	Steam Flow Rate(ton/hr)	282.6	282.6	0.000
	Steam Outlet Enthalpy(kcal/kg)	766.1	766.06	0.005
	Surface Area(m ²)	Unknown	3825.5	-
HPEV	Steam Outlet Pressure(kg/cm ²)	102.4	102.4	0.000
	Steam Outlet Temperature(°C)	311.3	311.27	0.010
	Steam Flow Rate(ton/hr)	282.6	282.6	0.000
	Steam Outlet Enthalpy(kcal/kg)	655.1	651.33	0.575
	Surface Area(m ²)	Unknown	28996.3	-
HPEC2	Water Pressure(kg/cm ²)	102.4	102.4	0.000
	Water Outlet Temperature(°C)	266.4	266.4	0.000
	Water Flow Rate(ton/hr)	282.6	282.6	0.000
	Water Outlet Enthalpy(kcal/kg)	Unknown	278.46	-
	Surface Area(m ²)	Unknown	16408.19	-



		Reference	Modeling	Error(%)
LPEV	Steam Pressure(kg/cm ²)	5.8	5.8	0.000
	Steam Outlet Temperature(°C)	156.8	156.76	0.026
	Steam Flow Rate(ton/hr)	24.7	24.7	0.000
	Steam Outlet Enthalpy(kcal/kg)	658.4	657.58	0.125
	Surface Area(m ²)	Unknown	10672.6	-
HPEC1	Water Pressure(kg/cm ²)	104.6	104.6	0.000
	Water Outlet Temperature(°C)	161.3	161.3	0.000
	Water Flow Rate(ton/hr)	282.6	282.6	0.000
	Water Outlet Enthalpy(kcal/kg)	Unknown	164.04	-
	Surface Area(m ²)	Unknown	18735.8	-
DH ECO	Water Outlet Temperature(°C)	119.9	119.9	0.000
	Water Outlet Enthalpy(kcal/kg)	120.3	120.36	0.050
	Water Inlet Temperature(°C)	65.3	65.3	0.000
	Water Inlet Enthalpy(kcal/kg)	65.5	65.3	0.305
	Water Flow Rate(ton/hr)	353.3	353.3	0.000
	Surface Area(m ²)	Unknown	20805	-
DEA	Water Pressure(kg/cm ²)	3.7	3.7	0.000
	Water Outlet Temperature(°C)	140.1	140.14	0.029
	Water Flow Rate(ton/hr)	308.4	308.4	0.000
	Aux. Steam Flow Rate(ton/hr)	15.8	15.84	0.253
Feed Water	Water Pressure(kg/cm ²)	5	5	0.000
	Water Outlet Temperature(°C)	112.6	112.6	0.000
	Water Flow Rate(ton/hr)	292.6	292.56	0.014

System Modeling

Steam Turbine Modeling



KOREA DISTRICT HEATING CORP.

		Reference	Modeling	Error(%)
HP Steam Turbine	Inlet	Pressure(ata)	96.25	96.25
		Temperature(°C)	513.7	513.62
		Enthalpy(kcal/kg)	815.8	815.8
		Mass Flow(ton/hr)	283.7	0.000
	Seal Steam* (HP Turbine Bowl)	Pressure(ata)	Unknown	94.33
		Mass Flow(ton/hr)	0.13	0.000
	Isentropic Efficiency		Unknown	0.87
	HP Steam Turbine Power(kW)		Unknown	48,963
	HP Exhaust Pressure(ata)		Unknown	5.4
	LP Steam	Pressure(ata)	5.569	5.57
		Temperature(°C)	155.2	155.2
		Enthalpy(kcal/kg)	656.7	656.7
		Mass Flow(ton/hr)	8.88	0.000
LP Steam Turbine	LP Extraction (To DH #2)	Pressure(ata)	1.644	1.64
		Temperature(°C)	113.5	113.55
		Enthalpy(kcal/kg)	620.6	620.6
		Mass Flow(ton/hr)	173.5	0.000
	Isentropic Efficiency		Unknown	0.871
	LP Steam Turbine Power(kW)		Unknown	20,311
	LP Exhaust Pressure(ata)		0.547	0.547
	LP Exhaust Temperature(°C)		83.1	83.11
	LP Exhaust Enthalpy(kcal/kg)		587.9	587.9
	Terminal Power(kW)		67,803	0.000
Generator Efficiency		Unknown	0.9788	-

System Modeling

District Heater 1 Modeling



KOREA DISTRICT HEATING CORP.

Location		Design Data	Modeling	Error(%)
Cooling Water	CW Flow	2,706,086	2,709,120	0.112%
	CWIN T	65.000	65.000	0.000%
	CWOUT T	94.970	94.970	0.000%
	CWIN H	65.200	65.150	0.077%
	CWOUT H	95.200	95.160	0.042%
	ΔQ	81,182,580	81,300,691	0.145%
	CWIN P	9.500	9.500	0.000%
	CWOUT P	8.470	8.470	0.000%
Main Steam	Inlet P	0.963	0.963	0.000%
	Inlet T	98.000	98.040	0.041%
	Inlet Flow	161,680	161,680	0.000%
	Inlet H	600.400	600.400	0.000%
Aux. Steam	Inlet P	Unknown	94.330	-
	Inlet T	Unknown	512.750	-
	Inlet Flow	1,300	1,300	0.000%
	Inlet H	Unknown	815.800	-
Cond. Water	Inlet P	1.263	1.263	0.000%
	Inlet T	98.000	98.040	0.041%
	Inlet Flow	161,810	161,810	0.000%
	Inlet H	98.000	98.120	0.122%

System Modeling

District Heater 2 Modeling



KOREA DISTRICT HEATING CORP.

Location		Design Data	Modeling	Error(%)
Cooling Water	CW Flow	3,338,051	3,343,840	0.173%
	CWIN T	72.250	72.250	0.000%
	CWOUT T	100.000	100.000	0.000%
	CWIN H	72.400	72.380	0.028%
	CWOUT H	100.200	100.200	0.000%
	ΔQ	92,797,818	93,025,629	0.245%
	CWIN P	8.590	8.590	0.000%
	CWOUT P	7.560	7.560	0.000%
Main Steam	Inlet P	1.263	1.263	0.000%
	Inlet T	105.700	105.720	0.019%
	Inlet Flow	187,550	187,550	0.000%
	Inlet H	618.000	618.000	0.000%
Aux. Steam	Inlet P	1.263	1.263	0.000%
	Inlet T	74.200	74.290	0.121%
	Inlet Flow	96,530	96,530	0.000%
	Inlet H	74.200	74.290	0.121%
Cond. Water	Inlet P	1.263	1.263	0.000%
	Inlet T	105.700	105.720	0.019%
	Inlet Flow	284,080	284,080	0.000%
	Inlet H	105.900	105.860	0.038%

Introduction

System Modeling





Results

Conclusion

Performance variation according to DH return Temperature


- **Performance improving by DH return temperature variations**

- **District heater of Back pressure turbine may replace the condenser of condensing turbine**
- **Steam turbine performance may varied according to the DH return temperature variation**




Performance variation according to DH return Temperature

● CHP System performance variations by DH return temperature variations *(System efficiency and Back Pressure variations)*




System Power and Efficiency variation
vs. Returning Temperature




System Power and ST Back Pressure
vs. Returning Temperature

Performance variation according to DH return Temperature

● CHP System performance variations by DH return temperature variations (*District heat and Pump required work variations*)



Supply Temperature and Heat rate variation
vs. Returning Temperature



Water Flow rate and Pump Work variation
vs. Returning Temperature

Introduction

System Modeling



Results

Conclusion

Conclusion

- **Analyzing CHP Performance by the DH return temperature variation which are varied by the heat consuming pattern**
 - CHP Performance are varied by **DH Return Temp. variations**
 - **Steam Turbine power may increases** by reduction of condensing pressure
 - **Pump required work may decreases** by required district heating flow
- **The maintaining supply heat consumption method shows more efficient performance than the maintaining supply temperature**
 - Increasing Cooling flow rate for maintaining supply heat consumption may reducing DH supply temperature
 - It bring to increase of steam turbine power
- **Analysis of end user's heat consuming trend based on the real data may requires for more accurate results**

Thank You for Your Attention!

Any Questions?



KDHC R&D Institute
Senior Researcher, Jong Jun Lee

E-mail : leejj1023@kdhc.co.kr
leejj1023@gmail.com

Office : 82-2-2040-1258
Cell : 82-10-4844-7247