


BURNS  McDONNELLSM



Denver International Airport Total Facility Optimization

Josh Foerschler
Aurom Mahobian

CAMPUSENERGY2015



AGENDA

- DIA Intro
- BMcD-DIA History
- Optimization Projects
- Results
- Conclusion

Denver International Airport

- ▶ Opened February 28, 1995
- ▶ 15th Busiest Airport in the World
- ▶ 34,000 Acres (Largest Land Area Airport in US)
- ▶ 76,000 Feet of Length on Six Runways
- ▶ >6M Square Feet of Space Under Roof
 - Terminal, 3 Concourses & Airport Office Building
- ▶ >52M Passengers per Year



Slide 3

OLA1

Add infographic

Ash, Olivia L, 2/4/2015

DIA - Burns & McDonnell History

1980-
1983

City of
Denver
initiates
site
planning
activities



1989

Burns &
McDonnell
hired to
assist in
schematic
design for
terminal

1995-
Present

Held
various
on-call
contracts,
numerous
designs.
Scopes:
• MEP
design
througho
ut
terminal

DIA CENTRAL UTILITY PLANT (CUP) MASTER PLAN

COMMISSIONED CUP UTILITY MASTER PLAN IN 2010

- ▶ South Terminal, Hotel and Concourse planned expansions
- ▶ Equipment performance, system demands, plant efficiency and useful life considered.

▶ CUP Master Plan Outcome:

- Timeline for plant expansions
- Site wide pumping system mods
- Pressure independent control valves at Concourses
- Cooling tower sump mods
- Free cooling addition (4,150TR)
- Plant Data Historian
- R22 replacement master plan

EQUIPMENT:

- ▶ 12,750 tons of mechanical cooling (5 Units)
- ▶ 6,650 tons of free cooling (3 Units)
- ▶ 8 cooling towers, 2 separate sumps
- ▶ 300,000 Btu/hr of boiler capacity

Roadmap
for Future




HYDRONIC SYSTEM OPTIMIZATION

HYDRONIC SYSTEM OPTIMIZATION

PROJECT SUMMARY



- ▶ Original *BRDG-TNDR* blending system in place (HW & CHW)
- ▶ Poor delta T, three levels of pumping from CUP to users
- ▶ AFT Fathom models created



- ▶ Goals of Program:
 - Convert system to true variable primary, variable secondary
 - Eliminate tertiary loop
 - Eliminate all blending/3-way valves
 - Improve delta T at coils
 - Increase efficiency of CUP
 - Extend capacity of CUP
 - Energy efficiency gains
 - Better control and reporting at equipment level
 - Energy savings from eliminating pumps
 - Energy Rebates

HYDRONIC SYSTEM OPTIMIZATION

ENERGY IMPACT & COST SAVINGS

TERTIARY LOOP ELIMINATED:

- ▶ 168 Pumps
- ▶ >1,900 HP

PRESSURE INDEPENDENT CONTROL VALVES INSTALLED:

- ▶ >500 valves at AHUs,

- ▶ Energy Savings:
 - 6.8M kWh/yr
- ▶ Demand Savings:
 - 820 kW
- ▶ CO₂ Emissions
 - 15M lbs/yr
- ▶ Annual Cost Reduction:
 - >\$400,000
- ▶ Xcel Energy Rebate:
 - \$330,000



DELTA T

CONDENSER WATER SYSTEM OPTIMIZATION

CW SYSTEM OPT

PROJECT SUMMARY



- ▶ 8/10 Cooling Tower Cells Used
- ▶ One Common Sump
- ▶ Two Levels of Pumping
- ▶ Undersized HXs for Free Cooling
- ▶ Poor Maintenance Access in Sump



Goals of Program:

- ▶ Design sump separation for variety of uses:
 - Maintenance Access
 - Dual Temperature Abilities
- ▶ Free Cooling Addition (new HX)
- ▶ Variable speed pumping on CW system
- ▶ Temp CTs & piping needed during construction

CW SYSTEM OPTIMIZATION

ENERGY IMPACT & COST SAVINGS (est.)

- ▶ Sump Pit Wall Erected with Slide Gates
- ▶ CW Piping Modifications (new 48" isolation in CW header)
- ▶ 4,150 TR Heat Exchanger Installed
- ▶ BAS Sequence Updates



ENERGY SAVINGS:

- ▶ 2.4M kWh/yr

NEW AVAILABLE TON-HRS

- ▶ 5.7M Ton-Hrs

ANNUAL COST REDUCTION:

- ▶ >\$140,000

XCEL ENERGY REBATE:

CHILLER ADDITION AND DISPATCH OPTIMIZATION

CHILLER ADDITION & DISPATCH OPTIMIZATION


PROJECT SUMMARY

► Chiller #4 Failure

- Stapleton chiller moved to DIA, chiller froze multiple times in recent years

► Goals of Program:

- Evaluate mult. chiller configurations, quantities, sizes & dispatch models
 - Single/Dual Chiller(s)
 - Parallel/Series Setup
 - Single/Dual Compressor(s)
 - Variable/Constant Compressor
- Evaluate variable primary CHW and CW conversions
- Perform LCCA for each config
- Install additional capacity in CUP
 - 2 x 2,500 TR
- Space constraint in Chiller Room
- Created BIM model of plant to prove fit



CHILLER ADDITION & DISPATCH OPTIMIZATION

PROJECT PHOTOS



CHILLER ADDITION & DISPATCH OPTIMIZATION

ENERGY IMPACT & COST SAVINGS

- ▶ Ultimate Design:
 - Two chiller setup, parallel configuration
 - Dual compressor machines
 - Variable speed compressors
 - 2,500 TR each
 - Variable CHW flow
 - CHW/CW pumping improvements

ENERGY SAVINGS:

- ▶ 1.5M kWh/yr

DEMAND SAVINGS

- ▶ 140kW

XCEL ENERGY REBATE:

- ▶ \$150,000

DIA - Central Plant Chiller Addition

Life Cycle Economic Analysis

PROJECT NO. 67715

Rev 3-Centrifugal Water Chillers

York-JCI Equipment

July 2012

J. Foerschler

Burns & McDonnell

SINCE 1898

| Inputs - Implementation | Selection | Inputs - Financing |
|---|--------------|-------------------------------|
| Trane(CDHF) Dual Machine, Dual Compressor - 2500 TR | 10 | Financing Term (Years) |
| Operating Scenario | AHRI | Payments per Year |
| Chiller Install Cost | \$ 1,660,000 | \$ of Payments |
| Cash Investment | | Financing Rate |
| Final Cost | \$ 1,660,000 | Percent Project Financed |
| | | Total Project Amount Financed |

| Chiller Bid Tab Results | Inputs - Escalation & NPV Calculation |
|--------------------------------------|---------------------------------------|
| Yearly Chiller Consumption (kWh) | 5,330,368 |
| Yearly Pumping Consumption (kWh) | 200,255 |
| Yearly Chiller & Pump Operating Cost | \$ 442,450 |
| Life Expectancy (Years) | 25 |

| | |
|----------------------|------|
| Utility Escalation* | 3.0% |
| Discount Rate | 4.0% |
| Equipment Escalation | 3.5% |

ENERGY PROGRAM

| Period** | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | 2020 | 2021 | 2022 | 2023 |
|--------------------------|----------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|--------------|
| ENERGY REVENUE | | | | | | | | | | | | |
| TOTAL REVENUE | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - |
| OPERATING ACTIVITIES | | | | | | | | | | | | |
| Annual O&M Costs | | | | | | | | | | | | |
| Annual Energy Usage | \$ (442,450) | \$ (455,723) | \$ (469,395) | \$ (483,477) | \$ (497,981) | \$ (512,921) | \$ (528,308) | \$ (544,158) | \$ (560,482) | \$ (577,297) | \$ (594,616) | \$ (612,454) |
| INVESTMENT ACTIVITIES | | | | | | | | | | | | |
| Chiller Plant Activities | | | | | | | | | | | | |
| Cash Investment | \$ (1,660,000) | | | | | | | | | | | |
| FINANCING ACTIVITIES | | | | | | | | | | | | |
| Borrowed Funds * | \$ - | | | | | | | | | | | |
| Debt Service * | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - | \$ - |
| TOTAL EXPENSE | \$ (2,102,450) | \$ (455,723) | \$ (469,395) | \$ (483,477) | \$ (497,981) | \$ (512,921) | \$ (528,308) | \$ (544,158) | \$ (560,482) | \$ (577,297) | \$ (594,616) | \$ (612,454) |

ANALYSIS

| Period** | 0 | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | 11 |
|-----------------------------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|----------------|
| ANNUAL NET CASH FLOW ** | \$ (2,102,450) | \$ (455,723) | \$ (469,395) | \$ (483,477) | \$ (497,981) | \$ (512,921) | \$ (528,308) | \$ (544,158) | \$ (560,482) | \$ (577,297) | \$ (594,616) | \$ (612,454) |
| CUMULATIVE NET CASH FLOW | \$ (2,102,450) | \$ (2,558,173) | \$ (3,027,568) | \$ (3,511,045) | \$ (4,009,027) | \$ (4,521,948) | \$ (5,050,256) | \$ (5,594,413) | \$ (6,154,896) | \$ (6,732,193) | \$ (7,326,808) | \$ (7,939,262) |
| CASHFLOW BREAK-EVEN CALCULATION | | | | | | | | | | | | |
| CUMULATIVE INVESTMENT NET | \$ (2,102,450) | \$ (2,558,173) | \$ (3,027,568) | \$ (3,511,045) | \$ (4,009,027) | \$ (4,521,948) | \$ (5,050,256) | \$ (5,594,413) | \$ (6,154,896) | \$ (6,732,193) | \$ (7,326,808) | \$ (7,939,262) |
| CUMULATIVE BREAK-EVEN CALCULATION | | | | | | | | | | | | |

CUP CONTROLS UPGRADE & CHW OPTIMIZATION (HARTMAN LOOP)

CUP CONTROLS UPGRADE + CHW OPTIMIZATION

PROJECT SUMMARY

- ▶ Original DIA Building Automation System in Place
 - Multiple generations, terminals
- ▶ BRDG-TNDR Panel Still in Place
- ▶ Constant Speed CT Fans
- ▶ Goals of Program:
 - Update BAS system
 - CHW Optimization via Hartman LOOP technology
 - Implement energy efficiency measures & advanced sequences
 - Increase level of reporting and trending for DIA personnel
 - Convert CT to variable speed
 - Motor and VFD installations



Before





After

CUP CONTROLS UPGRADE + CHW OPTIMIZATION

ENERGY IMPACT & COST SAVINGS (est.)

- ▶ >10,000 Points on New BAS System
- ▶ Hartman LOOP integration
- ▶ BAS Sequence Updates
- ▶ Plant Efficiency Increase:
 - 0.921 to **0.615** kW/ton



ENERGY SAVINGS:

- ▶ 7.3M kWh/yr

DEMAND SAVINGS:

- ▶ 322 kW

CT WATER SAVINGS:

- ▶ 4M gal/yr

CO2 EMISSIONS REDUCTION:

TOTAL FACILITY OPTIMIZATION RESULTS

TOTAL FACILITY OPTIMIZATION RESULTS

DIA OPERATORS HAVE WITNESSED...

- ▶ Matched Plant & System CHW & HW flows
- ▶ Chilled Water Delta T increase from 9 to **14°F**
- ▶ Hot Water Delta T increase from 40-50 to **70°F**
- ▶ Ability to project tonnages with outside air, and match-load CUP chillers to achieve **best KW/ton**
- ▶ Ability to load 64MM BTU boilers up to desirable 70–90% load (most efficient)
 - *“This year alone, compared to last year, we only had to run one boiler 90% of the time between the months of December thru February vs. last year we ran both boilers 100% of the time. **Projected all time high gas savings this year.**”*
- ▶ Addition of VFDs to all pumps & modulating control valves on the decoupler allows up to **5,000 TR “free cooling”**
- ▶ Higher sump temperatures lead to less run time on cooling fans
 - *“In free cooling mode this year alone, we are seeing **record low electric usage.**”*

Conclusion

So what are we saying?

- ▶ **Commit to a client**, develop a relationship, get to know their facilities/systems
- ▶ Start with a Utility Master Plan, **set the roadmap** for future projects
- ▶ **Identify** all energy-efficiency & system optimization projects...even if little to no funding available!
- ▶ Work with client to **execute projects one at a time**, work towards the goal of completion



[BURNSMCD.COM/ONSITE](http://burnsmcd.com/onsite)

CONTACT

Josh Foerschler, PE, LEED AP O+M, CEM

Project Manager

P: 303-474-2290

E: jfoerschler@burnsmcd.com

Aurom Mahobian, PE, LEED AP

Project Manager

P: 303-474-2267

E: amahobian@burnsmcd.com