

Campus Based Energy Security & Carbon Footprint Reduction: *The University of Minnesota's Master Energy Plan*

Presented by
U.S. Energy Services, Inc.
Wednesday, February 10, 2016



AGENDA

Discussion Topics: A Two-Part Solution

- **Situation Background and CHP Solution**
- **Price Risk Management Plan Solution**



Background and *Cleaner* Power Generation Solution with CHP



U of M Energy Management Requirements

- Reliable
 - Ensure reliable energy supply
- Sustainable
 - Reduce CO₂ emissions
- Cost-effective
 - Identify energy efficient opportunities and balance upfront investment costs with long-term savings potential



Utility Master Planning

As of June 2009, the situation was clear:

- Steam capacity was inadequate
- Boilers were aging and beyond their useful life
- Competing with other higher education institutions
- Sustainability plans – Zero Carbon by 2050
- The conclusion was to add two package boilers...

BUT

- Benchmarking other district energy facilities
- Another option, CHP, could save the University **\$'s**

Summary of Challenges



■ Reliability

- Projected shortage of 'firm' steam capacity
- Risk to research, teaching and operations due to 100% of steam for Minneapolis campus coming from one site served from single tunnel away from campus

■ Sustainability

- Commitment to provide energy with less carbon output

■ Cost Effectiveness

- Impact to utility rates after adding steam capacity
- Projected increases in purchased electrical costs
- Needed site for next efficient chilled water plant

Sustainability

The University's Institutional Commitment to Sustainability

2004

Regents
Policy
Adopted

2008

Presidents'
Climate
Commitment
Signed

2010

Systemwide
Sustainability
Committee
Appointed

2013

Workteam
Considers
Future

Sustainability Commitment

Carbon Footprint Reduction

- 10 to 13.5% of the Campus 2008 baseline
- **81,000 metric tons of CO₂**
(Recalculated number from 65,000)



Equivalent to:

- 17,000 passenger vehicles in a typical year or
- 192,857,143 miles driven by the average car or,
22.3 wind turbines


Source: epa.gov/cleanenergy/energy-resources/calculator

CHP Project Solution

- Addresses the deficiencies of the Old Main Utility Building as part of developing a multiple utility services building
- Installs a dual fuel Combustion Turbine Generator capable of exporting 20.4 MW to campus
- Installs a duct fired Heat Recovery Steam Generator
- Enhances campus electrical power distribution infrastructure
- Provides dedicated space for future chilled water and package boiler equipment




CHP Combustion Turbine




General Electric LM2500 Gas Turbine

CHP Efficiency

CONVENTIONAL GENERATION



COMBINED HEAT & POWER



49% OVERALL EFFICIENCY

75% OVERALL EFFICIENCY

U of M: 83%!

Projected Utility Rates with CHP

| | Current University Utility Rate | Projected Rates With Project |
|---------------------------|--|--|
| Steam (Rates \$/Mlb) | \$21.95 ¹ \$21.98² | \$19.99 ¹ \$22.27² |
| Electric (Rate \$/kWh) | \$0.0991 ¹ \$0.0991² | \$0.0900 ¹ \$0.0950² |

1 = FY12

2 = FY14

Projected Utility Costs with CHP

| | Current University Utility Costs | Projected Costs with a New Boiler and NO CHP Project | Projected Costs with the CHP Project |
|------------------------------------|----------------------------------|--|--------------------------------------|
| Steam (Annual Total) | \$43,141,000 | \$45,553,000 | \$43,720,000 |
| Electric (Annual Total) | \$39,338,000 | \$41,658,000 | \$37,692,000 |
| Total Annual Cost: | \$82,478,000 | \$87,211,000 | \$81,411,000 |

Projected Cost to Produce vs. Purchase Electricity \$/kWh with CHP

| | Projected Rates with Project: |
|------------------------------|-------------------------------|
| U's Cost per kWh to Produce | \$0.0258 |
| Effective Cost/kWh | \$0.0770 |
| U's Cost per kWh to Purchase | \$0.0810 |

Project Benefit Summary

■ **Cost-effective**

- Projected to reduce University utility costs by \$7 million annually
- Provides a financial hedge against purchased electrical costs
- Creates cost effective site for next chilled water plant

■ **Reliable**

- Provides sufficient 'firm' capacity for 15 years based on current projections
- Provides 2nd source of steam production dramatically reducing risk to campus research, teaching, and campus community

■ **Sustainable**

- Reduces Campus Carbon Footprint by 10%
- Significant increase in efficiency of utility systems

Potential Options for Operations:


| Option | Ownership of Plants | Operation of Plants |
|--------|---|--|
| 1 | University Owns: - State and U funding mix | University Operates |
| 2 | University Owns: - State and U funding mix | University Contracts Management (current arrangement) |
| 3 | U Enters into Long-term Lease w/ Third Party | U Purchases Utilities from 3rd Party |

Potential Options – Analysis

| | Option | Operating and Capital Costs | Reliability/Control |
|---|--|--|--|
| 1 | University Owns and Operates | Lowest: <ul style="list-style-type: none"> • U pays operational costs • U pays portion of capital cost | Highest: <ul style="list-style-type: none"> • University maintains most control. • Would require U to ramp up staffing/expertise. |
| 2 | University Owns but Contracts out Mgmt. | Moderate: <ul style="list-style-type: none"> • U pays operational costs • U pays portion of capital costs • U pays management fee • U pays profit/incentive | Moderate: <ul style="list-style-type: none"> • University manages through contract provisions • Utilizes industry expertise |
| 3 | U Enters into Long-term Lease w/ Third Party | Highest: <ul style="list-style-type: none"> • U pays operational costs • U pays 100% capital costs in rates • U pays management fee • U pays profit/incentive | Lowest: <ul style="list-style-type: none"> • University has least control • Subject to operational decisions by provider. |


Sizing Driven by Steam Requirements

Steam Demand Exceeds Reliable Steam Capacity



The Solution:

PROPOSED BOILER CAPACITY MEETS PROJECTED DEMAND UNTIL 2028



+ Major New Buildings

Supplier Diversification and Long Term Balanced Risk Management Plan



Supplier Diversification & Long Term Contracts

- Credit approved for multiple suppliers (BP Energy, Shell Energy, UET, etc.)
- Typically \$.02~\$.10/MMBTU savings when suppliers compete for business
- Negotiated 25 year discounted gas transport rate with utility

Balanced Position Hedge Program: Definition

- Defined hedging strategy – quantifiable targets + process for reassessment
- Defined execution strategy – defines the “who” and “how” of hedging
- Budget oriented: 40-75% hedged up to 36 months into future



Balanced Position Hedge Program: Goals

- Insurance against volatility → component dedicated to budget predictability
- Defines timeframe windows for layering up to supply hedge targets
- Bounded view of the market: % around equilibrium
- Maintain flexibility and cost effectiveness




Balanced Position Hedge Program: Goals

- Purchases slide forward from prompt month → min/max targets
- Purchase layers are *guides*, not absolutes: maintain flexibility to adjust
- Sliding purchase scale is synchronized to budget cycles
- Basis managed separately from NYMEX commodity pricing

Balanced Position Hedge Program: Backtesting

- Budget Year FOM index + transport + fuel
- Yearly budget costs
- 3 year average FOM index + transport + fuel
- 3 year average budgeted costs

University of Minnesota Hedge Position



*Thank you for your
time and attention!*

**To learn more about College/University Energy
Management, please contact:**

Matt Haakenstad

Vice President, Advisory Services

U.S. Energy Services

mhaakenstad@usenergyservices.com

763-543-4640

www.usenergyservices.com

Bruce Hoffarber

Vice President, Market Development

bhoffarber@usenergyservices.com

763-543-4625

Jerome Malmquist

Director, Energy Management

University of Minnesota

malmq003@umn.edu

612-625-3438


Appendix



Electric Sizing Limited by Loads

EAST BANK: ELECTRIC DEMAND VS. CHP CAPACITY

NON-PEAK ELECTRICAL SEASON (FALL/WINTER/SPRING)



Electric Sizing Limited by Loads

EAST BANK: ELECTRIC DEMAND VS. CHP CAPACITY

PEAK ELECTRICAL SEASON: SUMMER

