

EMBRACING THE CHANGE

TO

PRE-INSULATED PIPE SUPPORTS

WHAT ARE THEY?

WHY USE THEM?



EXHIBITOR
BOOTH 47

RILCO MANUFACTURING COMPANY

Kerry A. Esmond

<http://www.rilco.com>

kesmond@rilco.com

713-818-1561



PRE-INSULATED SUPPORTS FOR DISTRICT ENERGY APPLICATIONS



ABOVE GROUND PIPING FOR DISTRIBUTION
ABOVE GROUND PIPING IN PLANTS
PIPING IN TUNNELS
PIPING IN TRENCHES



RILCO MANUFACTURING COMPANY

<http://www.rilco.com>

kesmond@rilco.com

Kerry A. Esmond

713-818-1561

EFFICIENCY

**Isn't this a core objective of IDEA
and District Energy?**




**SUPPORTS THAT
WELD DIRECTLY TO PIPE
OR
CLAMP DIRECTLY TO PIPE**

HAVE DOCUMENTED INEFFICIENCIES



WELDED SUPPORTS ON AN INSULATED LINE



PRE-INSULATED SUPPORTS ISOLATE THE PIPE FROM THE OUTSIDE STRUCTURE FOR MAXIMUM EFFICIENCY

PRE-INSULATED SUPPORTS
OFFER AN IMMEDIATE THERMAL
BREAK

ELIMINATES “RADIATOR FIN” HEAT
LOSS THROUGH THE BASE

KEEPS BTU’S IN OR OUT OF THE
PIPE DEPENDING ON
TEMPERATURE OF SERVICE



CASE #1: CALCULATION OF COMPARITIVE HEAT LOSS OF VARIOUS PIPE SUPPORT DESIGNS and OPERATING COSTS

As a baseline calculation, “ASTM C680-10 Standard Practice for Estimate of the Heat Gain or Loss and the Surface Temperatures of Insulated Flat, Cylindrical, and Spherical Systems by Use of Computer Programs” is used to predict the surface temperature and heat loss of the insulation system. To evaluate the heat loss of the two pipe support designs, a CFD (computational fluid dynamics) program, Autodesk CFD 360-2015 calculation is utilized.

Using ASTM C680-10 calculations, We compared:

36” pipe with **100mm** of Mineral Wool, process temperature 296 °C. with a welded support that was insulated over the pipe and support

36” pipe with **40mm** of Pyrogel XT, process temperature 296 °C. using a pre-insulated pipe support


36” pipe with **50mm** of Pyrogel XT, process temperature 296 °C. using a pre-insulated pipe support

- All pipe lengths 1 meter
- * Native insulation of each over the pipe was calculated for a baseline without supports

RESULTS OF PIPE SUPPORT COMPARISON

Table 3-Comparison of Heat Loss and Surface Temperature of Native Insulation, welded on support and Insulated Designs

| Pipe Size | Pipe OD (in) | Insulation Thk(mm) | Insul Type | Process Temp (deg C) | Surface Temp. Native Insulation per CFD (deg C) | | | Heat Loss Native Insulation CFD (W/m) | Heat Loss of Weld Design and Insulated Design with High Strength Inserts CFD (W/m) | % Diff. |
|-----------|--------------|--------------------|------------|----------------------|---|-----------------------|--|---------------------------------------|--|---------|
| 36" | 36 | 100 | MW | 296 | 1.34 | WELDED SUPPORT | | -589.8 | -4107 | 596.3% |
| 36" | 36 | 40 | PG | 296 | 2.78 | PRE-INSULATED SUPPORT | | -605.6 | -870.2 | 43.7% |
| 36" | 36 | 50 | PG | 296 | -0.048 | PRE-INSULATED SUPPORT | | -478 | -745.25 | 55.9% |



**PERCENT HEAT LOSS FROM NATIVE INSULATION
NOTE WELDED SUPPORT SYSTEM**

COST ANALYSIS

Assuming an energy cost of \$6.00 per MMBTU,

Table 6 compares the net energy costs in utilizing weld on and insulated pipe support versus the same one meter section of pipe with the native insulation.

Table 7 extends the energy costs and savings assuming a system total of 200 support quantity.

ONE METER SUPPORT / PIPE SECTION

Table 6 -Calculation of Approximate Net Energy Costs between Native Insulation and Insulated Supports/ Weld on Supports

| Pipe Size | Insulation Thk(mm) | Insul Type & Support Type | Native Insulation Energy Cost per year @ \$6 MMBTU | Weld on and Insulated Support Cost @ \$6/USD per MMBTU | % Increase over Native Insulation | Energy Cost increase at Support over Native Insulation | 5 Year Energy Cost increase at Support over Native Insulation |
|-----------|--------------------|---------------------------|--|--|-----------------------------------|--|---|
| 36" | 100 | MW(Weld on) | \$ 105.78 | \$ 736.56 | 596.3% | \$ 630.78 | \$ 3,153.91 |
| 36" | 40 | PG(Insulated) | \$ 108.61 | \$ 156.06 | 43.7% | \$ 47.45 | \$ 237.27 |
| 36" | 50 | PG(Insulated) | \$ 85.73 | \$ 133.65 | 55.9% | \$ 47.93 | \$ 239.65 |

200 EACH SUPORTS AND ASSOCIATED PIPING



Table 7 -Calculation of Net Total System Energy Cost Savings Assuming a System Total of 200 Supports

| Pipe Size | Insulation Thk(mm) | Insul Type & Support Type | Annual Energy Cost increase at Support over Native Insulation for Single Support | Assumed Quantity of Supports in System | Annual Energy Cost increase at Support over Native Insulation for System | Annual Net Savings of Pipe Support Design versus Weld on Support | 5 Year Energy Cost increase at Support over Native Insulation for System | 5 Year Net Savings of Pipe Support Design versus Weld on Support |
|-----------|--------------------|---------------------------|--|--|--|--|--|--|
| 36" | 100 | MW(Weld on) | \$ 630.78 | 200 | \$ 126,156.39 | N/A | \$ 630,781.96 | N/A |
| 36" | 40 | PG(Insulated) | \$ 47.45 | 200 | \$ 9,490.78 | \$ 116,665.61 | \$ 47,453.91 | \$ 583,328.04 |
| 36" | 50 | PG(Insulated) | \$ 47.93 | 200 | \$ 9,585.83 | \$ 116,570.56 | \$ 47,929.17 | \$ 582,852.79 |

VISUAL REPRESENTATION OF COST COMPARISON


GRAPHS SHOW ONE SUPPORT ON ONE METER OF PIPE.

EXTRAPOLATE TO YOUR PROJECT SIZE




COMPUTER MODELING OF HEAT LOSS


WELDED SUPPORT




WELDED SUPPORT (INSULATION HIDDEN)




PRE-INSULATED SUPPORT



PRE-INSULATED SUPPORT (STEEL HIDDEN)



CASE #2: THERMAL LOSS TEST COMPARISON OF 3 TYPES OF PIPE SUPPORTS



PRE-INSULATED
SUPPORT



WELD-ON SHOE



CLAMP-ON SHOE

NOTE: Testing was performed in a shop environment at approximately 75-80 degrees F (24 degrees C). The test was performed in a calm environment with NO WIND. WIND across the system, and especially the WELDED support will significantly affect the heat loss and energy usage.



WATT
METER




THERMAL
LOGGING

THERMALLY TESTED PIPE SUPPORTS

INFRARED PHOTOGRAPHY OF HEAT LOSS


PRE-INSULATED SUPPORT



24" STEAM
LINE
SUPPORTS



343 Degree C
(650 Degree F)

WELD-ON SUPPORT



12" PROCESS
SUPPORTS

621 Degree C
(1150 Degree F)



RILCO GUIDE SUPPORT



RILCO PYROWRAP

HOT SERVICE PYROGEL XT
GUIDED
PRE-INSULATED PIPE SUPPORT


Pipe Size: 24"
Insulation Thickness: 20 mm
Length: 900 mm

Design Temperature: 343 Degree C (650 Degree F)

Vertical Load: 65 kN (14,613 lbf)
Lateral Load: 65 kN (14,613 lbf)
Axial Load: N/A

3.4
Kwatt/hour
to Retain
Heat
Saturation

651 °F
344 °C
PIPE



WELD-ON SUPPORT



SUNCOR

LS1-3-A-24"

WELDED PIPE SUPPORT


Pipe Size: 24"
Insulation Thickness: 0mm (20 mm over support)
Length: 900 mm

Design Temperature: 343 Degree C (650 Degree F)

Vertical Load: 65 kN (14,613 lbf)
Lateral Load: 65 kN (14,613 lbf)
Axial Load: N/A

4.6
Kwatt/Hour
to Retain
Heat
Saturation

656 °F
347 °C
PIPE



ENERGY USAGE COMPARISON

| ENERGY USAGE COMPARISON-PER <i>EACH</i> SUPPORT | | |
|---|------------|--|
| Weld-on vs Rilco Guide | 1.2 | Kwatt/Hour More Energy Required For Weld-on |
| Clamp-on vs Rilco Guide | 1.5 | Kwatt/Hour More Energy Required For Clamp-on |

| | | |
|--|---------------|-----------------------|
| 1.2 Kwatt/Hour Saved from EACH Support | = 1.2 | Kwatts saved PER HOUR |
| 1000 Supports | = 1,200 | Kwatts PER HOUR |
| 24 Hours in One Day | = 28,800 | Kwatts PER DAY |
| 365 Days in One Year | = 10,512,000 | Kwatts PER YEAR |
| 30 Year Plant Life Estimate | = 315,360,000 | Kwatts LIFE PLANT |

| CONVENTIONAL PIPELINE EFFICIENCY LOSSES AS COMPARED TO RILCO SUPPORTS | | | | | | | |
|---|--|------------|------------|--|--|---------------------------|---|
| | | EVERY HOUR | 8,331 | Cubic Feet of Natural Gas Energy is WASTED at pipe support points due to IN-Efficient supports | | | |
| | | EVERY DAY | 199,936 | | | | |
| | | EVERY YEAR | 72,976,749 | | | | |
| UPSTREAM ENERGY IN "X" |  | | | | | DOWNSTREAM ENERGY OUT "Y" | "Y" = "X" minus M Btu lost and wasting volumes of Cubic Feet of Gas |
| | | EVERY HOUR | 8.56 | M Btu's are LOST at pipe support points due to IN-Efficient Supports | | | |
| | | EVERY DAY | 205.53 | | | | |
| | | EVERY YEAR | 75,020.10 | | | | |

CASE #3: PRE-ASSEMBLY OF PIPELINES TAKING THE MODULAR APPROACH TO BUILDING A PIPELINE



BENEFITS OF PRE-ASSEMBLED PIPELINES

ABILITY TO PRE-INSTALL OFFSITE MINIMIZING LAYDOWN SPACE ISSUES

PIPE SYSTEM CAN BE PRE-ASSEMBLED PRIOR TO PROJECT STARTUP

EFFICIENT PRE-INSTALLATION REDUCES LABOR TIME IMPROVING PROJECT SCHEDULE AND REDUCING COSTS

SAFE PRE-INSTALLATION AT WAIST HIGH CONDITIONS

VERY EFFICIENT ON STRAIGHT PIPING RUNS USING UP TO 80 FOOT LONG SECTIONS OF PIPE

PROVEN COST SAVINGS

OTHER BENEFITS OF PRE-INSULATED SUPPORTS

INSTALLATION PRE-INSULATED SUPPORTS

VERSUS

SUPPORTS THAT WELD OR CLAMP DIRECTLY TO PIPE

INSTALLATION COMPARISONS

BETWEEN VARIOUS TYPES OF PIPE SUPPORTS

INSTALLATION PROBLEMS WITH NON-INSULATED SUPPORTS

WELD-ON SUPPORTS

1.) EXPENSIVE LABOR RATES TO WELD AND TIME CONSUMING WELDING AND FOR QC



2.) TIME CONSUMING LABOR TO TRIM INSULATION AND JACKET AROUND STEEL RIBS



EASY INSTALLATION USING PRE-INSULATED SUPPORTS

PRE-INSULATED SUPPORTS

1.) BOLT-ON TO PIPE FOR FAST SECURE INSTALLATION



2.) AFTER BOLTING YOU ARE FINISHED AS THE INSULATION AND JACKET ARE PART OF THE SUPPORT AND ARE INSTALLED AS WELL



CORROSION UNDER INSULATION

PRE-INSULATED SUPPORTS

VERSUS

SUPPORTS THAT WELD OR CLAMP DIRECTLY TO PIPE



CORROSION UNDER INSULATION

**PRE-INSULATED SUPPORTS TOTALLY ISOLATE
THE PIPE FROM THE OUTSIDE STRUCTURE**

PRE-INSULATED SUPPORTS



**WELDED
SUPPORT**



CONDENSATION



PRE-INSULATED SUPPORTS

VERSUS

SUPPORTS THAT WELD OR CLAMP DIRECTLY TO PIPE

**PRE-INSULATED SUPPORTS TOTALLY ISOLATE THE PIPE FROM THE
OUTSIDE STRUCTURE**

**PRE-INSULATED SUPPORTS CAN INCLUDE A SEALED VAPOR BARRIER SYSTEM TO
ELIMINATE CONDENSATION**



PRE-INSULATED SUPPORT TYPES

RILCO PIPE SUPPORT INSULATION MATERIAL OPTIONS



**ASPEN AEROGELS-PYROGEL-XTE
ASPEN AEROGELS-CRYOGEL-Z
CALCIUM SILICATE
ESLIN
FOAMGLAS
ARMACEL
HIGH DENSITY POLYURETHANE (PUF)
TRYMER
PERLITE**



COMBINATIONS OF DIFFERENT INSULATIONS

SO, WHY USE PRE-INSULATED SUPPORTS ?

EFFICIENT - SAVES ENERGY
SAVES OPERATING COST

EASY TO INSTALL - SAVES CONSTRUCTION TIME
SAVES CONSTRUCTION COST

BENEFITS – CAN BE BUILT USING VARIOUS TYPES OF
INSULATION TO WORK WITH YOUR SYSTEM

THEY CARRY THE LOADS OF YOUR PIPE

PROTECT AGAINST CORROSION (CUI)

PROTECT AGAINST CONDENSATION



RILCO MANUFACTURING COMPANY

<http://www.rilco.com>

kesmond@rilco.com

Kerry A. Esmond

713-818-1561

DOESN'T IT MAKE SENSE TO
“**EMBRACE THE CHANGE**”
TO
PRE-INSULATED PIPE SUPPORTS ?



WANT TO LEARN
MORE ABOUT
PRE-INSULATED
PIPE SUPPORTS?

COME VISIT ME AT
BOOTH 47

RILCO MANUFACTURING COMPANY

Kerry A. Esmond

<http://www.rilco.com>

kesmond@rilco.com

713-818-1561

