

PSU Burrowes Rd Steam Manhole Repair

Presented by:

Ron Pristash, Penn State University

Andy Price, Affiliated Engineers, Inc.



PennState




International District Energy Association
Campus Energy 2017
February 20-24, 2017

Penn State University


- **West Campus Steam Plant**
 - 338,000 pph steam production
 - 5.2 MW electric production
- **East Campus Steam Plant**
 - 317,000 pph steam production
 - 7.0 MW electric production
- **Distributed Central Chilled Water System**
 - Three plants produce 18,800 tons chilled water




Pennsylvania State University Btu per Square Feet and Total Square Feet



PSU Steam Distribution



PSU Steam Tunnels



Low Pressure Steam System

- **Superheated steam is produced at 250 psig, 540°F**
 - Turbine driven equipment
 - Backpressure turbines
 - Pressure reducing valves
- **High pressure steam distributed at 150 psig, (400°F)**
- **Low pressure steam distributed at 13 psig, saturation (230°F)**
 - Multiple design conditions used over history of University
 - Distribution system includes pressure reducing stations in manholes and tunnel zones. Pressure reducing stations do not include desuperheaters.

High Temperature Event




High Temperature Event


- **During routine preventative maintenance, steam crew observed damage to piping systems in manholes along Burrowes Road including**
 - **Concrete manhole damage**
 - **Broken concrete pedestals**
 - **Sheered steel anchors**
 - **Bent all-thread**
 - **Disconnected steel supports**

High Temperature Event

- **High pressure is supplied along Burrowes Rd to manhole 138 where it is reduced in pressure to supplement the low pressure system.**
- **Plant trend data shows high steam temperatures**
- **High Pressure Desuperheater discharge temperatures in excess of 500°F**
- **High to Low Desuperheater discharge temperatures in excess of 450°F**

Existing System





System Failures

THERMAL EXPANSION OF PIPE PENN STATE UNIVERSITY			
PIPING SEGMENT	DISTANCE (FT)	EXPANSION	
		DESIGN TEMP (240°F STEAM) (IN)	HIGH TEMP (500°F STEAM) (IN)
PLANT TO MH-226	139	2.1	5.3
MH-226 TO MH 227	171	2.6	6.5
MH-227 TO ANCHOR	118	1.8	4.5
ANCHOR TO MH-228	128	1.9	4.8
MH-228 TO ANCHOR	60	0.9	2.3
ANCHOR TO MH-229	118	1.8	4.7
MH-229 TO ANCHOR	78	1.2	3.0
ANCHOR TO MH-230	86	1.3	3.3
MH-230 TO MH-231	361	5.4	13.7
MH-231 TO MH-232	141	2.1	5.3

- **Manholes**
 - **227**
 - **229**
 - **230**
 - **231**
 - **238**
- **Tunnel Zone S**



MH 227

Spalling at MH
entrances



MH 227

- Expansion Joints reached limit stops
- Additional force exceeded concrete pedestal design





MH 229

- Slip expansion joints 'bottomed out'



MH 229





MH 230



MH 230

MH 230

- Pipe 'sprang' to new location following anchor failure



MH 231

**Large concrete pedestal
sheared at location of
embeds**





MH 231



MH 231

MH 231

- Bent, then sheared $\frac{3}{4}$ " embeds



MH 231

- Pipe moved laterally after anchor failure



MH 238



- Event 'tested' designs of piping systems further away from Power Plant
- Elbow replaced with tee in field without calculating new pipe stress
- Computerized pipe stress analysis *below* allowable stress with elbow, *above* allowable stress with tee

Tunnel Section S

- **Additional expansion resulted in anchor bolts bending until welds failed**




MH 227



MH 230





Design Standards




Design Standards

- **While normally saturated, due to the fact that the LPS is a byproduct of the co-generation steam turbines, this system could experience a temperature excursion. Temperature of the steam can reach 450°F if the desuperheater fails. As such, all LPS piping in the tunnels shall be designed for expansion associated with an excursion temperature of 450°F. Cast iron, malleable iron, brass and bronze components are prohibited.**
- **HPS shall be designed for expansion associated with a design temperature of 500°F.**


Expansion Compensation – Natural Flexibility

- **Loops, z-bends, L-bends – used with direct buried or conduit piping**



Expansion Compensation – Slip Joints

- **Select with sufficient travel,**
i.e. do not 'over engineer' a selection




Expansion Compensation

- **Double Slip Type Expansion Joints should not be used in tunnel or manholes.**
- **Preferred method is two single slip expansion joints with anchored spool piece**
 - **Order slips without reducers**
 - **Good location for building take-off and drip legs**



Expansion Compensation – Slip Joints

- Pipe must be aligned with slip joint for proper performance



- Guide pipe according to manufacturer's recommendations

Forces on Anchors


- Anchor must withstand pressure force, friction force in the expansion joint, and friction force from contact between pipe and pipe supports and guides
- Force on Anchor $\rightarrow F_A = F_P + F_C + F_S$
 - Pressure force, F_P
 - Force of compression, F_C
 - Friction force from supports, F_S



Forces on Anchors

- Anchor design must consider warm up and isolation conditions

i.e. forces may not be equal and opposite



Questions?

