

\$\$ DISPATCHING FOR DOLLARS \$\$

REALIZING INVESTMENT VALUE



Kurt Koenig

kkoenig@burnsmcd.com

919-900-1864

Agenda/ Overview

- Objective
- What have I got
- Why do we have it?
- What's at stake?
- Toolbag
- The Pudding
- Questions & Answers

Objective

3 Years Ago




2 Years Ago



18 Months Ago


4 Months Ago

A Week Ago




Objective

TODAY



What Have I Got? _____

- Combustion Turbine?
- Backpressure Steam Turbine?
- Extraction/Condensing Steam Turbine?
- New Steam Driven Equipment?
- Bunch of Variable Frequency Drives?



What Have I Got?

- **SAFETY**
- **Performance Curves**
 - Do the appropriate people have access to them
- **Training**
 - Who is getting it? Operators, Engineers, Managers, Accountants
 - When is it happening? Before/After equipment is in operation? During commissioning? In the future?
- **PM Schedules**
 - Who is contracted to perform?
 - Are they loaded in CMMS software?
 - Has OEM reviewed?
 - Are procedures readily available?
- **What are the Limits**
 - Ramp Rates
 - Emissions
 - Emergency procedures

**Think about these
early and often!**

Why do I have it?

- Who's Idea Was It?
- What's the Goal?
 - Improve efficiency?
 - Save Money?
 - Increase Reliability?
 - Reduce Emissions?
- What Operating Profile Was Anticipated?
 - 24/7, 365 at 100%
 - Seasonal Loading
 - Daily Loading
 - Cyclic
 - Emergency




What's at Stake?

- **Emissions Targets**
 - What's the Bogey? 20% Reduction?
 - What's the penalty/reward?
- **Reliability Targets?**
 - Blackstart?
 - % availability?
 - Know the cost of downtime, seasonally.
- **Dollars and Cents**
 - What did the asset cost?
 - What are the anticipated annual, monthly, hourly savings?
 - Know the impact of derates
 - How was the project funded? Performance Contract?
 - WHAT WAS IT SUPPOSED TO SAVE?

TOOLBAG

- What are the right tools for decision making and who needs them?
 - Annually – Senior Management, Accountants, Energy Managers, Commodity Purchasers
 - Seasonally – Maintenance Planners/Managers, Plant Managers, Asset Managers, Dispatchers, Production Managers
 - Monthly/Weekly – Energy Managers, Operators
 - Daily/Hourly – Operators



TOOLBAG

Simple


- Laminated Charts
- Sequencing Charts

Moderate

- Spreadsheets
- What if tools



Advanced

- DCS Integrated, real time decisions tools
- Dynamic thermodynamic models



TOOLBAG

MODERATE



	BASE OPERATION \$/hr	ALTERNATE OPERATION			
		\$/hr	\$/day	\$/month	\$/year
BASE PURCHASE	\$780	\$0	\$0	\$0	\$0
RTP PURCHASE	\$600	-\$341	-\$8,187	-\$249,021	-\$2,988,178
CTG	\$275	\$46	\$1,106	\$33,645	\$403,740
DB	\$0	\$0	\$0	\$0	\$0
Boiler A	\$1,309	\$0	\$0	\$0	\$0
Boiler B	\$0	\$327	\$7,854	\$238,885	\$2,866,623
Boiler C	\$300	-\$300	-\$7,195	-\$218,838	-\$2,626,050
Boiler C1	\$866	\$188	\$4,510	\$137,139	\$1,646,118
Boiler D	\$1,018	\$0	\$0	\$0	\$0
DIESEL	\$0	\$0	\$0	\$0	\$0
TOTAL FUEL	\$3,767	\$261	\$6,275	\$190,832	\$2,290,431
CURRENT COST	\$5,148	-\$80	-\$1,912	-\$58,190	-\$697,747

TOOLBAG

MODERATE

UNIVERSITY

Inputs and Assumptions



Dispatch Year
 Selected Operation Mode

Gas Turbine Model

GT Maintenance Start Date month day
 9/1/2013

GT Maintenance End Date month day
 9/2/2013

HTHWG - 3
 Hot Water Output MBTU
 Combustion Efficiency
 Low Fire Limit MBTU

HTHWG - 4
 Hot Water Output MBTU
 Combustion Efficiency
 Low Fire Limit MBTU

HTHWG - 6
 Hot Water Output MBTU
 Combustion Efficiency
 Low Fire Limit MBTU

Natural Gas Pricing
 HP Natural Gas per MMBTU
 LP Natural Gas per MMBTU

Electric Rates Sch. 9

Customer Charge per customer
 Facilities Charge per kW

Power Charge

On-Peak 1 per kW Months to Hours to
 On-Peak 2 per kW Months to Hours to
 Off-Peak

Energy Charge

On-Peak 1 per kWh Months to Hours to
 On-Peak 2 per kWh Months to Hours to
 Off-Peak 1 per kWh
 Off-Peak 2 per kWh

DSM Cost Adjustment

Electric Rates Sch. 31

Customer Charge per customer
 Facilities Charge per kW

Contract Supply MW
 Contract Back-Up MW

Back-up Power Charge

On-Peak per kW Day Hours to
 Maint 1/2 On-Peak Charge
 Off-Peak

Excess Power Charge

Primary Voltage per kW

DSM Cost Adjustment

Hourly Dispatch Mode

Loads

Hot Water MBH Ambient Air Temp F
 Elec Sub Bank #4 MW/h
 Elec Sub Bank #5 MW/h

Month
 Day
 Time 00:00 military

Fuel and Electric Cost

	Gas Cost	kwh Cost	kw Cost	Total Cost
HRSG First	\$569	\$316	\$94,767	\$95,652
BLRS First	\$341	\$595	\$178,718	\$179,655
T70 Off	\$341	\$595	\$178,718	\$179,655

Dispatch Output

Running Operation Mode





Gas Turbine Avg Load
 DB Avg Load
 HTHWG - 3 Efficiency
 HTHWG - 4 Efficiency
 HTHWG - 6 Efficiency

Fuel and Electric Cost

HRSG First per year
 BLRS First per year
 T70 Off per year

HRSG Peak Following

Cost **Most economical combination
 Starts Stops * This is happening every eight hours during the all year except when excess powers required this is pretty one off because in reality this maybe unpredictable and an absord number of swings
 Hours T70 off



- DCS Integrated Dispatch Recommendations
- Dynamic thermodynamic modeling that measures and predicts plant and equipment performance including degradation.
- Commodity Market and weather inputs
- Economic reporting

TOOLBAG

ADVANCED


Location	Newark	Update Input Fields	Load GateCycle
Prime Mover	Titan 250		
Design		Run This Case	Run & Update Summary
Ambient Temperature (F)	55		
Relative Humidity	0.6		
Elevation (ft)	30		
Engine Power Output (kW)	21,340		
Engine Net Heat Rate (Btu/kW-hr, LHV)	8,952		
Engine Exhaust Flow (lb/hr)	541,124		
Engine Exhaust Temp (F)	889		Run & Update All Cases

Off Design	99% Fired	99% Unfired	1% No IC Fired	1% No IC Unfired	1% IC Fired	1% IC Unfired	ISO Fired	ISO Unfired
Ambient Temperature	15.5	15.5	91	91	91	91	59	59
Ambient Relative Humidity	0.6	0.6	0.6	0.6	0.6	0.6	0.6	0.6
Equivalent Elevation	30	30	30	30	30	30	30	30
Net Power	23,493	23,493	17,800	17,800	17,800	17,800	21,006	21,006
Net Heat Rate	8,881	8,881	9,428	9,428	9,428	9,428	8,981	8,981
Exhaust Gas Outlet Flow	578,616	578,616	480,324	480,324	480,324	480,324	535,248	535,248
Exhaust Gas Outlet Temperature	848	848	911	911	911	911	872	872

SPHT1[SPHT]	SuperheaterODMethodFlag[0]
TMX1[TMX]	DesiredOutletTemperature[0]
V1[PIPV/LV]	DesiredInletPress[0]
AUX1[AUXBLR]	DesiredFlow[0]
ST1[ST]	BypassSTFlag[0]
ST1[ST]	Pres[1]
ST1[ST]	UserInputEfficiency[0]
SYSTEM[SYSTEM]	BOPLossasFixedValue[0]
SPHT[MACRO]	Enabled[0]
STE[MACRO]	Enabled[0]
MU1[MAKEUP]	Temp[1]

GateCycle Outputs	
SYSTEM[SYSTEM]	AmbientTemperature[0]
SYSTEM[SYSTEM]	AmbientRelativeHumidity[0]
SYSTEM[SYSTEM]	EquivalentElevation[0]
DB1[BURNER]	MethodFlag[0]
ELC1[CHILLER]	ElectChillerMethodFlag[0]
S35[GAS]	Pres[1]
C1[GTCOMP]	Pres[1]
S24[SINK]	Flow[0]
S24[SINK]	Pres[0]
S24[SINK]	Temp[0]
S24[SINK]	Enth[0]
ST1[ST]	Flow[0]
ST1[ST]	Pres[0]
ST1[ST]	Temp[0]
ST1[ST]	Enth[0]
ST1[ST]	Flow[1]
ST1[ST]	Pres[1]
ST1[ST]	Temp[1]
ST1[ST]	Enth[1]
FPT1[FPTMOD]	Flow[1]
FPT1[FPTMOD]	Pres[1]
FPT1[FPTMOD]	Temp[1]
FPT1[FPTMOD]	Enth[1]
S31[SOURCE]	Flow[1]
S31[SOURCE]	Pres[1]
S31[SOURCE]	Temp[1]
S31[SOURCE]	Enth[1]
DA1[DEAER]	Flow[2]
DA1[DEAER]	Pres[2]
DA1[DEAER]	Temp[2]
DA1[DEAER]	Enth[2]
DA1[DEAER]	Flow[3]


		GC Version:	
		Date:	
		Starting Time:	
		Ending Time:	
		Status:	
s	UOM	Description	Case No Value
	F	Ambient Temperature	40.8
		Ambient Relative Humidity	0.6
	ft	Equivalent Elevation	20
	MW	Net Power	22.2
	BTU/kW-hr	Net Heat Rate	8,905
	lb/hr	Exhaust Gas Outlet Flow	556,889
	F	Exhaust Gas Outlet Temperature	860
	kW	Auxiliary Losses	187
		Elect. Chiller Method Flag	0
	F	Desired Gas Outlet Temperature	40.8
	psig	Outlet Pressure	350
	psig	Desired Exit Pressure	426
		Firing Method Flag	1
	F	Desired Burner Exit Temperature	1500
		Superheater OD Method Flag	3
	F	Desired Outlet Temperature	750
	psig	Desired Exit Pressure	750
	lb/hr	Desired Flow rate	0
		Bypass ST Flag	Y
		ST Exit Pressure	750
		Overall Efficiency	0.871039867
	kW	BOP Loss as Fixed Value	400
		Macro Enabled	Y
		Macro Enabled	N
	F	Outlet Temperature	125
	F	Ambient Temperature	41
		Ambient Relative Humidity	1
	ft	Equivalent Elevation	20
		Firing Method Flag	1
		Elect. Chiller Method Flag	0
	psig	Outlet Pressure	350
	psig	Main Outlet Pressure	426
	lb/hr	Inlet Flow	134,648
	psig	Inlet Pressure	747
	F	Inlet Temperature	750
	BTU/lb	Inlet Enthalpy	1372
	lb/hr	Steam Inlet Flow	146616
	psig	Steam Inlet Pressure	750
	F	Steam Inlet Temperature	750
	BTU/lb	Steam Inlet Enthalpy	1372
	lb/hr	Main Outlet Flow	146616
	psig	Main Outlet Pressure	750
	F	Main Outlet Temperature	750
	BTU/lb	Main Outlet Enthalpy	1372
	lb/hr	Outlet Flow	67,324
	psig	Outlet Pressure	0
	F	Outlet Temperature	180
	BTU/lb	Outlet Enthalpy	148
	lb/hr	Outlet Flow	70,163
	psig	Outlet Pressure	0
	F	Outlet Temperature	70
	BTU/lb	Outlet Enthalpy	79
	lb/hr	Main BFW Inlet Flow	2,349
	psig	Main BFW Inlet Pressure	125
	F	Main BFW Inlet Temperature	125
	BTU/lb	Main BFW Inlet Enthalpy	133
	lb/hr	Main Steam Inlet Flow	11,069



The Pudding






- Savings Realized
- Budget Variances
- Emissions Reductions



Summary

- Establish a feed forward loop
 - Consultants, Engineers, OEM's
- Budget for the tools to make great decisions
 - Simple to Advanced, select according to situation, market, and assets
- Respond to market changes
 - Why do we run like this? Is it still appropriate?
- Understand equipment
 - Degradation, limits, upgrades

Summary



Questions & Answers

Thank You

Kurt Koenig
Project Manager
Burns & McDonnell
OnSite Energy & Power
919-900-1864
kkoenig@burnsmcd.com