

10th Street Chiller Plant Capacity Optimization

June 22, 2016



Ever-Green Energy

www.ever-greenenergy.com

Problem Summary

- 10th Street Plant operating below capacity on design day
- Towers were not able to achieve design return temperature
- How much was plant performance reduced?
- How do you determine performance loss and improvement on real time basis?
- How do you measure improvement when implementing changes?



Project Objective

- Evaluate methods to improve or increase capacity
- Implement improvements to optimize plant performance
- Set up data collection and trend operating data to determine plant performance based on historic and real time data
- Allow for periodic review of historical performance
- Allow operators to monitor performance in real time basis
- Minimize project cost



10th Street Plant

- Chillers: 1 x 2000 TR, 2 x 2500 TR
- Cooling towers: 1 x 6,500 gpm, 5 x 3,000 gpm
- Storage tank: 1 x 35,000 ton-hr



Step 1 Troubleshooting

- Ockham's Razor: *look at simple solutions first*
 - Housekeeping
 - Mechanical
 - Commissioning



Step 1 Troubleshooting



Visual Inspection

- Tower fouling

Solution

- Review water treatment
- Scale: water jet pipes



Step 1 Troubleshooting

Operational

- Tower 4 overflow soaking cars and drift
- Fans on Tower 5 and 6 VFD choked at 50 hz

Solution

- Verify drift eliminators install properly
- Install overflow pipe and route to basin
- Vibration problem - analyze



Step 1 Troubleshooting


Vibration Problem

- Check vibration switch calibration
- Tower mechanical (visual and vibration testing)
- Install method to tension cross bracing
- Test at full speed
- Repeat until problem resolved



Step 2 Recommission

- Optimize fan operation with blade pitch to draw design power on design day (all fans found to be drawing below design power)



Description 10th Street Plant Cooling Tower As Left
 Date: 23-May-14
 Ambient Temp: 65 dF

| Tower | HMI Speed (hz) | VFD (hz) | VFD (Amps) | | Hp | Motor Nameplate*** | | | | | Fan Blade Pitch | | Vib. Switch | | |
|-------|-------------------|-------------|------------|--------|-----|--------------------|---------|------|------|---------------|-----------------|-----------|----------------------|------|-------|
| | | | As FND | As LFT | | FLA | Voltage | RPM | SF | Inverter Duty | As FND | AS Left | Model | Trip | Alarm |
| 4 | LO | | | | 100 | 114 | 460 | | 1.15 | Two Speed | 13.0 | 14.0 | PMC 440D | 8.0 | 60% |
| | HI | | 105 | 110 | 100 | | | | | | | | | | |
| 5a | 60 | 60 | 82 | 107 | 100 | 116 | 460 | 1790 | 1.15 | Yes | 14.0 | 21.0 | PMC 440D | 8.0 | 100% |
| 5b | 60 | 60 | 77 | 108 | 100 | 116 | 460 | 1790 | 1.15 | Yes | 14.5 | 21.0 | PMC 440D | 8.0 | 100% |
| 5c | 60 | 60 | 86 | 106 | 100 | 116 | 460 | 1790 | 1.15 | Yes | 15.5 | 21.0 | PMC 440D | 8.0 | 100% |
| 6a | 60 | 60 | 83 | - | 75 | 84 | 460 | 1780 | 1.15 | Yes | No Change | No Change | Metrix Mechanical | | |
| 6b | 60 | 60 | 81 | - | 75 | 84 | 460 | 1780 | 1.15 | Yes | No Change | No Change | Metrix Mechanical | | |

Notes:

* Vibration Switch adjusted per input from Marley. Trip limits in SCADA eliminated.

** Tower 6A/B not adjusted.

*** Motor Nameplates read and verified in field.

**** Design Pitch for 5 A/B/C is 15.4 degrees


**** Design Pitch for 4A is 14.0 degrees



Step 3 Data Collection and Trending

Plant Performance (kW/ton)


- Power Monitoring Equipment- SCADA Data collection
 - Install PTs, CTs, and Power Meters
 - Connect to SCADA
 - Trend Data in Historian




Step 3 Data Collection and Trending

- Performance trending
- Multi mode plant operation
- Efficiency calculation
 - kW/ton
 - Tank on line
 - Tank off line
 - Charging from distribution

| PLANT EFFICIENCY | | TANK OFFLINE (TKO) | TANK ONLINE (TK1) |
|------------------|-----------|-------------------------------|-------------------------------|
| DESCRIPTION | KW/TON | KWH/TON-HR | KWH/TON-HR |
| CHILLERS | $E2/M2$ | $SUM(E2)/SUM(M2)$ | $SUM(E2)/SUM(M2)$ |
| AUX LOADS | $Eaux/M2$ | $SUM(Eaux)/SUM(M2)$ | $SUM(Eaux)/SUM(M2)$ |
| TOTAL PRODUCTION | $E1/M2$ | $[SUM(E2)+SUM(Eaux)]/SUM(M2)$ | $[SUM(E2)+SUM(Eaux)]/SUM(M2)$ |
| PLANT AVERAGE | — | $SUM(E1)/SUM(M1)$ | $SUM(E1)/SUM(M1)$ |



Step 3 Data Collection and Trending




Step 4 Data

- Historic data
- 2009-2014 rising kw/ton
- 2015 falling kw/ton

| Plant Efficiency | | Tank Offline | Tank Online |
|------------------|--------|--------------|-------------|
| Description | KW/TON | KW/TON-HR | KW/TON-HR |
| Chillers | 0.00 | 0.54 | 0.57 |
| Aux Loads | 0.00 | 0.31 | 0.45 |
| Total Production | 0.00 | 0.85 | 1.02 |
| Plant Average | | 0.87 | 1.06 |

10th Street Efficiency and Production by Year



Project: Next steps to improve performance

- Train operators and encourage efficiency improvements by multipath problem solving
- Reduce condenser water temperature (55-60 df min)
- Normalize plant efficiency to wetbulb, generate plant efficiency curve based on actual measured variable
- Plant COP/real time cost. What metric is simplest to follow?
- Variable Speed drive on tower 4

