### **Campus Energy 2021** BRIDGE TO THE FUTURE Feb. 16-18 | CONNECTING VIRTUALLY WORKSHOPS | Thermal Distribution: March 2 | Microgrid: March 16




### Making Resiliency Projects Sustainable

Exploring Power Supply Options for a Proposed California Oceanwater Desalination Plant

Marc Serna, P.E. (SCWD Chief Engineer) Mark Donovan, P.E. (GHD Desalination Program Manager) Nathan Ninemire, P.E. (Burns & McDonnell Project Manager)





## **Presentation Objectives**

Introduce Desalination Project, Purpose, and Challenges

Identify Power's Role in Resiliency / Sustainability

Summarize Options Identified to Potentially Meet Needs

Present Key Findings and California-specific Considerations





### COMMUNITY NEED

GHDWQODHEAD

# **Community Served & Identified Need**

- SCWD serves 35k residents, 1k businesses, and 2 million visitors per year in south coastal Orange County, CA
- 85-100% of drinking water comes from outside community
- Concerns: Natural disasters, droughts, and supply shortages
- Solution: Local water source that provides reliable water supply, meets community water needs, and minimizes community and environmental impact






South Coast Service Boundar

## **Project Goals Established**

SOUTH COAST

- Need-based Local Water Supply
- Cost-effective
- Community Service and Reliability

► 100% Carbon Neutral






## **Moving the Project Forward**

GHD Hired as Program Manager

Concept design using seawater reverse osmosis desalination technology

Regulatory Compliance with Ocean Plan

Community Engagement








### PROJECT DEVELOPMENT

GHDWQODHEAD

### **Project History**






SOUTH COAST

# **Project Highlights**

- Seawater reverse osmosis desalination technology
- Subsurface intake approach
- Comingled brine discharge
- Ideal location
- Community and environmental considerations










## **Project and Power Challenges**

- Environmental concerns
- Community concerns
- Challenges to moving project forward
- Power and fuel





### POWER NEEDS & OPTIONS

GHDWQODHEAD.

### **Power Source Options**

### 1. Utility Power

- ► Lower capital, higher operating
- ► Perceived lower resilience
- ► Not carbon-neutral option



### OR

### 2. Self-Generation

- Potential economic and resiliency benefit
- Potential for high-efficiency CHP
- Potential low carbon options









### **Utility Power – SDG&E; Reliability**

	DEFINITION	SDG&E (Or	ange County)	PEER UTILITIES <sup>1</sup>		
OUTAGE INDICE		2018	3-Year Average	IEEE Large Utilities <sup>2</sup>	IEEE Southwest Region	
SAIDI	Minutes Without Power / Customer	56.02	63.94	253	118	
SAIFI	Sustained Interruptions / Customer	0.585	0.587	1.37	1.1	
CAIDI	Minutes / Interruption	95.8	108.54	185	107.3	
MAIFI	Momentary Outage Customer %	0.168	0.229	NA	NA	

#### Notes:

- **1.** Based on IEEE benchmark data for 2017 operation, as 2018 not available.
- **2.** SDG&E classified as large utility with > 1M customers.





### Utility Power – SDG&E; Carbon

► 45% Renewables Now

► SDGE Emissions Factor ~28% - 45% of Fossil Fuel Self Generation Options

California 2045 Carbon Neutrality = Built-In Carbon Reduction Plan





## Utility Power – SDG&E; Costs

### Service Extension Costs (credited back)

- ► Single feed
- Redundant feeds from common substation
- Redundant feeds from different substations

### ► Tariffs

- Energy charges
- Demand charges
- Steady load means steady demand charges

► First Year Expected Blended Rates\*: >\$160/MWh with REC's

\*2020 tariffs





# Self-Generation Options; Summary

### Fuel consuming generators (CT, RICE, Fuel Cell) and Solar PV

- Solar PV for carbon
- Alternate fuels considered
- CHP considered but no use for thermal energy
- Battery storage potential

### Minimal utility import from utility

- Departing load and standby charges (beyond energy/demand charges)
- Departing load = cost for removing load from system
- Standby charges = cost for reserved capacity as backup

### Offsite generation explored if economic benefit (less resiliency benefit)





# Self-Generation Options; Resilient

Supply Option		Power Supply Configuration							
		1	2	3	4	5	6	7	
Single Electric Feed		Х	Х	Х	Х	Х	Х	Х	
Redundant Electric Feed			Х	Х					
Redundant Substation Tie-In				Х					
Dual Fuel CTG					Х				
Gas Recip						Х			
Fuel Cells							Х		
Solar								Х	
Single Failure Scenario <sup>(1)</sup>	Probability <sup>(2)</sup>	Operational Outcome							
Loss of Main Unit	8								
Single Feeder Outage	5								
Substation Outage	4								
Loss of Natural Gas Service	4								
Multiple Failure Scenario <sup>(1)</sup>									
Total Electric Utility Outage	3								
Total Utility Outage (Gas / Electric)	2								
Total Utility & Main Unit Outage	1								
Outage Results No Operational Impact Not Applicable to Configuration (1) Failure Scenario outages can be avoided by installing backup generators and site fuel storage. (2) Subjective probability scale of 1-10, with 1 being the lowest and 10 being highest.									

# Self-Generation Options; Carbon

Renewable Fuels Unavailable at Scale

Fossil fuels require REC's long term (no built-in reduction like SDGE)

Fuel cells have similar carbon to reciprocating engine but lower overall emissions

Fuel cells have more hydrogen fuel capabilities (future-proofing)





## Self-Generation Options; Carbon

Option		Self-Generation (Scope 1 Emissions)			ed Power Emissions)	Total Annual Carbon Footprint w/o RECs			
		MWh	MTCO2	MWh	MTCO2	MTCO2	Delta PP		
Base	Purchased Power (PP)	0	0	25,445	5,089	5,089	-		
1	PP + Solar PV	Reductions depend on magnitude of solar deployment							
2A	Combustion Turbine	24,173	17,872	1,272	254	18,126	256%		
<b>2</b> B	Reciprocating Engine	24,173	11,029	1,272	254	11,284	122%		
2C	Fuel Cell	23,206	11,451	2,239	448	11,899	134%		


Purchased power decreases over time but not self-generation (except fuel conversion).






## Self-Generation Options; Cost

- Traditional fossil fuel generators have lower production costs than purchased power, <u>except</u>:
  - Standby and departing load charges substantially impact economics (~50% increase)
  - CTG blended power cost > purchased power
  - RICE blended cost slightly less than purchased power
- Fuel cells financially attractive with soon-to-expire incentives (~30% less than PP)
- Solar PV attractive due to incentives, but supplements only
- Battery storage value not seen for site power, incentives or grid service could improve value





# **Considerations Moving Forward**

"Greening" of grid has built-in future-proofing and carbon reductions

- Reliable utility power allows for resiliency
- Onsite generation only cost effective with state incentives Departing load charges apply and greatly impact economics
- Onsite generation less attractive with no CHP application
- ► No clear alternative fuels. Remote LFG option may be an option
- Resiliency may be best addressed with standby generators







