

LEADING THE WAY **CampusEnergy**2022

Feb. 15-18 | Westin Boston Seaport District Hotel | Boston, Mass.



Maximizing Energy Efficiency Through Condensing Economizers

Joseph Richter, Combustion & Energy Systems, LTD.



- 
- Until a renewable energy source is available for reliable and continuous District Heating, a solution to emission reductions is Energy Efficiency through Waste Heat Recovery.
 - Utilizing waste heat not only reduces fuel consumption improving overall efficiency, but reduces greenhouse gas and carbon emissions.

The added benefit – **Lower operating costs for the same output.**

Condensing Heat Recovery Systems

- Standard heat recovery systems like economizers, can reduce boiler stack temperatures to about 250F and are designed to avoid condensation of the flue gas.
- A condensing economizer improves heat recovery by capturing energy well below the dew point of the flue gas.

The Goal: Recover the maximum amount of usable heat possible from your exhaust gas

You paid for it, you might as well use it!

Sources of Hot Gas

Combustion Sources

Boilers

Turbines

Engines

Thermal Oxidizers

Etc.


Hot Wet Air

Dryers


Ovens

Etc.

BTU Content in the fuel \neq Energy to the process or heating load




Energy From the Fuel
1. Process – 77%




Energy From the Fuel

1. Process – 77%
2. Vaporize H_2O – 15%



Energy From the Fuel

1. Process – 77%
2. Vaporize H_2O – 15%
3. Heat The Air – 6%




Energy From the Fuel

1. Process – 77%
2. Vaporize H₂O – 15%
3. Heat The Air – 6%
4. Setting Losses – 2%

Condensing Heat Recovery The Energy Bonus


- Waste heat is categorized as **sensible** and **latent heat**
- Evaporating water absorbs ~15-20% of the total heat created by the fuel and it is lost to the atmosphere in the exhaust gas



Condensing Heat Recovery Reduces This Loss!



Sensible and Latent Heat




Air to Air Heat Exchangers, Energy Wheels & Standard Economizers utilize *Sensible* Heat Recovery

(heat available through temperature change only)



Sensible and Latent Heat



Condensing Economizers are designed to take advantage of latent heat recovery by condensing the water out of flue gases.

Condensing Heat Recovery

How it Works

- By heating cold process liquids with hot boiler exhaust gases the ConDex system recovers both *sensible* and *latent* heat energy.
- As the hot exhaust passes over the ConDex finned tubes, the gases are cooled beyond the point where water vapor condenses out, releasing the energy it took to vaporize it initially.
- The phase change from vapor to liquid recovers approx.:

***1,000 BTU of Energy for every Pound of Water
Condensed***



How Much Energy Is Lost in Exhaust Gases?



Assume 80 Degree Ambient Temp.
Boiler Input – 100 MMBTU/Hr
Gas Outlet Temperature After
Standard Economizer = 350 °F
86,000 #/Hr Exhaust at 350 °F

Application: Package Boiler



How Much Energy Is Lost in Exhaust Gases?




Application: Package Boiler

Assume 80 Degree Ambient Temp.
Boiler Input – 100 MMBTU/Hr
Gas Outlet Temperature After
Standard Economizer = 350 °F
86,000 #/Hr Exhaust at 350 °F

**12.3 MMBTU/Hr Lost to the
Atmosphere!**

Condensing Heat Recovery The System





Because each installation is custom engineered, the required materials of construction are established based on the site specific requirements.

Standard material of construction is 304L stainless steel. Specialized metallurgy such as titanium, Incoloy or Hastelloy are used. Coatings such as Heresite are also used.




WATER RECOVERY FROM EXHAUST GAS


- Condensed water recovery rates vary from 4 – 60 Gallons Per Minute, depending on the application.
- Water is reusable in many applications such as boiler make up water, cooling tower water or process water.



Standard Condex Condensing Economizer

- Can take hot gas from multiple generators
- Does not interfere with existing exhaust flow
- Includes ID Fan, stack and controls
- Can heat multiple, independent liquid streams





Heat multiple independent liquid streams such as process water and make up water.



Capture heat from multiple heat sources using a single ConDex Economizer.



VICINITY

Grand Rapids, MI

Provides Steam to buildings in the downtown area for space heating and cooling, domestic hot water, chilled water, humidification and sterilization.

2 Natural Gas- Powered Boilers

Make-Up water going to the DA

Fuel Savings \$1.1 MM/Year

CO₂ Reduction: 6,350 Tons/Year

NO_x Reduction: 4.14 Tons/Year

ConDex PERFORMANCE DATA SHEET

Date: January 27, 2009	Designed by: Dan Veitch
Customer: Trigen	
Reference: Grand Rapids	
Quotation No.: 209055	MONTHLY AVERAGE DESIGN

Heat recovery system in the **Condensing** mode.

Fuel: _____ Natural Gas

Gas side: _____ Gas type _____ Boiler Flue
 Total flow rate _____ 114000 lb/hr
 Inlet temperature _____ 396 °F
 Outlet temperature _____ 127 °F
 Dew point _____ 134 °F
 H₂O vapor by weight @ inlet _____ 11.3 %
 H₂O vapor flow @ inlet _____ 12882 lb/hr
 H₂O vapor flow @ outlet _____ 10259 lb/hr
 H₂O condensed _____ 2623 lb/hr
 Specific heat @ avg. temperature _____ .026 Btu/lb.°F
 Pressure drop _____ 2.35 inch w.c.
 Fouling factor _____ .002 hr. ft². F/Btu
 Maximum velocity at inlet temperature
 through the new free area _____ 26 fps

Gas Flow: 114,000 Lb/Hr

Gas Temp In: 396 F

Gas Temp Out: 127 F

Liquid side: _____ Fluid type _____ Boiler Make Up
 Total flow rate _____ 99567 lb/hr
 Inlet temperature _____ 85 °F
 Outlet temperature _____ 190 °F
 Pressure drop _____ 10 psi
 Fouling factor _____ .001 hr. ft². F/Btu
 Velocity at average temperature _____ 4 fps

Water Flow: 99,567 Lb/Hr

Water Temp In: 85 F

Water Temp Out: 190 F


Sensible Heat Load: _____ 7,955,175 Btu/hr

Latent Heat Load: _____ 2,619,834 Btu/hr

TOTAL HEAT RECOVERED (with 2% losses) _____ 10,575,009 Btu/hr

Energy Recovered:
10.57 MMBTU/Hr









Indiana State University

Terra Haute, IN
Provides steam for heating, cooling and processes such as cooking or for research uses.

2 Natural Gas- Powered Boilers

Make-Up Water going to the DA

Fuel Savings \$339 K/Year

CO₂ Reduced: 1,939 Tons/Year

NO_x Reduced: 1.27 Tons/Year

ConDex PERFORMANCE DATA SHEET

Date:	October 26, 2009	Designed by:	Dan Veitch
Customer:	Indiana State University		
Reference:	Energy Recovery Project		
Quotation No.:	209056		

Heat recovery system in the **Dry** mode.

Fuel: _____ Natural Gas

Gas side: _____ Gas type _____ Boiler Flue
 Total flow rate _____ 92000 lb/hr
 Inlet temperature _____ 290 °F
 Outlet temperature _____ 158 °F
 Dew point _____ 134 °F
 H₂O vapor by weight @ inlet _____ 11.3 %
 H₂O vapor flow @ inlet _____ 10396 lb/hr
 H₂O vapor flow @ outlet _____ 10396 lb/hr
 H₂O condensed _____ 0 lb/hr
 Specific heat @ avg. temperature _____ 0.27 Btu/lb·°F
 Pressure drop _____ 1.50 inch w.c.
 Fouling factor _____ .002 hr· ft²· F/Btu
 Maximum velocity at inlet temperature
 through the new free area _____ 30 fps

Gas Flow:

Gas Temp In:

Gas Temp Out:

Liquid side: _____ Fluid type _____ Water
 Total flow rate _____ 95000 lb/hr
 Inlet temperature _____ 142 °F
 Outlet temperature _____ 175 °F
 Pressure drop _____ 20 psi
 Fouling factor _____ .001 hr· ft²· F/Btu
 Velocity at average temperature _____ 7 fps

Water Flow:

Water Temp In:


Water Temp Out:

Sensible Heat Load: _____ 3,179,080 Btu/hr

Latent Heat Load: _____ 0 Btu/hr

TOTAL HEAT RECOVERED (with 2% losses) _____ 3,179,080 Btu/hr

Total Energy Recovered:



No	By	Date	Checked	Date	REVISION

COMBUSTION & ENERGY SYSTEMS LTD. 25 ROYAL CREST COURT SUITE #110 MARKHAM ONT. Telephone (905) 415-9400 Fax (905) 415-9482		CUST: INDIANA STATE UNIVERSITY TITLE: CONDENS SYSTEM - PIPING & INSTRUMENTATION DRAWING	
<small>THE INFORMATION CONTAINED IN THIS DRAWING IS THE PROPERTY OF COMBUSTION & ENERGY SYSTEMS LTD. AND IS NOT TO BE COPIED WITHOUT WRITTEN PERMISSION.</small>		DRAWN BY: DHV DATE: 10/1/09	SCALE: NTS DRAWING NUMBER: 209056 APPROVED BY: REV: 0



LEADING THE WAY
CampusEnergy2022

Feb.15-18 | Westin Boston Seaport District Hotel | Boston, MA





Manhattan, KS
Provides steam for campus heating and cooling

2 Natural Gas- Powered Boilers

Make-Up Water feeding to DA

Fuel Savings: \$304 K/Year

CO₂ Reduced: 2,683 Tons/Year

NO_x Reduced: 1.75 Tons/Year

ConDex PERFORMANCE DATA SHEET

Date: August 19, 2010 Designed by: Dan Veitch
 Customer: Kansas State University
 Reference: Energy Recovery Project- Design Conditions
 Quotation No.: 210237

Heat recovery system in the Condensing mode.

Fuel: _____ Natural Gas

Gas side: _____ Gas type _____ Boiler Flue
 Total flow rate _____ 70000 lb/hr
 Inlet temperature _____ 310 °F
 Outlet temperature _____ 129 °F
 Dew point _____ 134 °F
 H₂O vapor by weight @ inlet _____ 11.3 %
 H₂O vapor flow @ inlet _____ 7910 lb/hr
 H₂O vapor flow @ outlet _____ 6741 lb/hr
 H₂O condensed _____ 1169 lb/hr
 Specific heat @ avg. temperature _____ 0.26 Btu/lb·°F
 Pressure drop _____ 1.75 inch w.c.
 Fouling factor _____ .002 hr· ft²· F/Btu
 Maximum velocity at inlet temperature
 through the new free area _____ 25 fps

Gas Flow: 70,000 Lb/Hr

Gas Temp In: 310 F

Gas Temp Out: 129 F

Liquid side: _____ Fluid type _____ Water
 Total flow rate _____ 31600 lb/hr
 Inlet temperature _____ 55 °F
 Outlet temperature _____ 195 °F
 Pressure drop _____ 8.00 psi
 Fouling factor _____ .001 hr· ft²· F/Btu
 Velocity at average temperature _____ 3 fps

Water Flow: 31,600 Lb/Hr

Water Temp In: 55 F

Water Temp Out: 195 F


Sensible Heat Load: _____ 3,302,170 Btu/hr

Latent Heat Load: _____ 1,166,442 Btu/hr

TOTAL HEAT RECOVERED (with 2% losses) _____ 4,468,612 Btu/hr

Total Energy Recovered:
4.47 MMBTU/Hr







LEADING THE WAY
CampusEnergy2022

Feb.15-18 | Westin Boston Seaport District Hotel | Boston, MA





Central
Washington
University



Ellensburg, WA

Provides steam to campus
for building heat and cooling

4 Natural Gas- Powered
Boilers

Heating loop glycol for
Samuelson Hall,
Discovery Hall and the
Health Sciences Building

Heat Recovered at Peak
6.28MM BTU/Hr

LEADING THE WAY
CampusEnergy2022

Feb.15-18 | Westin Boston Seaport District Hotel | Boston, MA



ConDex PERFORMANCE DATA SHEET

Date: March 8, 2013
 Customer: Central Washington University
 Reference: Operating Regime 3, OAT 0
 Quotation No.: 212099-R2

Designed by: Sean Burrowes

Heat recovery system in the **Condensing** mode.

Fuel: _____ Natural Gas

Gas side: _____ Gas type _____ Boiler flue
 Total flow rate _____ 51,382 lb/hr
 Inlet temperature _____ 269.2 °F
 Outlet temperature _____ 93 °F
 Dew point _____ 132°F
 H₂O vapor by weight @ inlet _____ 11.13%
 H₂O vapor flow @ inlet _____ 5,718 lb/hr
 H₂O vapor flow @ outlet _____ 1,695 lb/hr
 H₂O condensed _____ 4,023 lb/hr
 Specific heat @ avg. temperature _____ 0.267 Btu/lb.°F
 Pressure drop _____ 1.96 inch w.c.
 Fouling factor _____ 0.002 hr· ft²· F/Btu
 Maximum velocity at inlet temperature
 through the new free area _____ 18.4 fps

Gas Flow: 51,382 Lb/Hr

Gas Temp In: 269 F

Gas Temp Out: 93 F

Liquid side: _____ Fluid type _____ 30% Propylene Glycol
 Total flow rate _____ 170,000 lb/hr
 Inlet temperature _____ 73 °F
 Outlet temperature _____ 113 °F
 Density _____ 64.08 lb/ft³
 Specific heat @ avg. temperature _____ 0.924 Btu/lb.°F
 Pressure drop _____ 8.05 psi
 Fouling factor _____ 0.001 hr· ft²· F/Btu
 Velocity at average temperature _____ 5.41 fps

Glycol Flow: 170,000 Lb/Hr

Glycol Temp In: 73 F

Glycol Temp Out: 113 F


Sensible Heat Load: _____ 2,231,261 Btu/hr

Latent Heat Load: _____ 4,051,939 Btu/hr

TOTAL HEAT RECOVERED (with 2% losses) _____ 6,283,200 Btu/hr

Total Energy Recovered:
6.28 MMBTU/Hr





LEGEND PER ANSI/ISA-S5.1

-----	ELECTRICAL SIGNAL	*NF*	= NOT FURNISHED BY C.E.S.
-----	DUCTING (NOT BY CES)	*S	SHIPPED LOOSE BY C.E.S. FOR FIELD INSTALLATION BY OTHERS
-----	PIPING (NOT BY CES)		PRESSURE REGULATING VALVE WITH FILTER
---#---	INSTRUMENT AIR LINE (IAS) (NOT BY CES)		3-WAY SOLENOID VALVE
	INTERLOCK TO/FROM CONTROL PANEL		GLOBE OR GATE VALVE (HAND OPERATED)
	ANALOG SIGNAL TO/FROM CONTROLLER		BALL VALVE (HAND OPERATED)
	INSTRUMENT SYMBOL PER ISA S5.1		PRESSURE RELIEF VALVE
	C.E.S. ITEM NO.		

No	By	Date	Chgd	Date	REVISION

COMBUSTION & ENERGY SYSTEMS LTD. 25 ROYAL CREST COURT SUITE #110 MARKHAM ONT. Telephone (905) 415-9400 Fax (905) 415-9482 www.combustionandenergy.com		DIST: CENTRAL WASHINGTON UNIVERSITY - POP TITLE: CONDEX HEAT RECOVERY SYSTEM - PIPING & INSTRUMENTATION DRAWING	
DRAWN BY: S.W.B. DATE: MAR 8, 2013	SCALE: NTS APPROVED BY:	DRAWING NUMBER: 212099-R2 REV:	SHEET NO:




LEADING THE WAY
CampusEnergy2022

Feb.15-18 | Westin Boston Seaport District Hotel | Boston, MA



How does the CONDEX system work?

1. Flue gases are drawn off of the boiler stacks by fans, which push them through the CONDEX heat exchanger
2. The gases are then cooled by glycol to the point where water vapor can condense, releasing the heat it took to vaporize initially
3. As the boilers load changes, the supply control dampers open and close to capture all available flue gases
4. The remaining 90° F gases leave the heat exchanger and are discharged to the atmosphere by a separate stack.



A model of the CONDEX heat exchanger

This new innovation allows CWU to:

- Prevent burning additional natural gas
- Reduce greenhouse gas emissions
- Save money
- Recover usable water from flue gas condensation
- Enhance sustainability on campus



Davis, CA

Provides steam, electricity and chilled water to the campus.

2 Natural Gas Fired Boilers using Ultra Low NOx burners

3 heating coils

- Condensate Return
- Dormitory Heating Loop
- Make Up Water

Fuel Savings \$1.4 MM/Year

CO₂ Reduced: 9,194 Tons/Year

NO_x Reduced: 0.68 Tons/Year

ConDex PERFORMANCE DATA SHEET

Date: October 11, 2011 Designed by: C Veitch
 Customer: University of California, Davis
 Reference: Condex Condensing Economizer System Performance Data
 Quotation No.: 211088R4 CONDENSATE RETURN

Heat recovery system in the **dry cooling** mode.

Fuel: _____ Natural Gas

Gas side: _____ Gas type _____ Boiler Flue
 Total flow rate _____ 215,000 lb/hr
 Inlet temperature _____ 301 °F
 Outlet temperature _____ 215 °F
 Dew point _____ 135 °F
 H₂O vapor by weight @ inlet _____ 11.35 %
 H₂O vapor flow @ inlet _____ 24,402 lb/hr
 H₂O vapor flow @ outlet _____ 24,402 lb/hr
 H₂O condensed _____ 0 lb/hr
 Specific heat @ avg. temperature _____ 0.27 Btu/lb·°F
 Pressure drop _____ 0.29 inch w.c.
 Fouling factor _____ 0.001 hr·ft²·F/Btu
 Maximum velocity at inlet temperature
 through the new free area _____ 17.4 fps

Gas Flow: 215,000 Lb/Hr

Gas Temp In: 301 F

Gas Temp Out: 215 F

Liquid side: _____ Fluid type _____ Water
 Total flow rate _____ 159,000 lb/hr
 Inlet temperature _____ 175 °F
 Outlet temperature _____ 205 °F
 Pressure drop _____ 14.92 psi
 Fouling factor _____ 0.001 hr·ft²·F/Btu
 Velocity at average temperature _____ 7.44 fps

Water Flow: 159,000 Lb/Hr

Water Temp In: 175 F

Water Temp Out: 205 F

TOTAL HEAT RECOVERED (with 2% losses) _____ 4,856,445 Btu/hr

Total Energy Recovered:
4.85 MMBTU/Hr

ConDex PERFORMANCE DATA SHEET

Date: October 11, 2011 Designed by: C Veitch
 Customer: University of California, Davis
 Reference: Condex Condensing Economizer System Performance Data
 Quotation No.: 211088R4 BOILER MAKE UP WATER

Heat recovery system in the **dry cooling** mode.

Fuel: _____ Natural Gas

Gas side: _____ Gas type _____ Boiler Flue
 Total flow rate _____ 210,286 lb/hr
 Inlet temperature _____ 128 °F
 Outlet temperature _____ 126 °F
 Dew point _____ 128 °F
 H₂O vapor by weight @ inlet _____ 9.3 %
 H₂O vapor flow @ inlet _____ 19,688 lb/hr
 H₂O vapor flow @ outlet _____ 18,447 lb/hr
 H₂O condensed _____ 1,241 lb/hr
 Specific heat @ avg. temperature _____ 0.261 Btu/lb.°F
 Pressure drop _____ 0.12 inch w.c.
 Fouling factor _____ 0.001 hr·ft²·F/Btu
 Maximum velocity at inlet temperature
 through the new free area _____ 13.1 fps

Gas Flow: 210,286 Lb/Hr

Gas Temp In: 128 F

Gas Temp Out: 126 F

Liquid side: _____ Fluid type _____ Water
 Total flow rate _____ 26,000 lb/hr
 Inlet temperature _____ 70 °F
 Outlet temperature _____ 123 °F
 Pressure drop _____ 6.91 psi
 Fouling factor _____ 0.001 hr·ft²·F/Btu
 Velocity at average temperature _____ 3.53 fps

Water Flow: 26,000 Lb/Hr

Water Temp In: 70 F

Water Temp Out: 123 F

Sensible Heat Load: _____ 145,765 Btu/hr


Latent Heat Load: _____ 1,241,907 Btu/hr

TOTAL HEAT RECOVERED (with 2% losses) _____ 1,387,672 Btu/hr

Total Energy Recovered:
1.38 MMBTU/Hr

Total Energy Recovered
15.82 MMBTU/Hr





LEADING THE WAY
CampusEnergy2022

Feb.15-18 Westin Boston Seaport District Hotel Boston, MA







LEADING THE WAY
CampusEnergy2022

Feb.15-18 | Westin Boston Seaport District Hotel | Boston, MA



Joseph Richter

