



WESLEYAN
UNIVERSITY

Microgrid Planning Study, Design, & Implementation

Community

Wesleyan University – Middletown, CT

- 3,000 students
- 1,300 faculty and staff
- 320 acres
- 312 buildings
- 3,000,000 sf.
- 2,250,000 sf, 80 buildings receive steam/chilled water from central plant and are on Wesleyan's 5 kV/15 kV electrical distribution system



Site plan

Legend

Academic Administrative Athletic Facility Dining Faculty / Staff Graduate Undergraduate Under - Fraternity Commercial Offline Sold



November 7, 2011



WESLEYAN UNIVERSITY SITE PLAN



History

- Established 5 kV electrical distribution system in 1960
- Began conversion from 5 kV to 15 kV electrical distribution system in 2008
- Installed 2.5 mW reciprocating gas engine cogeneration system in 2008
- In 2008 produced approximately 80% of demand
- In 2008 supplied domestic and heating hot water for 500 beds
- In 2008 added 3,200 pounds of steam to the steam loop from first cogen



Self Study

- In October 2011, a snow storm caused 80% of Connecticut to lose power, including Wesleyan
- Wesleyan buildings were without utility power for 3 -8 days
- Without power Wesleyan cannot establish a shelter for faculty, staff, or students
- Without power, ongoing experiments in the science buildings can be destroyed along with important material stored in freezers
- Without power, food is lost in dining venues



Best Practices



October 2011

Improving Reliability

- The existing cogeneration system was used to power parts of campus once it was clear that the outage would be longer than a day
- The consequences of the outage were studied recognizing that emergency power reliability is an important part of business continuity and campus safety
- Soon after a study of campus power reliability was undertaken
- In response to the storm the State of Connecticut Department of Energy and Environmental Protection (DEEP) created incentive programs for cogeneration systems and microgrids (where facilities are connected to localized power generation sources)



Options for emergency power

The following options were evaluated by Wesleyan for their ability to provide emergency power, their ability to provide a return on investment and their impact on the environment:

- Fuel cells set up as combined heat and power
- Solar
- Wind
- Standby emergency generators
- Cogeneration micro-turbines
- Cogeneration gas engines

Power reliability & capacity matrix

Option	Increased Reliability	Increased Capacity	Impact on Neighbors	Return on Investment	Cost	Alternate Funding Available	Estimated Cost	Estimated ROI
Make modifications to existing CoGen, switching, engine upgrades APPROVED						no	\$ 150,000	5 years
Install larger CoGen at CPP, 3.5 MW, sell Jenbacher 2.4 MW, est. net cost						yes, from PURA*	\$ 4,000,000	\$ 4,000,000
Install diesel generator at Vine Street, emergency/maybe peak shaver						no	\$ 2,000,000	\$ 2,000,000
Install gas CoGen at Freeman, 500 KW - No connection to campus						yes, from PURA	\$ 1,978,760	20 years
Install gas CoGen at Freeman, 1.5 MW - Connection to campus cost included						yes, from PURA	\$ 3,478,760	10 years
Install capacitor bank at Vine Street						no	\$ 2,000,000	\$ 2,000,000
Install emergency generator at Freeman, diesel or gas TBD						no	\$ 950,000	\$ 950,000
Install emergency generator at Usdan/Fayerweather, diesel or gas TBD						no	\$ 800,000	none
Install emergency generator at Hall-Atwater/Shanklin, diesel or gas TBD						no	\$ 850,000	\$ 850,000
Install emergency generator at Exley, diesel or gas TBD						no	\$ 1,100,000	\$ 1,100,000
Install Fuel Cell at Freeman, say 1.5 MW						yes, PPA, LREC	\$ 7,500,000	\$ 7,500,000
Solar at Long Lane - 1.5 MW						yes, PPA, ZREC	\$ 7,000,000	\$ 7,000,000
Connect Freeman to Vine Street				\$30,305/yr		no	\$ 578,760	19 years
Increase speed to eliminate old 5 K substation at Vine Street						no	\$ 4,500,000	\$ 4,500,000
Buildings to be added to Vine Street/CoGen								
156 High							\$ 520,000	
(Bayit)							incl	
(Religion)							incl	
(International House)							incl	
Public Safety						no	\$ 120,000	
Eclectic						no	\$ 80,000	
Open House						no	\$ 80,000	
Romance Languages						no	\$ 130,000	
Russell House						no	\$ 160,000	
UR						no	\$ 80,000	
Court Street Apartments						no	\$ 120,000	
East Asian Studies						no	\$ 250,000	
GLSP						no	\$ 120,000	

includes cost to con

Good or none

Fair or partial

Bad or poor

*PURA = State of Connecticut "Public Utilities Regulatory Authority"

Cost - >2,000,000 is

Cogeneration – gas engine – combined heat and power (CHP) selected

- Place a gas powered reciprocating engine in or near a building to provide electricity and waste heat
- A number of colleges, universities, and secondary schools are installing gas engine cogeneration systems such as – Clark, Wellesley, Amherst, Smith, UConn, Yale, Harvard, Fairfield, MIT, Williams, UMass, Trinity, Loomis, Avon Old Farms, SUNY Syracuse Environmental Science, CCSU, Duke, SUNY Westbury and Plymouth State

Pros and Cons

- Pros
 - Used in a cogeneration system they can be efficient and also provide emergency power when required
 - Relatively low maintenance
 - Best return on investment of any option
 - Good emissions ratings, lower emissions than utility generators
 - Higher system efficiency than utility generators because the heat from the engine is used

Pros and Cons

- Pros (continued)
 - Replaces gas used for production of an equivalent quantity of steam and hot water
 - Replaces gas used for production of an equivalent quantity of electricity with reduced emissions
- Cons

Conclusion


- Several technologies investigated including Fuel Cells, solar, wind, stand alone generators and cogeneration with gas engines. The final selection was CHP using a reciprocating natural gas engine
- Multiple engines modeled. Final selection based on optimal ROI is rated for 676 kW
- Suitable location identified as Freeman Athletic Center mechanical space.
- Engine provides steam to the campus loop, hot water to serve pool heating, domestic hot water, and heating loads of the 280,000 sf facility

Conclusion continued

- New unit is connected to Vine Street substation via new feeder by adding Freeman to the campus electrical distribution system
- Current electrical load on Vine Street with existing cogen and Freeman is ~8,126 mWh annually
- The new engine will produce 4,635 mWh annually



Cogeneration system impact




Cost

- Total CHP installation cost: \$3,550,000 (includes SCR)
- Total duct bank/interconnection cost: \$620,000
- Expected savings net of service agreement & renewable energy credits
 - Fossil fuel & CL&P savings: \$304,177
 - Expected maintenance agreement cost: (\$120,785)
 - Expected renewable energy credit revenue: \$ 46,350
 - **Net annual savings: \$ 229,742**
- CEFIA rebate: \$300,000
- DEEP Microgrid Grant: \$650,000
- Simple payback: 14 years (includes domestic hot water changes)

Schedule

- Feasibility – April/May 2012
- Engine selection – June/July 2012
- Engine bidding – July/September 2012
- Engine order – November 2012
- Engine delivery – August 2013
- Air permitting – October 2012 to July 2013
- Installation – September 2012 to March 2013
- First fire – January 2014
- Utility interconnect – February 2014


Compliance




Island Mode Testing: 12/29/16

- Report from the Connecticut Department of Energy & Environmental Protection (DEEP)
- Highlighting the load additions and subtractions observed during testing
- Additional data includes hours of operation operating in parallel and island mode, dates/times of unplanned outages and fuel usage data


Island Mode Testing: 12/29/16




Island Mode Testing: 12/29/16




Island Mode Testing: 12/29/16



Island Mode Testing: 12/29/16



Island Mode Testing: 12/29/16



Reporting

Start Time

1/31/2014 11:45 AM

End Time

1/31/2014 12:45 PM


Duration: 1m

WESLEYAN UNIVERSITY

Freeman Athletic Center Emissions Testing Report

Description:	Freeman Outside Air Temperature PI Tag: CCS.TT_OAT Units: °F	Freeman Outside Air Relative Humidity CCS.AT_OAH %	Freeman Generator Output CCS.G2_KW kW	Freeman Genset Gas Flow Total CCS.GenGasTotal Mcf	Freeman Genset SCR Inlet Pressure CCS.G2_SCR_PressIn "WC	Freeman Genset SCR Outlet Pressure CCS.G2_SCR_PressOut "WC	Freeman Genset SCR Inlet Temperature CCS.G2_SCR_TempIn °F	Freeman Genset SCR Outlet Temperature CCS.G2_SCR_TempOut °F	Freeman Genset SCR Urea Flow CCS.G2_SCR_UreaFlow GPH	Freeman Genset SCR Urea Pressure CCS.G2_SCR_UreaPress PSIG
31-Jan-14 11:45:00	40.62	31.75	653	137	7.09	4.75	732.15	722.00	1.90	18.34
31-Jan-14 11:46:00	40.75	32.21	653	137	7.20	4.82	732.08	722.00	1.90	18.36
31-Jan-14 11:47:00	40.89	41.51	652	137	7.16	4.82	732.50	722.00	1.90	18.23
31-Jan-14 11:48:00	41.14	38.62	653	137	7.13	4.82	732.61	722.00	1.90	18.09
31-Jan-14 11:49:00	41.56	34.79	653	137	7.09	4.82	732.23	722.00	1.89	18.00
31-Jan-14 11:50:00	41.98	29.63	653	138	7.06	4.82	732.00	722.00	1.89	18.06
31-Jan-14 11:51:00	42.40	28.29	653	138	7.02	4.82	732.00	722.00	1.89	18.13
31-Jan-14 11:52:00	42.71	32.04	653	138	6.98	4.82	732.00	722.27	1.89	18.20
31-Jan-14 11:53:00	42.63	29.51	653	138	6.95	4.82	732.00	723.00	1.89	18.27
31-Jan-14 11:54:00	42.53	31.49	652	138	6.91	4.82	732.00	722.23	1.89	18.34
31-Jan-14 11:55:00	42.42	31.80	652	138	6.88	4.82	732.00	722.00	1.89	18.41

Microgrid 2nd generator location



[illegible]

Keys to Success

- Select the right engineering team
- Do your permitting homework: First
- Begin discussions with Utility, State and Local Agencies Early
- Model your load and demand duration curves accurately;
Preferably 5 years of data
- Track, measure and model your thermal loads – Site-specific
and campus wide

Keys to Success

- ROI
- Select the service organization in parallel of your prime mover and packager
- Interview the service team
- Understand lines of communication
- Visit the manufacturer and packager prior to selection

Keys to Success

- Establish relationships up and down the supply chain
- Involve your supplier, packager and service organization with BOP issues/decisions

Questions?



Project photos



Project photos



Project photos



Project photos

