

Data Driven Non-Proprietary Plant Optimization

This presentation is protected by US and International copyright laws. No part of this presentation or any documents or other written materials contained herein may be reproduced, transmitted displayed or otherwise used in any form or by any means, electronic, mechanical, photocopying, recording, or otherwise, without prior written permission of Smith Engineering PLLC.

© Smith Engineering PLLC 2014 All rights reserved

DEFINITIONS

1. Data Driven

- Data drives the solution and not engineering rules of thumb

2. Non-proprietary

- Code that is fully open, non-encrypted, modifiable by any programmer, and the end-user has full ownership

3. Plant

- Group of energy consuming equipment arranged in a process: Power plant, chiller plant, steam plant, water treatment plant, etc.

4. Optimization

- Webster's - An act, process, or methodology of making something as fully perfect, functional, or effective as possible
- The combination of capital expenditures that results in the highest possible NPV

PRESENTATION OUTLINE

1. Optimization process

- A. Optimization Prerequisites
- B. Baseline the plant's energy use
- C. Complete understand of utility rate structure
- D. Proper Evaluation
- E. Understand the optimization contract
- F. Adhere to site standards
- G. M&V

2. Real world examples with results


- A. Merck Pharmaceutical – West Point, PA
- B. Large Financial Institution – Pittsburg, PA
- C. LEED Gold Data Center (Princeton University) – Princeton, NJ

OPTIMIZATION PRE-REQ – MAINTENANCE

Energy savings from routine maintenance:

1. Punch chiller cond/evap tubes
2. Combustion analyses/tuning
3. Check chiller refrigerant levels
4. Clean strainers
5. Open balancing valves on VFD driven pumps
6. Unclog tower nozzles
7. Repair CW supply temperature reset
8. Utilize existing free cooling HX
9. Repair steam traps
10. Etc.

Do this before the plant baseline is established




OPTIMIZATION PRE-REQ – INSTRUMENTATION, CALIBRATION, AND HISTORICAL TRENDING

1. **Does the plant have adequate instrumentation?**
 - A. Meters, PTs, TTs, etc.
2. **Is the instrumentation calibrated?**
 - A. Meters, valves, TTs, PTs, etc.
 - B. ABC (Always Be Calibrating)
3. **Is the data trended?**
 - A. Required to establish an energy baseline and used for rebates
 - B. One year or two years of trend data is optimal
 - If no existing data: establish trends or use operator hand logs



Optimization Process



BASELINE – COLLECT TREND DATA AND PERFORM RATE STRUCTURE ANALYSIS

1. Collect Trend Data

- A. Chiller, tower fan, CW pump, CHW pump, and fan power data
- B. CW and CHW flow data
- C. CHW and CW temperatures
- D. Start/stops on constant speed motors, if no power data
- E. Weather data

2. The largest driver of energy costs and potential energy savings is the rate structure

- A. Be very wary of blended rates
- B. Modeled savings for large financial client using blend rates resulted in \$100,000 per year
- C. Modeled savings for large commercial client using actual rate structure was \$55,000 per year

BASELINE DATA COLLECTION

Chiller Plant Operational Data												Measure:		Base			
Calculation Method:												Baseline - Thermosystems Data				Basis: <input checked="" type="checkbox"/> Installed <input type="checkbox"/> Conceptual <input type="checkbox"/> Future	
Design	Tag	CH-1			CH-2			CH-3			CH-4						
	Equip	Chiller			Chiller			Chiller			Chiller						
	Make/Model	Trane/CVHF770			Trane/CVHF770			Trane/CVHF770			Trane/CVHF770						
	Capacity/Hp	700/			700/			700/			700/						
	CHW	1,400			1,400			1,400			1,400						
	CW	2,100			2,100			2,100			2,100						
Existing Operation		Hours	kTon-hrs	kWh	Hours	kTon-hrs	kWh	Hours	kTon-hrs	kWh	Hours	kTon-hrs	kWh				
	Jan	216	42	0	4	1	0	162	46	14,638	171	94	44,306				
	Feb	535	90	51,455	2	8	20	134	43	13,449	0	0	0				
	Mar	319	164	28,062	270	75	32,901	81	49	12,155	0	0	0				
	Apr	720	183	78,799	19	4	1,250	10	4	1,250	0	0	0				
	May	83	32	11,891	438	234	36,441	196	144	40,854	120	58	18,968				
	Jun	21	8	3,536	156	56	23,202	218	67	33,493	632	334	117,994				
	July	218	134	152,402	199	99	41,773	227	106	46,618	0	0	0				
	Aug	735	330	129,080	267	130	53,107	70	32	13,848	32	5	1,878				
	Sep	720	307	119,817	0	0	0	142	48	20,928	0	0	0				
	Oct	69	20	9,117	3	1	340	78	32	12,958	670	221	94,823				
	Nov	0	0	0	38	4	2,561	3	1	461	988	144	52,732				
	Dec	0	0	0	1	0	0	53	18	6,971	254	58	21,157				
	Total	4,358	1,492	645,829	1,323	589	250,917	1,461	616	210,125	2,713	982	144,361				
	Total Cost	\$		33,583			13,094	\$		12,298	\$		17,901				

Design	Equip	Make/Model	Trane/CVHF770		
	Capacity/Hp	700/			
Existing Operation	CHW	1,400			
	CW	2,100			
Existing Operation		Hours	kTon-hrs	kWh	
	Jan	228	42	0	
	Feb	535	91	53,455	
	Mar	519	164	74,702	
	Apr	720	163	79,799	
	May	83	32	13,891	
	Jun	21	8	3,536	
	July	728	334	152,402	
	Aug	735	330	139,080	
	Sep	720	307	119,817	
	Oct	69	20	9,117	
	Nov	0	0	0	
	Dec	0	0	0	
	Total	4,358	1,492	645,829	
	Total Cost	\$		33,583	

Date:	5/9/2013	Client:	Bank of NY Mellon
Project:	CHW Plant Optimization		
Manufacturer Dynamic	Utility Rate Data		
	Utility	Blend Rate	
	Elec	\$	0.052 \$/kWh
	Demand	\$	8.61 \$/kW
	Gas	\$/Therm	
	SWr	\$/hd	
	Wtr	\$/hd	
	Sum Mh	Sum kWh	Sum Cost
		61,036	\$ 3,175
		66,973	\$ 3,483
		120,018	\$ 6,241
		84,877	\$ 4,388
		188,209	\$ 9,787
		177,239	\$ 9,216
		242,242	\$ 12,597
		207,993	\$ 10,813
		148,765	\$ 7,736
		107,258	\$ 5,577
		55,804	\$ 2,902
		28,129	\$ 1,463
	\$ -	\$ 1,446,917	\$ 77,376


OPTIMIZATION ENERGY ANALYSIS – EQUIPMENT AND SYSTEM PERFORMANCE

1. Use real data, no models, no IPLV

A. Develop Efficiency Maps for:

- Chillers
- Pumps
- Towers
- Boilers
- CTGs
- STGs
- Compressors

Steam Chiller Efficiency Map




2. Model Actual Proposed Sequence


A. Sequences are code, use the actual code to model the plant improvements

HYDRAULIC MODELING

1. Compressible and Non-Compressible
 - A. Pipe Flo
 - B. Fathom
 - C. Termis
2. Requires extreme detail, otherwise don't spend the money
 - A. All valves, strainer, elevations, coil dp
 - B. Calibrate with actual test data



OPTIMIZATION




LARGE CAMPUS CHILLED WATER PUMP


$$HP = \frac{Flow \times Head}{3960 \times \eta}$$

1. Flow: Campus dictates ΔT and thus flow
2. Head: Too many valves to poll to perform DP reset; therefore hydraulically remote DPT determines pump head
3. η can never be greater than pump+motor+VFD **BEP** ~80%

TDH: 135' FLOW: 2621 GPM η : 56%



TDH: 135' FLOW: 2621 GPM η : 56%



3 CHW Pumps

TDH:
135'


Total FLOW:
7,863 GPM

η :


56%

Total kW:
375


TDH: 135' FLOW: 2621 GPM η : 56%




TDH: 0' FLOW: 0 GPM η : 0%



TDH: 133' FLOW: 1965 GPM η : 76%



TDH: 133' FLOW: 1965 GPM η : 76%



4 CHW Pumps

TDH:

133'

Total FLOW:

7,863 GPM

η :

76%


Total kW:

259


kW Reduction:

115

TDH: 133' FLOW: 1965 GPM η : 76%



TDH: 133' FLOW: 1965 GPM η : 76%



ENERGY ANALYSIS

Chiller Plant Operational Data										Measure:	Base 2012 Energy Use					Date: 5/8/2013	Client: Bank of NY				
Calculation Method:										Baseline	Thermostat	Items Data	Basin	Controlled	Conversion	Final Change	Equipment Efficiency	Manufacturer Status	Actual Dynamic	Manufacturer Demand	Utility Rate Data
Design	Tag	CH-1			CH-2			CH-3			CH-4									Utility	Base Rate
	Equip	Chiller			Chiller			Chiller			Chiller									Elec	\$ 0.052 5/yr
	Make/Model	Trane/CH170			Trane/CH170			Trane/CH170			Trane/CH170									Demand	\$ 8.81 5/yr
	Capacity/Hp	700			700			700			700									Gas	5/yr
	CHW	1,400			1,400			1,400			1,400									Ste	5/yr
	CW	2,000			2,000			2,000			2,000									Wtr	5/yr
Ending Operation		Hours	kWh-Btu	kWh	Hours	kWh-Btu	kWh	Hours	kWh-Btu	kWh	Hours	kWh-Btu	kWh							Ste	kWh
	Jan	100	41	0	0	0	0	100	46	10,000	100	46	10,000								\$1,000
	Feb	100	36	0	0	0	0	100	40	10,000	0	0	0								\$0,000
	Mar	100	300	30,000	100	30	10,000	100	30	10,000	0	0	0								\$0,000
	Apr	100	100	20,000	10	0	0	100	0	0	0	0	0								\$0,000
	May	100	100	10,000	100	100	10,000	100	100	10,000	100	100	10,000								\$0,000
	Jun	100	0	0	0	100	100	100	0	0	0	0	0								\$0,000
	July	100	100	10,000	100	100	10,000	100	100	10,000	0	0	0								\$0,000
	Aug	100	100	10,000	100	100	10,000	100	100	10,000	0	0	0								\$0,000
	Sept	100	100	10,000	0	0	0	100	100	10,000	0	0	0								\$0,000
	Oct	100	100	10,000	0	0	0	100	100	10,000	0	0	0								\$0,000
	Nov	0	0	0	0	0	0	0	0	0	0	0	0								\$0,000
	Dec	0	0	0	0	0	0	0	0	0	0	0	0								\$0,000
	Total	1,000	1,000	100,000	1,000	1,000	100,000	1,000	1,000	100,000	1,000	1,000	100,000								\$0,000
	Total Cost	\$	\$1,000			\$	\$1,000			\$	\$1,000									\$	\$1,000
Controls System Optimization																					
Tag	CH-1			CH-2			CH-3			CH-4									Utility	Base Rate	
Equip	Chiller			Chiller			Chiller			Chiller									Elec	\$ 0.052 5/yr	
Make/Model	Trane/CH170			Trane/CH170			Trane/CH170			Trane/CH170									Demand	\$ 8.81 5/yr	
Capacity/Hp	700			700			700			700									Gas	5/yr	
CHW	1,400			1,400			1,400			1,400									Ste	5/yr	
CW	2,000			2,000			2,000			2,000									Wtr	5/yr	
	Hours	kWh-Btu	kWh	Hours	kWh-Btu	kWh	Hours	kWh-Btu	kWh	Hours	kWh-Btu	kWh							Ste	kWh	
Jan	100	40	0	0	0	0	0	0	0	0	0	0								\$0,000	
Feb	100	30	0	0	0	0	0	0	0	0	0	0								\$0,000	
Mar	100	300	30,000	0	0	0	0	0	0	0	0	0								\$0,000	
Apr	100	100	10,000	0	0	0	0	0	0	0	0	0								\$0,000	
May	100	100	10,000	0	0	0	0	0	0	0	0	0								\$0,000	
Jun	100	0	0	0	0	0	0	0	0	0	0	0								\$0,000	
July	100	100	10,000	0	0	0	0	0	0	0	0	0								\$0,000	
Aug	100	100	10,000	0	0	0	0	0	0	0	0	0								\$0,000	
Sept	100	100	10,000	0	0	0	0	0	0	0	0	0								\$0,000	
Oct	100	100	10,000	0	0	0	0	0	0	0	0	0								\$0,000	
Nov	0	0	0	0	0	0	0	0	0	0	0	0								\$0,000	
Dec	0	0	0	0	0	0	0	0	0	0	0	0								\$0,000	
Total	1,000	1,000	100,000	0	0	0	0	0	0	0	0	0								\$0,000	
Total Cost	\$	\$0,000			\$	\$0,000			\$	\$0,000									\$	\$0,000	
Tag	CH-1			CH-2			CH-3			CH-4									Total Savings		
Reduced kWh	-3,242			1,321			1,401			1,872									306,075		
Reduced energy	-\$63,120			\$25,807			\$26,119			\$37,164									\$0		
Reduction in Cost	\$	(\$3,882)			\$	\$13,094			\$	\$12,798			\$	\$8,906			\$	\$0			

OPTIMIZATION - FINANCIAL ANALYSIS

1. **First Cost**

- A. Use contractor GMP quotes, do not use engineering estimates
- B. Include all ongoing contract costs
- C. Include all maintenance costs

2. **Useful Life**

- A. Project VFDs and BAS controllers may be obsolete in 5-10 years

3. **Separate equipment from controls optimization**

- A. ECM-1 – Controls optimization
- B. ECM-2 – Free cooling heat exchanger
 - ECM-2 should use ECM-1 as a base

OPTIMIZATION - IMPLEMENTATION

1. Service Provider

- A. Ask for **relevant** project and client references for the project manager that will be on your project, the brand is less important

2. Site Standards

- A. Packaged bundles must adhere to site quality standards
- B. Examples:
 - VFD – IEEE-519
 - Chillers – marine water box
 - Meters – magnetic, ultrasonic, etc.
 - TT & PT – Rosemount, etc.



Case Study: **Merck Pharmaceutical** West Point, PA

1. Plant – 6,250 Tons (Total Site 80,000 Tons)

- (3) 1,250 Ton Trane CVHE Chillers, (2) 1,250 Ton Trane CVHF Chillers
- Variable Volume Primary

2. Rates

- \$0.065 per kwh


3. Controls System

- Allen Bradley PLCs

OPTIMIZATION RESULTS

- Plant average reduction in kW
 - **43%**
- Chiller average reduction in kW
 - **28%**
- CW pump average reduction in kW
 - **76%**
- CHW pump average reduction in kW
 - **73%**
- Tower average reduction in kW
 - **42%**
- Average reduction in CW flow
 - **63%**
- Average reduction in CHW flow
 - **60%**

Plant kW Duration Comparison (First 3 Months)



OPTIMIZATION RESULTS

	Controls Optimization
All in First Cost (\$)	\$548,000
Rebate (\$)	\$213,296
Net CapEx (\$)	\$334,704
Energy Savings (\$)	\$173,303
Simple Payback	1.93 Years



Case Study: Large Financial Institution CHW Plant Pittsburgh, PA

1. Plant

- (4) 700 Ton Trane CVHF Chillers
- Primary secondary system
- Data Center

2. Rates


- \$0.052 per kwh and \$8.61 per kw

3. Controls System


- Allen Bradley PLCs

OPTIMIZATION - CHILLER EFFICIENCY MAPPING



Pre-Optimization



Post-Optimization



OPTIMIZATION RESULTS – M&V



kWh Savings	879,547
\$ Savings	\$55,035
Rebate	\$52,772
Simple Payback	Less Than 1.5 Years

Payable To:	Mellon Bank NA
Attention To:	First Name: Dan
Address	525 WILLIAM PENN PL STE 2500
	City: PITTSBURGH
Incentive Payment:	\$55,312.32




Case Study: **LEED Gold Data Center** Princeton, NJ

1. Plant

- (3) 500 Ton Trane CVHF chillers
- Primary-secondary system
- Data center

LEED GOLD DATA CENTER.

Plant energy demand pre and post enhanced control logic (zero demand spike is from bringing the controller down to install the new logic)



CLOSING

- **Plant efficiency improvement decisions should be based on product agnostic, data-driven, rigorous analysis. A full understanding of the complete system, utility rates, component efficiencies, feasibility, and implementation cost is required.**
- **Optimization is not a “magic pill” – it requires an investment in the time of highly qualified people. The more complex the plant and process, the more time and “hands-on” attention required.**
- **The terms of the contract may be more important than the level of optimization.**