

# BAY WATER OR GRAY WATER

District Cooling Heat Rejection – the Arabian Gulf



Scott E. Henriques, PE,  
LEED AP O&M

Jonathan French, PhD

February 20, 2014



# BAY WATER OR GRAY WATER

## District Cooling Heat Rejection – the Arabian Gulf

*Once-through Sea Water or Cooling Towers with polished Treated Sewerage Effluent (TSE) make-up, will be considered for large District Cooling Plants (Western Shore of the Arabian Gulf)*

- Why the Discussion
- The Chillers
- Cost of Resource
- Materials and Equipment
- Environmental Case Study

# BAY WATER OR GRAY WATER

## District Cooling Heat Rejection – the Arabian Gulf

### Why the Discussion?

The future of potable water use in the region as the *normal* source for DC heat rejection make up water is being phased out

- Potable water use for heat rejection in the region is a significant strain on potable water systems
- In at least 2 GCC countries the use of potable water for the *normal* source of heat rejection for cooling systems is no longer allowed
- Many potable water providers are strongly discouraging the use of potable water for DC even when it is still allowed

Two possible alternatives are TSE and Sea Water

# BAY WATER OR GRAY WATER

District Cooling Heat Rejection – the Arabian Gulf

## The Chillers

### Chiller Efficiency

- Entering Condenser Water Temperature (ECWT)
- Fouling

### Materials

# BAY WATER OR GRAY WATER

## District Cooling Heat Rejection – the Arabian Gulf

### Chiller Performance ECWT

Average Coastal Sea Water Temperature							Dhahran Average WB (F)
Month	Western Arabian Gulf Sampling					(C) Avg (F)	
	Sta 1	Sta 2	Sta 3	Sta 4			
Jan	20.5	20.5	19.0	19.5	19.9	<b>67.8</b>	59.1
Feb	21.0	20.5	21.5	21.5	21.1	<b>70.0</b>	55.1
Mar	28.0	26.5	26.5	26.0	26.8	<b>80.2</b>	58.9
Apr	26.0	29.0	27.0	27.0	27.3	<b>81.1</b>	64.1
May	31.0	31.5	30.0	30.0	30.6	<b>87.1</b>	68.4
Jun	32.0	37.0	28.0	28.0	31.3	<b>88.3</b>	69.4
Jul	37.0	38.0	30.0	28.0	33.3	<b>91.9</b>	72.3
Aug	34.0	34.0	32.0	31.0	32.8	<b>91.0</b>	74.0
Sep	38.0	36.0	31.0	31.0	34.0	<b>93.2</b>	74.4
Oct	34.0	34.0	29.0	32.0	32.3	<b>90.1</b>	69.8
Nov	24.0	22.0	19.0	24.0	22.3	<b>72.1</b>	63.4
Dec	26.0	24.5	23.0	23.5	24.3	<b>75.7</b>	56.6

*...when it comes to chiller efficiency...*

**TSE out-performs Sea Water**

1. Mangrove Investigations Vol. IV
2. BIN data Dhahran (MIL) SD, WMO No. 404160

# BAY WATER OR GRAY WATER

## District Cooling Heat Rejection – the Arabian Gulf

### Chiller Performance

#### Fouling

- Fouling for sea water is far greater than polished TSE even when occasional sand storms are taken into account
- Sea water requires more frequent cleaning and maintenance to keep heat exchangers clean and chiller performance high

#### Materials

- Sea water requires titanium or other expensive heat exchange surfaces
- No special materials required for TSE once polished

***...when it comes to chiller fouling and materials...***

**TSE Cooling Towers out performs Sea Water**

# BAY WATER OR GRAY WATER

## District Cooling Heat Rejection – the Arabian Gulf

### Cost of the Resource

#### TSE

- Cost of operating the RO polishing system
- TSE costs \$1.363 per 1,000 gals (AED1.32/m<sup>3</sup>) in Dubai as of 2012, about one fifth the price of potable water<sub>3</sub>
- Other GCC countries are following Dubai's lead as TSE use grows

#### Sea Water

- It's still free

*...as a commodity...*

**Sea Water out performs TSE**

# BAY WATER OR GRAY WATER

District Cooling Heat Rejection – the Arabian Gulf

## Materials and Equipment

### Piping Size

- Once though Sea Water will require a greater diameter
- TSE piping will typically be supplied by the TSE utility
- Similar piping materials required (GRP, HDPE, et al.)

### Cooling Towers vs Sea Water Intakes

- Cooling towers less expensive than sea water intakes
- Sea Water intake pumps will consume more power than CT fans

***...for initial investment and power use...***

**TSE is less expensive than Sea Water**



# BAY WATER OR GRAY WATER

District Cooling Heat Rejection – the Arabian Gulf

## Environmental Case Study

### Once-through Sea Water heat rejection for District Cooling


- Western coast of the Arabian Gulf
- TR DC plant located on an ~ 2km x 1 km bay
- 40,000 TR and 70,000 TR plants at opposites sides of bay



# BAY WATER OR GRAY WATER

## District Cooling Heat Rejection – the Arabian Gulf

- Schematic heat Budget



Can heated seawater from once-through district cooling be safely discharged back to the bay? Local regulations state:

- Bay temperature cannot increase more than 2 C
- Outfall cannot be 10 C greater than intake

# BAY WATER OR GRAY WATER

## District Cooling Heat Rejection – the Arabian Gulf

X = distance from the SE end of the bay

T(X) = Temperature of the Bay at any X

T = Discharge Temperature of DCP

Ta = Ambient Gulf Temperature

### Upstream Boundary Condition

At the SE end of the Bay, where heated water would be discharged:

$$(T - T_a)_{se} > 15 \text{ F degrees} = 8.33 \text{ C degrees}$$

(Use as “ $(T - T_a)_{se} = 8.33 \text{ C degrees}$ ”, realizing the actual  $(T - T_a)$  will be greater than thus predicted.)

# BAY WATER OR GRAY WATER

District Cooling Heat Rejection – the Arabian Gulf

## Downstream Boundary Condition

$R*B*X_c$  = delta volume of Bay per tide cycle x  $(C_p)$

Where  $R$  = tide range,  $B$  = Bay width,  $X_c$  = Bay length

At the NW end of the Bay (channels to the sea), the tidal heat export rate is

$$H_c < (T - T_a) * R * B * X_c$$

(Use as “ $H_c = (T - T_a) * R * B * X_c$ ”, again realizing that the actual  $(T - T_a)$  will be greater than thus predicted.)

# BAY WATER OR GRAY WATER

District Cooling Heat Rejection – the Arabian Gulf

A pair of diffusion equations in difference form were integrated numerically from the sea ( $X = X_c$ ) back to the discharge points ( $X = 1$ ):

$$\Delta(T - T_a)/\Delta X = -H(X)/(K_o * X * B * D) \text{ [tidal flushing]}$$


and

$$\Delta H(X)/\Delta X = -k * B * (T - T_a) \text{ [heat to atmosphere]}$$

# BAY WATER OR GRAY WATER

## District Cooling Heat Rejection – the Arabian Gulf

Resulting Temperature, C, if the ambient temperature in the Gulf is 34 C (mean for July)



# BAY WATER OR GRAY WATER

## District Cooling Heat Rejection – the Arabian Gulf

### Assumption No. 1

- Tidal export of heat to sea via the channel will be “perfect”, i.e.; no water warmer than background will return on the flood tide
- *Yet realistically, export will be imperfect, water warmer than  $T_a$  will enter on the flood*
- Thus temperature curves would be somewhat higher than shown

# BAY WATER OR GRAY WATER

## District Cooling Heat Rejection – the Arabian Gulf

### Assumption No. 2

- The maximum temperature at the discharge points will be 15 F degrees = 8.33 C degrees warmer than the ambient sea temperature,  $T_a$
- *This will be true only if water is taken in directly from the sea, at temperature  $T_a$*
- Water taken in from the Bay will be warmer than  $T_a$ , thus discharge temperature will be greater than  $T_a + 8.33$  C
- *Again the curves would be higher than shown*



# BAY WATER OR GRAY WATER

## District Cooling Heat Rejection – the Arabian Gulf

Simplifying assumptions mask realities that would raise the figure's curves to higher values than shown. Therefore we may infer that in July, water temperature will:

- Not meet the regulatory requirement of no more than 2 C rise in bay temp
- Accelerate algal blooms due to elevated biochemical reaction rates
- Depress DO due to the algal blooms
- Depress the DO saturation concentration
- Exceed human body temperature

*For this project, once-through Sea Water heat rejection was not feasible for environmental reasons*

# BAY WATER OR GRAY WATER

District Cooling Heat Rejection – the Arabian Gulf

*Thank You*