



UCDAVIS
FACILITIES MANAGEMENT

Solar Thermal Optimization for District Hot Water through Energy Modeling




UC DAVIS

FACILITIES MANAGEMENT

Joshua Morejohn, Energy Manager

Priscila Castillo Cazares, JEMES CiSu

ECO energy
conservation
office



**UC Davis is converting their
district heating system from
steam to hot water**

- **Is solar thermal generation a
viable addition?**
- **How does it interface with heat
recovery?**



Outline


- Context
- Modeling Assumptions
- Baseline Model
- Scenarios 1 - 3
- Conclusions

Context

Aging steam DH system


- Boiler capacity issue
- Piping & insulation failures
- Building leaks
- Cost of maintenance
- 30-50% distribution losses

EXISTING STEAM DISTRICT HEATING



- Pre 1969 (> 45 yrs old)
- 1970 to 1989 (27-45 yrs old)
- 1990 to 2010 (6-26 yrs old)


UC Davis Monthly Htg & Clg Demand and Heat Recovery Potential



Context


Opportunity for Heat Recovery

Annual Energy Use Comparison




Context

Carbon Neutral by 2025




Current Campus Systems

ECO




Baseline model (HW district heating)




Scenario 1

ECO



Scenario 2



Scenario 3

ECO

Energy Demands


Using energyPRO (emd.dk)

Campus Energy Model


- 77 MW (305 pph) steam boiler plant
- 63 MW (18,000 tons) electric chiller plant
- 5 Mgal CHW TES Tank
- 30 MW solar PV plant

Unit	Primary fuel	Primary output	Output Capacity	Efficiency	Function	Inst. year	Condition
District heating supply							
Boiler 1	Natural Gas	Saturated Steam	20.3 MWth	-	None	1967	Non-operational
			80,000 pph steam				
Boiler 2			20.3 MWth	75%	Back-up	1967	Poor
			80,000 pph steam				
Boiler 3			19 MWth	75%	Summer baseload and	1994	Good
			75,000 pph steam				
Boiler 4			38 MWth	88%	Baseload	2009	Good
	150,000 pph steam						
District cooling supply							
Chiller B1	Electricity	Chilled Water	8.8 MWth	COP 4.25 0.83kW/Ton refrigeration	Baseload in summer	2004	Good
			2,500 ton Refrigeration				
Chiller B2			8.8 MWth			2004	Good
			2,500 ton Refrigeration				
Chiller C1			8.8 MWth		2010	Good	
			2,500 ton Refrigeration				
Chiller C2			8.8 MWth				
			2,500 ton Refrigeration				
TES Chiller 1			7MWth		Baseload + providing to cold TES	2000	Good
			2,000 ton Refrigeration				
TES Chiller 2			7MWth			2000	Good
			2,000 ton Refrigeration				
TES Chiller 3			7MWth			2004	Good
			2,000 ton Refrigeration				
TES Chiller 4			7MWth		2004	Good	
			2,000 ton Refrigeration				
Power Supply							
Fresno	Irradiance	Electricity	16 MWe AC	-	RE contribution	2017	Good
			20 MWe DC				
Solar PV Farm			13 MWe AC			2015	Good
			16.3 MWe DC				
Rooftop PV			604 kWe AC			2012	Good
			757 kWe DC				

Hot Water District Heating



With Solar Thermal Plant



Campus Energy Model

Using energyPRO (emd.dk)

A black and white photograph of a modern, multi-story building with a complex facade of windows and balconies. The building is the background for the text overlay.


HW Modeling Scenarios

- 1. 25 acre (100k m²) Solar Thermal (ST) plant**
- 2. One 2,500 ton Heat Recovery Chiller (HRC)**
- 3. One 2,500 ton HRC + ST + seasonal storage**

A black and white photograph of a modern, multi-story building with a complex facade of windows and balconies. The building is the background for the text overlay.


Scenario Assumptions


- 20 year model (2017-2036)
- 1.25 MGal HW TES for daily storage
- 31% steam distribution losses
(assuming actual heating demand is
69% of measured heating demand)




Scenario 1 Results

ST Production drives
Scenario 1 NG Usage
to zero in summer but
has less impact in
winter (compared to
Baseline NG Usage).





Scenario 1 HW with ST	Baseline HW (NG Boilers)	HW District with ST
% Boilers	100	49
% Solar Thermal	0	51
NG (m3/yr)	16,800,000	8,300,000
Elect (MWh/yr)	32,000	32,000
mtCO2e/year	80,000	64,000
Cost Savings/year	0	\$1M





Scenario 2

ECO


Scenario 2 Results

HRC HW Production drives **Scenario 2 NG Usage** to zero in summer but has less impact in winter (compared to **Baseline NG Usage**).





Scenario 2 HW with HRC	Baseline HW (NG Boilers)	HW District with HRC
% Boilers	100	40
% HRC	0	60
NG (m3/yr)	16,800,000	6,800,000
Elect (MWh/yr)	32,000	48,000
mtCO2e/year	80,000	66,000
Cost Savings/year	0	\$90k




Scenario 3


ECO

Scenario 3 Results


HRC + ST Production
drives **Scenario 3 NG**
Usage to zero year-
round (compared to
Baseline NG Usage).




UC Davis Heat Recovery Potential



Scenario 3 - HRC + ST + Seasonal Storage





Scenario 3 HW with HRC + ST + Seasonal storage	Baseline HW (NG Boilers)	HW District with HRC + ST + Seasonal storage
% Boilers	100	0
% HRC + ST	0	100
NG (m3/yr)	16,800,000	0
Elect (MWh/yr)	32,000	50,000
mtCO2e/year	80,000	53,500
Cost Savings/year	0	\$780k



Seasonal storage for the UC Davis district heating system would be 4.5x larger than the world's largest thermal storage pit (Vojens, Denmark)

Conclusions

- **Solar Thermal is ideal where Heat Recovery options are limited**
- **Heat Recovery can limit Solar Thermal potential**
- **Both are limited by summer heating loads and storage size**
- **Seasonal storage is required to leverage both Heat Recovery and Solar Thermal to their full extent**

