



Energy Systems for Island Resilience

Case Study : Guam



Avinash Srivastava, AICP
Principal and Director of Urban Analytics



Calum Thompson, PE, LEED AP
High Performance Communities



Imagine it.
Delivered.


- Integrated planning process focusing on resilience
 - Existing conditions and the need for resilience
 - Developing a resilient energy plan for Guam
- Methodology for assessment
 - Identifying critical loads
 - Methods of quantification and comparison of energy solutions
- Resultant plan
 - Technology integration
 - Phasing
 - Performance
 - Making Resiliency Investments Worthwhile
- Lessons learned and applicability elsewhere

Guam



Strategic Energy Master Plan


- The Strategic Energy Master Plan (SEMP) seeks to provide energy resiliency and security using efficiency, redundancy, and reliability in support of the forward operating mission.







Existing Conditions: Power Crisis

- GPA lost 80 MW generation
- JRM required to run on-site generation
- >400 power outages from 2010 - 2015






Future: Growth



- Federal Mandates (EO 13693)
 - Energy Use Intensity (EUI) – 25% reduction by 2025
 - Renewable Energy % - 25% by 2025
- SECNAV Goals
 - 50% alternative fuel sources by 2020
 - Net zero energy by 2030
- Resilience Goals:
 - Provide durable energy solutions
 - Avoid single points-of-failure
 - Ensure sustainable maintenance
 - Use cost-effective energy strategies
 - Meet required energy mandates and goals



Strategies: Demand reduction

- Demand reduction 1st step
- Utility capacity constraint accentuates its resilience value
- >4,000 projects



Strategies: District Cooling + SWAC

- District energy is key for reducing energy demand
- District Cooling
 - Centralized generation more efficient
 - Secondary maintenance benefits
- SWAC
 - Requires only approximately 20% of the electricity of conventional cooling (to power the pumps)
 - Numerous studies identified SWAC to be cost-effective at Guam




Strategies: Solar + Storage

- Number of sites suitable for PV
 - Up to 45 MW of rooftop solar
 - Adjacent land of solar farms
 - Off-site government land with direct-connection opportunities
- Energy storage serves dual purpose
 - Load balancing to use PV energy
 - Demand management to reduce costs




Strategies: Microgrid



- Why Microgrids? Mission Assurance
- DoN has 2 overarching Shore Energy Goals:
 - Assure Energy Security for Critical Installation Operations
 - Maximize Availability of Renewable Energy
- Renewable energy systems require an energized electrical distribution to operate
- Microgrids allow renewable energy systems to support the mission during commercial power outages
- Microgrids deliver operational flexibility to sustain critical operations during extended outages



Methodology: Resilience Assessment




Critical Mission Energy Demand Component	
% of total annual energy demand for installation	30% based on Microgrid Studies
R1 Reliability	
Reliability is concerned with the delivery of energy systems within acceptable regulatory standards and quality. It has 3 main metrics:	
R1a Grid Reliability	33%
Reliability of energy distribution systems	
R1b Smart Grid Capability	33%
Visibility and automation or operations	
R1c Advanced Peak Demand/Power Management Capability	33%
Active load and power quality management	
R2 Resiliency	
Resiliency is defined as the ability of Energy Systems to anticipate, resist, absorb, respond, adapt, and recover from a disturbance. It has 4 main metrics:	
R2a Redundancy & Availability	30%
Avoidance of Single Points of Failure (SPOF) in energy infrastructure and ensuring that there is adequate supply of energy in emergency situations.	
R2b Diversification	10%
Capability of receiving energy through a variety of sources in order to ensure stability in supply and pricing.	
R2c Cyber Security & Hardening	30%
Mitigating risk from cyber attacks; hardening infrastructure from physical damage.	
R2d Recovery & Operability in Emergency	30%
Ability to restore operational capacity of critical facilities post an emergency that disrupts normal energy supply, and sustain operations in emergency mode.	
R3 Efficiency	
Efficiency contributes towards operational savings and reduction of loads that directly impact other resiliency and readiness aspects. It has 2 metrics:	
R3a Energy Efficiency	50%
Reduction in energy use intensity	
R3b Energy Operational Savings	50%
Lifecycle reduction in energy utility bills and maintenance operations	




Methodology: Identifying Critical Loads

- Within these critical facilities, the use of energy varies significantly
- Need to consider:
 - Operational times
 - Scale of demand
 - Type of demand
 - Process loads
 - Lighting systems
 - Heating, cooling and ventilation
 - Quality of supply
 - Role under critical operation
 - Ability to load-shed
 - Changing functionality




Methodology: Identifying Critical Loads

- A communications building has different demand than a training facility, armory, or airfield



Communications Facility



Recreational Facility

Methodology: Identifying Critical Loads

S1-4: Critical Load Profile

Critical Load

30% of the Annual Energy Demand


~350 MWh/day of Demand

Storage can help meet this demand

System Capacity


25 MW Generators

OR ~350 MWh of Battery Storage



Methodology: Operational Configurations

- Design systems to maximize economic case
- Example is microgrid, solar and storage strategy at Guam



- Peak demand reductions allow system to pay for itself

Methodology: Operations

Storage: Peak Solar Day

Operation

Sized for critical supply resiliency

Peak Day Peak Output 80 MW

Solar with battery reduces peak demand by
50% under typical operation

System Capacity


110 MW PV

220 MWh Battery Storage


50 MWh used for peak shaving

15 MW Generators (0% needed)

Typical Operation



Grid Failure Operation



Methodology: Operations

Storage: Average Day

Operation

Average Day Peak Panel Output 58 MW

45 MW grid demand during the day

All solar serves critical load

Does not require use of generators


System Capacity

110 MW PV


220 MWh Battery Storage

15 MW Generators (0% needed)

Typical Operation



Grid Failure Operation



Methodology: Operations

Storage: Minimum Day

Operation

Minimum Day Peak Output 3 MW

4 MW grid demand during the day

All solar serves critical load

Requires additional generator operation


System Capacity

110 MW PV


220 MWh Battery Storage

3 MW Generators (50% needed)


Typical Operation



Grid Failure Operation




Methodology: Operations



Reading this Graphic


The graphic represents hourly electricity supply and demand at each location on an average day. It shows the output from PV (pink and green), when batteries would operate (purple), and the remaining demand from the grid.



Typical Day Operation of a Future JRM

By 2035, Under No Action, Utility Bills Increase by **\$73,333k** 110%
For Scenario, By 2035, Utility Bills will change by **-\$57,786k** -41%
For Scenario, In 20 Years Projects will save **\$844,203k**

Savings Scenario Utility Bills No Action Utility Bills



* Model 3 PV (Rooftop and Ground Mounted) contributes to utility savings

Results: Resilience

Critical Mission Energy Demand Component
% of total annual energy demand for installation

30%

based on Microgrid
Studies

R1 Reliability

Reliability is concerned with the delivery of energy systems within acceptable regulatory standards and quality. It has 3 main metrics:

R1a Grid Reliability

33%

Reliability of energy distribution systems

R1b Smart Grid Capability

33%

Visibility and automation of operations

R1c Advanced Peak Demand/Power Management Capability

33%

Active load and power quality management

R2 Resiliency

Resiliency is defined as the ability of Energy Systems to anticipate, resist, absorb, respond, adapt, and recover from a disturbance. It has 4 main metrics:

R2a Redundancy & Availability

30%

Avoidance of Single Points of Failure (SPOF) in energy infrastructure and ensuring that there is adequate supply of energy in emergency situations.

R2b Diversification

10%

Capability of receiving energy through a variety of sources in order to ensure stability in supply and pricing.

R2c Cyber Security & Hardening

30%

Mitigating risk from cyber attacks; hardening infrastructure from physical damage.

R2d Recovery & Operability in Emergency

30%

Ability to restore operational capacity of critical facilities post an emergency that disrupts normal energy supply, and sustain operations in emergency mode.

R3 Efficiency

Efficiency contributes towards operational savings and reduction of loads that directly impact other resiliency and readiness aspects. It has 2 metrics:

R3a Energy Efficiency



50%

Reduction in energy use intensity





R3b Energy Operational Savings

50%

Lifecycle reduction in energy utility bills and maintenance operations



Results: Comparison

JRM Energy Scenarios		Energy Security and Readiness Scorecard				EO 13693 Mandates*			CNIC Goal*	SECNAV Goals*		Cost Metrics			
Scenario Number	Scenario Description	Reliability	Resiliency	Efficiency	Energy Security and Readiness Scorecard Snapshot ⁵	Energy Intensity Reduction - 25% by 2025	Electric Renewable Energy - 30% by 2025	Renewables Mandate - 25% by 2025	Energy Consumption Reduction - 50% by 2020	Energy from Alternate Sources - 50% by 2020	Net-Zero (Utilizing Additional Sites ³) - 100% by 2030	Cost (\$M) ⁶	By 2035 Projects Will Save (\$M)	Cost \$ / MBTU Saved	Positive Cash Flow
1	Business as Usual + Government Planned Projects ¹	57	48	95		48%	84%	84%	26%	35%	28%	\$	\$\$	\$\$	14 Years (2029)
2	Mandate Compliance ¹	60	52	96		49%	100%	100%	26%	50%	44%	\$	\$\$	\$	13 Years (2028)
3	Resilient with Net-Zero MCBG ^{1,2,3}	100	87	100		62%	113%	113%	26%	54%	42%	\$\$	\$\$\$	\$\$\$	17 Years (2032)
4	Resilient Plus ^{1,2,3,4}	100	90	100		65%	138%	138%	26%	55%	66%	\$\$\$	\$\$\$	\$\$\$\$	22 Years (2037)

Notes:

Red Values indicate a Mandate or Goal is not being met.

Green Values indicate that a Mandate or Goal is being met or exceeded.

*Performance against mandates and goals is projected to target year and covers the full installation load.

0-59	Weak - needs improvement
60-79	Moderate - improved
80-100	Strong - approaching the intent of guidance
	The Recommended Energy Scenario


Climate Impact

- Alaska
 - Heating systems are critical
 - District heating & local boilers?
- Guam
 - Cooling is critical
 - District cooling and local chillers?
- San Diego
 - Could lose cooling / heating and be comfortable
 - Passive building design?



Utility Grid Reliability / Power Quality

- Seattle
 - Very reliable grid
 - Reduced back-up power requirements?
- Guam
 - Unreliable, poor quality power supply (400 outages in last 5 years)
 - Increased need for on-site generation infrastructure



Summary



Calum Thompson : calum.thompson@aecon.com

Avinash Srivastava: avinash.srivastava@aecon.com