

# **Paying for Carbon Reduction: Stationary Fuel Combustion and Grid- Supplied Electricity**

**Presenter:**

**James Bohn, FVB Energy Inc.**

**International District Energy Association  
Annual Conference  
June 26, 2019**



*Global Presence  
Local Solutions*

*45 Years of Experience in Sustainable District Energy Systems*


# Agenda

## 1. Presentation

- Aggressive carbon reduction goals
- Scoping emissions
- Planning for capital requirements
- Financial viability
- Pricing carbon
- Key Considerations

## 2. Q&A

# Aggressive Carbon Reduction Goals




# Aggressive Carbon Reduction Goals

## OBJECTIVE

Accounting for campus growth, achieve carbon neutrality by 2046 — Princeton's 300th anniversary — through the use of repeatable, scalable and innovative solutions.

## Targets

Campus emissions (metric tons CO<sub>2</sub> x 1000)




\*2018 represents an average of 2017 and 2018 performance data.

\*\*Targets reflect CO<sub>2</sub> equivalence (CO<sub>2</sub>e)

# Scoping Emissions


1. Stationary fuel combustion
2. Grid-supplied energy



# Planning for Capital Requirements

- **Key thoughts:**
  1. Existing building stock mix and characteristics
  2. Temperature requirements
- **Budgeting at the University of Michigan**

**What is the mix of new vs. existing building space?**  
**What are the characteristics of the existing HVAC systems?**




## What temperatures are required for hot water thermal service?

|                                   | Option A - Building Peak Supply of 180 °F                              | Option B - Building Peak Supply of 140 °F   |
|-----------------------------------|--|---|
| <b>HWDH Distribution System</b>   | Higher Delta T, smaller pipe sizes                                     | Lower Delta T, larger pipe sizes  |
| <b>Building System Conversion</b> | Non-invasive retrofit of AHUs likely                                   | Mandatory replacement of AHUs & coils   |
|                                   | Reuse of hot water piping on building side of steam/HW heat exchangers | Mandatory replacement of perimeter radiation.<br><br>Potential Replacement of hot water piping in the building. |
| <b>Operating Costs</b>            | Higher energy costs for temperature boost during peak conditions       | Increased use of low temperature resources  |
|                                   | Higher distribution heat loss.   | Lower distribution heat loss.   |
|                                   | Lower pumping costs.   | Higher pumping costs.   |

# Capital Requirements: U-M Preliminary Study

| Option   Description                                  | 2018 \$ Totals |
|---|----------------|
| Present Value in 2018 (USD in millions)               |                |
| Option 1 – Base Case – One for one boiler replacement | \$21           |
| Option 2 – Central Heating Plant                      | \$58           |
| Option 3 – Central Heating Plant + Cogeneration       | \$78           |



# Financial Viability: Metrics

- **Simple payback**
- **Net Present Value (NPV):**
  - The difference between the present value of the benefits of a project and its costs.
  - Executing a project with a positive NPV is equivalent to avoiding its NPV in cash today

# Financial Viability: U-M Preliminary Study

## Outcomes without Carbon Cost

- Key thoughts:
  1. Viable in the long term
  2. 30-Yr study window influences NPV

|  | Option 1          | Option 2         | Option 3           |
|--|-------------------|------------------|--------------------|
| 30-Yr Net Present Value<br>Present Value in 2018 (USD in millions) | Localized Heating | New Boiler Plant | CHP Plant Addition |
| Natural Gas  | \$49              | \$29             | \$48               |
| O&M  | \$35              | \$28             | \$44               |
| Carbon Cost  | \$0               | \$0              | \$0                |
| Electricity Offsets  | \$0               | \$0              | (\$84)             |
| <i>Subtotal Operating Costs</i>                                    | \$84              | \$57             | \$8                |
| <i>Subtotal Capital Costs</i>                                      | \$19              | \$56             | \$76               |
| Net Incremental Capital Costs                                      |                   | \$37             | \$57               |
| <i>Total Life Cycle Costs</i>                                      | \$103             | \$112            | \$84               |
| NPV Cost Savings vs. Base  |                   | <b>(\$9)</b>     | <b>\$19</b>        |
| Option Selection   | 2                 | 3                | 1                  |
| Payback (years)  |                   | 26               | 18                 |


# Pricing Carbon

- **Key thoughts:**
  1. **\$27.27/Ton is equivalent to a cost of 1.5 cents per kWh when electrical service is provided by DTE Energy**
  2. **Implementing a carbon cost increases financial viability of district energy options**

|  | Option 1          | Option 2         | Option 3           |
|--|-------------------|------------------|--------------------|
| 30-Yr Net Present Value<br>Present Value in 2018 (USD in millions) | Localized Heating | New Boiler Plant | CHP Plant Addition |
| <b>With a \$27.27/Ton Carbon Tax</b>                               |                   |                  |                    |
| Total Life Cycle Costs   | \$ 123            | \$ 127           | \$ 97              |
| NPV Cost Savings vs. Base  |                   | <b>(\$5)</b>     | <b>\$26</b>        |
| <b>With a \$60/Ton Carbon Tax</b>                                  |                   |                  |                    |
| Total Life Cycle Costs   | \$ 146            | \$ 145           | \$ 112             |
| NPV Cost Savings vs. Base  |                   | <b>\$1</b>       | <b>\$35</b>        |
| <b>With No Carbon Tax</b>  |                   |                  |                    |
| Total Life Cycle Costs   | \$ 103            | \$ 112           | \$ 84              |
| NPV Cost Savings vs. Base  |                   | <b>(\$10)</b>    | <b>\$19</b>        |

# Where will your electricity consumption come from?

## What is the carbon footprint of that power?




# Key Considerations

## Distribution piping system (DPS) lifespan

- EN-certified piping systems are expected to last at least 50 years
- Difficult to capture the residual value of the DPS over a shorter study period

## The spark spread

- Infamously difficult to predict changing natural gas prices over time
- Variation by region and utility mix



# Key Considerations

## Seasonal boiler efficiency

- Small variations in efficiency can have large effects
- An in-depth study presented in the 1994 ASHRAE journal postulated 42.5% to 76.6% should be used when actual performance is not available

# Thanks for your attention!

## Questions?

**James Bohn**

**Phone: 612-315-6451**

**Email: [jbohn@fvbenergy.com](mailto:jbohn@fvbenergy.com)**



*Global Presence  
Local Solutions*

*45 Years of Experience in Sustainable District Energy Systems*