

DECEMBER 2018



The University of Texas at Austin
Utilities and Energy Management

THE EVOLUTION OF THE UT AUSTIN UTILITY PLANTS

JUAN ONTIVEROS, P.E.

The University of Texas at Austin

BEN ERPELDING, P.E.

Optimum Energy




Presentation Objectives


- UT Austin's Philosophy for Cooling
- UT's Actual Historical Performance
- Impact to Power Generation
- UAE Plant Operation vs UT Plant Operation
- VFD vs Constant Speed



Plant Performance



Holistic Approach to Total Energy



Evolution of Optimization

2007

45K Tons - Eliminate Steam Turbine Chillers, Add 15K Electric Chillers w/VFD's but no Optimization

Annual Average kW/ton = 0.84

15 million GSF

MW = 59, Tons = 29.3k, Steam 200k

2008

45k Tons - Start Optimizing 15K ton plant

Annual Average kW/ton = 0.80

15.9 million GSF

MW = 60, Tons = 33.1k, Steam = 190k

2009

Evaluate Distribution DP control and VFD Pumps at CS3

Annual Average kW/ton = 0.77

15.9 million GSF

MW = 62, Tons = 34k, Steam = 191k

2013

Optimize Multiple Plant Dispatch, Reduce DP to 10 to 4 psi (summer vs rest of year) (4 plants)

Annual Average kW/ton = 0.66

17.9 million GSF

MW = 61, Tons = 33.4k, Steam = 188k

2014 – 2017

Start Using 4 MG TES

4-year Average kW/ton = 0.66

18.3 million GSF

MW = 61k, Tons = 33.6k, Steam = 203k

2018 - 60k Tons

Add 15k All VFD Plant, Add VFD to 5k ton OM Chiller, Start Using 6 MG TES

Annual Average kW/ton = 0.615

19.6 million GSF

MW = 65, Tons = 38.3k, Steam = 240k

Total
Cumulative


Saved:

509.6K MWh

\$21.3 Million



Peak MW Adjusted for Space Growth





Campus Staging

OAT 59.8 °F

OAH 41 %

WET BULB 48.0 °F

CHURMODE ON

LOOPMODE ON

UT Austin

Campus Demand

UT CHW Demand Flow	22,136.0 gal/min
UT CHW Demand Tons	8734.5 Tons
UT CHW Chlr Tons	6661.5 Tons
UT CHW TES Tons	2073.0 Tons

Chiller Station 4

Total Plant kW	0.0 kW
Total Plant Efficiency	0.000 kW/Ton
C54 CH1 EvapTons	0.0 Tons
C54 CH1 EvapFlow	0.0 gal/min
C54 CH2 EvapTons	0.0 Tons
C54 CH2 EvapFlow	0.0 gal/min
C54 CH3 EvapTons	0.0 Tons
C54 CH3 EvapFlow	2.0 gal/min

Thermal Energy Storage Tank 1

TESMODE	2
Total Plant Energy Use	137.4 kW
TES1 Pump Efficiency	0.022
Charge Flow	0.0 gal/min
Discharge Flow	6,042.0 gal/min
Thermocline	58.0 ft

UT Austin Distributed Chiller System

Thermal Energy Storage Tank 2

TESMODE	0
Total Plant Energy Use	0.0 kW
TES2 Pump Efficiency	0.0
Charge Flow	0.0 gal/min
Discharge Flow	0.0 gal/min
Thermocline	9.0 ft

System Totals

UT CHW Total Flow	16,106.0 gal/min
UT CHW Total kW	2,305.5 kW
UT CHW Total Ton	6661.5 Tons
UT CHW Total kW/Ton	0.346 kW/Ton
C53 Total Ton	0.0 Tons
C54 Total Ton	0.0 Tons
C55 Total Ton	0.0 Tons
C56 Total Ton	3953.0 Tons
C57 Total Ton	2708.5 Tons
HDPE CHW5 Flow	-3,332.0 gal/min
HDPE CHWR Flow	-3,440.0 gal/min

Chiller Station 5

Total Plant kW	0.0 kW
Total Plant Efficiency	0.000 kW/Ton
C55 CH1 EvapTons	0.0 Tons
C55 CH1 EvapFlow	3.0 gal/min
C55 CH2 EvapTons	0.0 Tons
C55 CH2 EvapFlow	3.0 gal/min
C55 CH3 EvapTons	0.0 Tons
C55 CH3 EvapFlow	6.0 gal/min

Dashboard

Chiller Station 6

Total Plant kW	1,255.0 kW
Total Plant Efficiency	0.318 kW/Ton
C56 CH1 EvapTons	0.0 Tons
C56 CH1 EvapFlow	0.0 gal/min
C56 CH2 EvapTons	2010.0 Tons
C56 CH2 EvapFlow	4,795.0 gal/min
C56 CH3 EvapTons	1943.0 Tons
C56 CH3 EvapFlow	4,789.0 gal/min

Dashboard

Turbine Inlet Cooling

G78 AIC ZI	0.0
G78 AIC Flow	146.0 gal/min
GT10 AIC ZI	20.0
GT10 AIC Flow	188.0 gal/min

Chiller Station 3

Total Plant kW	0.0 kW
Total Plant Efficiency	0.000 kW/Ton
C53 CH1 EvapTons	0.0 Tons
C53 CH1 EvapFlow	0.0 gal/min
C53 CH2 EvapTons	0.0 Tons
C53 CH2 EvapFlow	0.0 gal/min
C53 CH3 EvapTons	0.0 Tons
C53 CH3 EvapFlow	0.0 gal/min

Dashboard


Chiller Station 7

Total Plant kW	913.1 kW
Total Plant Efficiency	0.338 kW/Ton
C57 CH1 EvapTons	1355.1 Tons
C57 CH1 EvapFlow	3,285.0 gal/min
C57 CH2 EvapTons	0.0 Tons
C57 CH2 EvapFlow	1.0 gal/min
C57 CH3 EvapTons	1353.4 Tons
C57 CH3 EvapFlow	3,216.0 gal/min
C57 CH4 EvapTons	0.0 Tons
C57 CH4 EvapFlow	0.0 gal/min
C57 CH5 EvapTons	0.0 Tons
C57 CH5 EvapFlow	2.0 gal/min
C57 CH6 EvapTons	0.0 Tons
C57 CH6 EvapFlow	1.0 gal/min

Dashboard



Persistent Monitoring



Performance To Date vs Last Year


- Using Both TES for First Time (80,000 ton-hrs)
- Started TES & Chilling Station Optimization
 - Working through transitions:
 - Charging to Discharging & Vice Versa
 - Multiple Chilling Station Dispatch
 - Optimize Power Generation vs Chilled Water Production
 - Shift load to Nighttime – Increase Electrical Generation Efficiency (~3% Better)
- Peak Electrical Load and Cooling Load is August to September
 - Peak Power = 59 MW vs last year at 65 MW
 - Peak Cooling Demand = 34,118 vs last year at 38,300 (includes TES Dispatch)
 - **30,000 tons are Spare (CS3, CS4 & 5-2500 ton Chillers at CS7)**

**Goal is to
Absorb Campus
Growth With No
New Plants**

Auxiliary Energy Performance

UAE District Energy Plant


- Condenser water pump efficiency decreases as load decreases
- Primary pumps behave exactly the same
- This is the result of constant speed pumping and lack of VFDs
- Pumps cannot adjust with load so efficiency is a step function based on the number of pumps running
- # Pumps On = # Chillers On
- Chiller staging becomes a critical factor in overall efficiency



Variable Speed Condenser Water Pumps


UT Austin

- Condenser water pump efficiency increases as load decreases
- Variable CHW primary-only plant (no primary secondary)
- Pumps adjust with load
- # Pumps on does not equal # Chillers On
- Chiller staging becomes less of a factor in overall efficiency



Variable Speed Chillers vs. Constant Speed Chillers


- Chiller efficiency is linearly proportional to lift
- Variable speed chillers are more efficient at all loading due to redundant equipment.
- Constant speed chillers use constant speed condenser water pumps
- Variable speed chillers are operating at variable condenser water flow
- > 20% savings even at high wet bulbs



Cooling Tower Selection

Site	Entering (deg F)	Leaving (deg F)	Wet bulb (deg F)	Approach (deg F)
UT Austin CS7	93	83	78	5
UAE site 1	103.1	93	86	7
UAE site 2	105.1	95	88	7
UAE site 3	105	95	86	9
UAE site 4	104.9	95	87.62	7.38
UAE site 5	103.1	93.2	87.8	5.4
UAE site 6	102.38	93	87.8	5.2
UAE site 7	107.6	96.8	91.4	5.4
UAE site 8	105	95	86	9
Recommended design for UAE	101	91	88	3


Cooling Tower Selection



- Approach gets worse as wet bulb decreases
- Approach improves significantly at part flow conditions
- It is possible at 33% flow to operate at less than a 1 deg F approach
- Towers at UT Austin are consistently operating at 1.5 to 2.5 deg F approaches year round.

All Variable Speed Chilled Water Plant



UAE District Energy Constant Speed Plant vs UT Austin All Variable Speed Plant (39 deg F CHWST)



Thermal Energy Storage (Total UT CHW Plant Electric kW)



Reset zoom





Questions?

JUAN ONTIVEROS, P.E.

The University of Texas at Austin
Juan.Ontiveros@austin.utexas.edu



The University of Texas at Austin
Utilities and Energy Management

BEN ERPELDING, P.E.

Optimum Energy
ben.erpelding@optimumenergyco.com

