

LEADING THE WAY
CampusEnergy2022

Feb.15-18 | Westin Boston Seaport District Hotel | Boston, MA

Thermal Energy Storage (TES) for Resiliency and Capital Offset at the University of Oregon

Justin Grissom, P.E.




BURNS  **MCDONNELL**

February 17, 2022


UNIVERSITY OF OREGON OVERVIEW

- ▶ 295-acre campus located in Eugene, Oregon with 80+ buildings
- ▶ Tier 1 Public Research University and #1 in Oregon
- ▶ Over 22,000 students enrolled in 2021-2022
- ▶ 10MW Combined Heat and Power (CHP) plant
- ▶ 6.5MW Emergency Power Generation
- ▶ Two (2) Natural Gas Fired Boilers (60/65 kpph)
- ▶ 7,500-ton Chilled Water Plant
- ▶ Nearly four miles of Distribution Tunnels



UTILITY AND ENERGY INITIATIVES

- ▶ EWEB study and potential rebates
- ▶ Delta-T improvements
- ▶ Equipment Staging and Pump Control
- ▶ Building-side improvements
- ▶ Hydraulic modeling
- ▶ Strategic Energy Management Plan




DRIVERS FOR UPGRADES

- ▶ Campus is growing!
- ▶ Chilled water load is projected to grow from 6,000 tons to 13,500 tons by 2050
- ▶ Need to expand existing chilled water plant capacity to maintain N+1 redundancy
- ▶ Potential for rebates and future financial advantages with TOD electrical rate structure
- ▶ Desire for increased resiliency



OUR PROCESS

- ▶ Developed load projections
- ▶ Focus was on 2030 with consideration though 2050
- ▶ Load Assumptions
- ▶ Current Day CHW load profile
 - Load Growth (2019 peak – 4,600 tons)
 - ▶ 6,000 Ton Peak - +30%
 - ▶ 8,400 Ton Peak - +80%



OUR PROCESS


- ▶ Identified new chiller capacity/capital costs needed for future loads
 - Chiller plant design based on 1500 ton “blocks” of capacity
 - Determined that 2 chillers could be avoided through 2037
 - Preserves future plant floorspace, reduced maintenance costs

OUR PROCESS


- ▶ Evaluated tank sizes, materials, and operating scenarios
 - 2, 3, and 4 MMGal tank capacities evaluated
 - Concrete and Steel tanks were both considered
 - Load Levelling, Partial Storage, and Full Storage analyzed
 - Load Levelling maximized capital offset with minimum tank size
 - ▶ Likely different results with a time-of-day rate structure

OUR PROCESS


FULL LOAD SHED (FLS)



PARTIAL LOAD SHED (PLS)



LOAD LEVELLING (LL)






OUR PROCESS

- ▶ Financial analysis and LCC-based tank size selection
- ▶ Concrete Tank (tank only)
 - 2MMGal/15,000 ton-hours (95' x 55')
 - 4MMGal/30,000 ton-hours (130' x 55')
- ▶ Steel Tank (tank only)
 - 2MMGal/15,000 ton-hours (81'x 56')
 - 4MMGal/30,000 ton-hours (112' x 58')
- ▶ Costs are roughly equal at budgetary pricing level – steel vs. concrete
- ▶ Steel tank requires less diameter for similar overall height

OUR PROCESS

- ▶ Under current loads:
 - Max \$ Savings = Load Levelling (LL)
 - \$ saved for 2MG = 3MG = 4MG
- ▶ ANY Future Load Growth limits operation of 2MG Tank
- ▶ 3MG Tank Size Recommended
 - LL on 99% of days thru 100% peak growth
 - LL even on peak day thru 50% peak growth




Note: Excess Storage must be >0 to Load Level

OUR PROCESS

► Design

Piping Plan View




Decoupler – New Valve

Interior




Exterior



OUR PROCESS

► Design



OUR PROCESS

► Bidding

- Solicitation allowed for concrete or steel
- Multiple bids received
- Generally similar bid \$ and duration
 - One outlier with major exclusions

EFFORTS TO DATE/CURRENT STATUS

- ▶ Tank has been awarded
- ▶ Permitting completed
- ▶ Site work has begun
- ▶ Temporary chilled water shutdown for tie-ins completed

NEXT STEPS

- ▶ Complete additional balance of plant work
 - New Cooling Tower
 - CHW Pump VFDs
 - Upgrades to Free Cooling Heat Exchanger
 - Control System upgrades
 - Miscellaneous structural upgrades

LESSONS LEARNED

- ▶ Low cost, low carbon electricity is challenging for ECMs
- ▶ Load levelling will likely prevail with no time-of-day rate impact
- ▶ Benefits to selecting a vendor that can provide a full “turnkey” tank installation
- ▶ Water treatment costs can be significant

