Campus Energy 2021 BRIDGE TO THE FUTURE Feb. 16-18 | CONNECTING VIRTUALLY WORKSHOPS | Thermal Distribution: March 2 | Microgrid: March 16



Thermal Energy Storage Couples Savings with Flexibility at NCSU Centennial Campus

Bill Ferrell - NCSU **Jonathan Eveleth, PE** - RMF Engineering, Inc.





Q&A Will Not Be Answered Live

Please submit questions in the Q&A box. The presenters will respond to questions off-line.



NORTH CAROLINA STATE UNIVERSITY

- Founded in 1887 in Raleigh, North Carolina
- 36,000 Students
- 8,800 Faculty and Staff
- 12 colleges representing all major academic fields

CENTENNIAL CAMPUS

- Public-Private research campus
- 70+ corporate, government and nonprofits
- 70+ research and academic units
- Home to College of Engineering, College of Textiles and Institute for Emerging Issues





CENTENNIAL BIOMEDICAL CAMPUS PLANT 4,800 TON CHW 80,000 PPH STEAM

Centennial Campus

CATES PLANT 4,000 TON CHW

- 100,000 PPH STEAM
- 11 MW POWER GENERATION

WEST CHILLER PLANT 2,000 TON CHW

West Campus

NORTH CAROLINA STATE UNIVERSITY – DISTRICT ENERGY

NC STATE UNIVERSITY

YARBROUGH PLANT 10,000 TON CHW 200,000 PPH STEAM

CENTENNTIAL CAMPUS UTILITY PLANT

- 11,000 TON CHW
- 25,000 TON-HOURS TES
- 180,000 PPH STEAM
- 5.5 MW POWER GENERATION


Problem: Growth on Centennial Campus





CENTENNIAL CAMPUS UTILITY PLANT - CHILLED WATER

NORTH CAROLINA STATE UNIVERSITY










Utility Cost Savings – Time of Use

On-Peak Cost

- \$19.29/kW Summer Demand Charge
- \$14.15/kW Winter Demand Charge
- \$0.054 per kWh Energy Charge



NC STATE UNIVERSITY


Off-Peak Cost

- \$0.89/kW Demand Charge
- \$0.049/kWh Energy Charge





Summer Power Shift North Carolina State University - CCUP




Average Monthly Demand Charge Savings: 2,000 kW per month


Estimated Annual Savings \$290,000+/year




Connectivity



Connectivity: Discharge




Connectivity: Charge



Challenge: Operation and Control

- PLC Based Control System
- Desired Automatic Dispatching
- Capital Project Limitations
- Predictive Weather Data
- Operator Control








CENTENNIAL CHILLER PLANT - TES WEATHER DATA



Monday, March 16, 2020 16:28:55


OUTSIDE AIR				FORECAST	DATA		Ĵ.		FORECAST DATA							
67.5 °F WET BULB	тіме		ТЕМР (°₽)	HUMIDITY (%)	PRESSURE (mb)	ENTHALPY (BTU/LB)	ESTIMATED TONS		ТІМЕ		темр (⁰ €)	HUMIDITY (%)	PRESSURE (mb)	ENTHALPY (BTU/LB)	ESTIMATED TONS	PRODUCTION 1419 TONS 0.731 kW/TON
50.7 °F	16:00	8	59.6	46	1027.7	19.6	1218		5:00	8	53.3	81	1024.0	20.3	1312	RLA AVG
29.1 %	17:00	8	60.7	45	1026,7	20.0	1267		6:00	8	52.1	83	1023.9	19.8	1245	74.3 %
ENTHALPY	18:00	8	61.7	44	1026.5	20.3	1318		7:00	\otimes	51.4	84	1023.9	19.5	1205	STAGING CURRENT STAGE
	19:00	8	61.5	46	1026.8	20.5	1342		8:00	9	51.2	84	1024.0	19.5	1192	1
CHILLED	20:00	之	59.8	51	1026.8	20.3	1314		9:00	9	51.8	84	1024.1	19.7	1234	STAGE LOGIC
CONDENSER WATER	21:00	乙	58.6	56	1026.9	20.3	1317		10:00	9	52.7	84	1024.2	20.2	1304	
	22:00	乙	57.2	61	1026.8	20.2	1301		11:00	9	53.6	85	1024.2	20.8	1396	
COOLING TOWERS	23:00	凶	56.1	64	1026.6	20.0	1268		12:00	9	55.1	81	1024.1	21.2	1465	
TES TANK	24:00	之	55.2	69	1026.4	20.1	1283		13:00	宁	57.8	77	1023.8	22.3	1639	
	1:00	凶	54.5	74	1025.8	20.2	1299		14:00	9	60.2	75	1023.5	23.4	1842	
WEATHER DATA	2:00	心	53.7	77	1025.2	20.1	1285		15:00	8	62.6	71	1022.8	24.2	2013	
BUTTON 6	3:00	乙	53.5	79	1024.8	20.2	1296		16:00	8	64.6	69	1022.1	25.1	2196	
	4:00	8	53.4	80	1024.5	20.2	1305									
BUTTON 7					400	0	но	JRLY ESTIMATED TO	ONS							
TRENDS					880											
ALARMS					200											
LOGIN					100		20:00 22:00 24	00 2:00 4:00 6:00	£00 10:00	12:00	14:00 15:00				Weather Powe	red by Dark Sky
ACKALM	11 40 48 AM 1/16/2220 CCUP CH2_STRT_FAIL CCUP CHILLER 2 NOT RUNNING WHEN COMMANDED TO START 1											Digital Digital				

Forecast Accuracy



Sequencing

- Forecast ton-hours
- Tank capacity
- Available chillers






CENTENNIAL CHILLER PLANT - TES TANK

for the second second													Tuesday, Janua	ry 05, 2021 14:58:56
OUTSIDE AIR TEMP 53.1 °F	SEASON	PREP START	PREP DEMAND START START		TES STAGE	TANK AVAILABLE (TONS)	DEMAND ESTIMATE (TONS)	DEMAND REMAINING (TONS)	TES CHLR STAGE	CHILLER BIAS	CHILLER	!S	PEAK KW IMPORT	PLANT PRODUCTION 785 TONS
WET BULB	WINTER	5:30	5:45	21:15	DEMAND	12499	11575	5345	0	NO BIAS	СН1 СН2 СН3 С	на сн5 сн6	3836	0.016 kW/TON
45.4 °F HUMIDITY 55.4 %			99.8 %	5 9 ¹	9.7 %								kW IMPORT	RLA AVG
ENTHALPY	RTD 29: 49.9 0 RTD 28: 50.2 0											_	3497	STAGING CURRENT STAGE
	RTD 27: 49.9 0 RTD 26: 49.7 0	F-					1000		HOURLYEST	IMATED TONS			DELTA kW	0
CHILLED WATER	RTD 25: 49.6 9 RTD 24: 49.5 9	F					750 -						339	STAGE LOGIC DISABLED
CONDENSER WATER	RTD 23: 49.4 ° RTD 22: 49.3 ° RTD 21: 49.2 °	F-					500 — -							TES FLOW 500 GPM/ACTIVE
COOLING TOWERS	RTD 20: 49.2 0 RTD 19: 49.2 0	F-					250 — - 0 —							ACTIVE
TES TANK	RTD 18: 48.7 0 RTD 17: 46.9 0	F -					14:00	16:00 18:00 20:0	0 22:00 24:00	2:00 4:00 6:	00 8:00 10:00 12:00 14:0			
WEATHER DATA	RTD 16: 43.0 ° RTD 15: 42.5 ° RTD 14: 42.4 °	F -												
DETAILS	RTD 13: 42.4 0 RTD 12: 42.2 0	F-												
	RTD 11: 42.2 ° RTD 10: 41.6 ° RTD 09: 42.1 °	F-				50.3	2 ºF	TES-2	TO/FROM CHWR HDR					
TRENDS	RTD 08: 42.1 ° RTD 07: 42.1 °	F-						100.0 %			EXPANSION TANK VALVE	TES TANK MAKE	UP WATER	TES LEVEL (%)
ALARMS	RTD 06: 41.4 ° RTD 05: 42.1 ° RTD 04: 42.2 °	F-				42.	-771 TONS 1 °F -2294 GP		0.0 %	S-3		÷	0 GPM	PV 99.8 SP 98.0
LOGIN	RTD 03: 41.8 0 RTD 02: 41.9 0		* * * * *	<u>v v</u> v v				100.0 % 100.1 %	TO/FROM CHWS HDR		0.0 % 0.4 %	29.3 PSIG 0.0 % 0.6 %		OP 0.0
ACKALM	RTD 01: 41.9											LEVEL CTRL	ACTIVE	

Alarms & Operator Control

- Alarms
- Operational Chiller
 Selection






Design Decisions

- Foundation System
- Stairs vs Ladder
- Thermowells vs string temperature sensors
- Dual level transmitters


NC STATE UNIVERSITY

• Façade & Roof



Lessons Learned

- Chiller Maintenance Routine
- Building Controls Predictable temperature spikes at chiller startup
- Construction collaboration is critical!





Jonathan Eveleth, PE, CEM Associate 919.941.9876 Jonathan.Eveleth@rmf.com

NC STATE UNIVERSITY



Bill Ferrell

Plant Engineer

919.513.0736

wferrell@ncsu.edu

