

# ***In Depth Feasibility Studies Aquifer Thermal Energy Storage (ATES) VAMC Chillicothe and Columbus, OH***

20 February 2014

Presented to

IDEA's 27<sup>th</sup> Annual Campus Energy Conference  
***“Clean, Efficient & Resilient Energy”***

February 18 - 21, 2014 • Atlanta Marriott Marquis • Atlanta, GA



by

Mark A. Worthington, Underground Energy, LLC

Mark A. Worthington  
President  
C.G., LSP, LEED AP



Underground Energy, LLC  
*Applied Hydrogeology  
Geothermal Innovation*

8 Highfield Drive  
Lancaster, MA 01523 USA  
Telephone: 508-263-9960  
Email: mark.worthington@underground-energy.com

[www.underground-energy.com](http://www.underground-energy.com)

# Project Team



**IF**TECH



# Outline


- Purposes of this presentation:
  - Understand ATES applications for district energy systems
  - Understand ATES feasibility study methodology
  - Review ATES FS findings for two sites in Ohio
- Project History
- Review ATES FS Results
  - Hydrogeology
  - Loads
  - ATES Conceptual Design
  - Electricity and Emissions Reductions
  - Project Finances
- Current Project Status






# Schematic of an Earth-Coupled Heating and Cooling System


Interior HVAC



Heat Pump




Earth Couple



## LEGEND

- Interior Loop
- Refrigerant Loop
- Ground Loop

# ATES for Cooling





# ATES Growth in The Netherlands

1990




2000



2010



# ATES Based District Heating & Cooling Systems in The United States



Richard Stockton College, Pamona, NJ (2 MW)

# ATES Project Phasing




- Phase I – Desktop Feasibility Study
  - Non-intrusive, look for fatal flaws
  - Preliminary cost estimate
- Phase II – Pre-Design Work
  - Hydrogeologic characterization
  - Thermal and hydraulic modeling of well field
- Detail Design
  - Well and equipment specifications
  - Integration with MEP systems
  - Detailed cost estimate
- Construction
- Commissioning
- Operation, Maintenance & Monitoring



# Phase I ATES


## Feasibility Study Components

- Hydrogeologic Evaluation
  - Aquifer physical and hydraulic properties
  - Aquifer geochemical properties
- Engineering Evaluation
  - Cooling/Heating configuration evaluated
  - Conceptual design
  - Calculate electricity and emissions reductions
- Financial Evaluation
  - Estimate construction cost
  - Estimate financial benefit
  - Identify incentives and financing mechanisms
- Regulatory Evaluation
  - Identify permits required



# ATES Hydrogeologic Evaluation


## Chillicothe, OH





# ATES Hydrogeologic Evaluation

## Chillicothe, OH



Notes:

<560

Approximate bedrock elevation (ft MSL)



Existing VA irrigation well


**FIGURE 4**  
**Available Well Logs in Site Vicinity**



1.0

0.49

0.97




Note: These locations represent records that have coordinates in the ODNR Well Log Database. Please go to <http://ohiodnr.com/water/maptechs/welllogs/appNew/Default.aspx> to search additional records.



# ATES Hydrogeologic Evaluation


## Columbus, OH





# ATES Hydrogeologic Evaluation Columbus, OH

VA Columbus Wells



Notes:

A

A'

Cross Section Line

2017953


Ohio DNR Well Log No.



0.5

0.24


0.49



Note: These locations represent records that have coordinates in the ODNR Well Log Database. Please go to <http://ohiodnr.com/water/maptechs/welllogs/appNew/Default.aspx> to search additional records.



# ATES Hydrogeologic Evaluation Columbus, OH



Project: Columbus ATES FS

Figure XX: Schematic Hydrogeologic Cross Section A-A', B-B', and C-C'



# ATES Hydrogeologic Evaluation

## Aquifer Hydraulic Properties

Parameter	Chillicothe	Columbus
Aquifer Saturated Thickness	98 ft (30m)	20-65 ft
Aquifer Saturated Thickness	98 ft (30m)	20-65 ft
Aquifer depth	115 ft (35m) below ground surface	~115 ft (35m) below ground surface
Aquifer hydraulic conductivity	$1.5 \times 10^{-1}$ cm/s	$\sim 10^{-1}$ cm/s
Aquifer transmissivity	320,000 gpd/ft (3,900 m <sup>2</sup> /day)	8,000 – 800,000 gpd/ft (100 – 10,000 m <sup>2</sup> /day)
Hydraulic Gradient	$10^{-3}$	$10^{-2} - 10^{-3}$
Aquifer storativity	0.042	?
Aquifer Porosity	0.35	0.35
Ambient Groundwater Temperature (est)	55 °F (12.8° C)	55 °F (12.8° C)
Groundwater depth in aquifer	17 ft (5.2m) below ground surface	40 ft (12m) below ground surface
Groundwater elevation in aquifer	621 ft MSL	755 ft MSL
Groundwater flow velocity	1.1 ft /day (0.33 m/day)	~2 ft /day (0.6 m/day)

# ATES Hydrogeologic Evaluation


## Aquifer Geochemistry

ANALYTE	Chillicothe			Columbus
	TH 1-86	TH2-86	PW-1	
Sample Date	2-13-1986	2-13-1986	6-10-1986	
Total Dissolved Solids (mg/L)	360	372	320	
Bicarbonate Alkalinity (mg/L)	204	226	218	
Bicarbonate (mg/L)	204	226	218	
Carbon Dioxide (mg/L)	12	13	14	
Chloride (mg/L)	9	9	36	
Sulfate (mg/L)	105	128	92	
Fluoride (mg/L)	0.28	0.32	0.18	
Silica (mg/L)	0.08	0.09	2.2	
Sodium (mg/L)	14.2	15.1	7.20	
Potassium (mg/L)	2.87	3.04	3.82	
Total hardness (mg/L)	286	298	364	
Calcium (mg/L)	68.0	71.2	122	
Magnesium Hardness (mg/L)	116	120	60	
Magnesium (mg/L)	0.02	0.02	17.3	
Total Iron (mg/L)	0.52	0.59	1.08	Up to 4
Manganese (mg/L)	33.4	34.6	0.17	
Copper (mg/L)	0.00	0.00	0.00	
Turbidity (NTU)	0.46	0.37	6.7	
pH (SU)	7.44	7.45	7.38	


# ATES Engineering Evaluation

## Cooling and Heating Load Duration Curves (Columbus, OH)

### Cooling LDC



### Heating LDC





# ATES Engineering Evaluation

## Groundwater System Design Assumptions

Chillicothe

	Unit	Scenario 1	Scenario 2
Depth wells	feet	90	120
Maximum well yield	gpm	250-300	350-400
Number of doublets (pair of wells)		2	3
Maximum yield groundwater system	gpm	770	770
Natural groundwater temperature	°F (°C)	55 (12.8)	
Injection temperature cold wells, ATES storage temperature during loading operation	°F (°C)	39.2 (4.0)	
Extraction temperature cold wells, supply temperature	°F	41.0 → 46.4	


Columbus

	Unit	Scenario A	Scenario B1	Scenario B2
Depth wells	feet	110	110	110
Maximum well yield	gpm	230	180	180
Number of doublets (pair of wells)		3	2	2
Maximum yield groundwater system	gpm	700	360	360
Natural groundwater temperature	°F (°C)	55 (12.8)		
Injection temperature cold wells, ATES storage temperature during loading operation	°F (°C)	39.2 (4.0)	41.0 (5.0)	41 (5.0)
Extraction temperature cold wells, supply temp. from cold store during cooling operation	°F (°C)	41.0→44.6 (5.0→7.0)	42.8→46.4 (6.0→8.0)	42.8→46.4 (6.0→8.0)



# ATES Engineering Evaluation


## Chillicothe, OH





# ATES Engineering Evaluation

Columbus, OH







# ATES Engineering Evaluation

## Chillicothe, OH

### ATES Implementation Concept A:

Direct cooling combined with new central chiller(s), rejection of condenser heat to wells



#### ENERGY PRODUCTION

##### COOLING LOAD, BUILDINGS (kTR-hrs)

Outside Air (free cooling)	150 kTR-hrs	8%
ATES, Direct Cooling	1,398 kTR-hrs	73%
Chillers, Well Water	363 kTR-hrs	19%
	kTR-hrs	
	kTR-hrs	
S:a	1,911 kTR-hrs	100%

##### COOLING LOAD, BUILDINGS (MWh)

Outside Air (free cooling)	528 MWh	8%
ATES, Direct Cooling	4,922 MWh	73%
Chillers, Well Water	1,277 MWh	19%
	MWh	
	MWh	
S:a	6,727 MWh	100%

##### HEAT INJECTION TO WELLS (MWh)



Outside Air (free cooling)	MWh	
ATES, Direct Cooling	4,922 MWh	77%
Chillers, Well Water	1,468 MWh	23%
	MWh	
	MWh	
S:a	6,390 MWh	100%

# ATES Engineering Evaluation

## Chillicothe, OH

### ATES Implementation Concept B:

Direct cooling combined with new central chiller(s), rejection of condenser heat to cooling tower



#### ENERGY PRODUCTION

##### COOLING LOAD, BUILDINGS (kTR-hrs)

Outside Air (free cooling)	150 kTR-hrs	8%
ATES, Direct Cooling	1,398 kTR-hrs	73%
Chillers, Cooling Tower	363 kTR-hrs	19%

S:a	1,911 kTR-hrs	100%
-----	---------------	------

##### COOLING LOAD, BUILDINGS (MWh)

Outside Air (free cooling)	528 MWh	8%
ATES, Direct Cooling	4,922 MWh	73%
Chillers, Cooling Tower	1,277 MWh	19%

S:a	6,727 MWh	100%
-----	-----------	------

##### HEAT INJECTION TO WELLS (MWh)

Outside Air (free cooling)	MWh	
ATES, Direct Cooling	4,922 MWh	100%
Chillers, Cooling Tower	MWh	



S:a	4,922 MWh	100%
-----	-----------	------

# ATES Engineering Evaluation

## Chillicothe, OH

### ATES Implementation Concept C:

Direct cooling combined with existing air cooled chillers at individual buildings



#### ENERGY PRODUCTION

##### COOLING LOAD, BUILDINGS (kTR-hrs)

Outside Air (free cooling)	150 kTR-hrs	8%
ATES, Direct Cooling	1,398 kTR-hrs	73%
Chillers, Air Cooled	363 kTR-hrs	19%

<b>S:a</b>	<b>1,911 kTR-hrs</b>	<b>100%</b>
------------	----------------------	-------------

##### COOLING LOAD, BUILDINGS (MWh)

Outside Air (free cooling)	528 MWh	8%
ATES, Direct Cooling	4,922 MWh	73%
Chillers, Air Cooled	1,277 MWh	19%

<b>S:a</b>	<b>6,727 MWh</b>	<b>100%</b>
------------	------------------	-------------

##### HEAT INJECTION TO WELLS (MWh)


Outside Air (free cooling)	MWh	
ATES, Direct Cooling	4,922 MWh	100%
Chillers, Air Cooled	MWh	

<b>S:a</b>	<b>4,922 MWh</b>	<b>100%</b>
------------	------------------	-------------



# ATES Engineering Evaluation

Concept A,B&C Winter Mode  
“ATES charging”





# ATES Engineering Evaluation

## Columbus, OH



### ATES Implementation Scenario A:

Direct cooling combined with chillers for peak capacity and supply temperature control

summer



winter







# ATES Engineering Evaluation

## Columbus, OH



### ATES Implementation Scenarios B1 and B2:

Heating and cooling with electric heat pump; natural-gas engine-driven heat pump

summer




winter




# ATES Engineering Evaluation

## Chillicothe



## Columbus


(cooling-only scenario)






# ATES Engineering Evaluation

## Chillicothe



## Columbus



# ATES Financial Evaluation

## Capital Expenditures

### Chillicothe

Chillicothe ATES - CAPEX - Scenario 1	Concept A (k\$)	Concept B (k\$)	Concept C (k\$)
<b>Geothermal System</b>	<b>\$2,100</b>	<b>\$2,100</b>	<b>\$2,100</b>
2 x 2 24" wells, 90 ft deep	\$380	\$380	\$380
Well housings, pumps & equipment	\$250	\$250	\$250
Utility Services - Electricity for well pumps & equipment	\$110	\$110	\$110
Piping and control cables between wells and ETS	\$1,360	\$1,360	\$1,360
<b>Energy Transfer Station</b>	<b>\$1,700</b>	<b>\$1,820</b>	<b>\$520</b>
Building	\$160	\$160	\$80
Electrical	\$550	\$670	\$100
Mechanical	\$310	\$310	\$140
Major Equipment (PHE, Chillers,CT, EG etc )	\$680	\$680	\$200
<b>DC Distribution Piping</b>	<b>\$1,000</b>	<b>\$1,000</b>	<b>\$840</b>
Underground DC Piping and control cables	\$880	\$880	\$720
Building Interconnections	\$120	\$120	\$120
<b>Customer Buildings</b>	<b>\$370</b>	<b>\$370</b>	<b>\$370</b>
Piping and control cables within building	\$100	\$100	\$100
Building system modifications (delta T related)	\$240	\$240	\$240
Addition constr. cost for building #31	\$30	\$30	\$30
<b>GC Admin, OH&amp;P &amp; Sales Tax</b>	<b>\$620</b>	<b>\$640</b>	<b>\$350</b>
<b>Subtotal Construction</b>	<b>\$5,790</b>	<b>\$5,930</b>	<b>\$4,180</b>
<b>Soft Costs</b>			
Engineering	\$460	\$480	\$300
Owners Costs	\$370	\$380	\$210
<b>Subtotal Soft Costs</b>	<b>\$830</b>	<b>\$860</b>	<b>\$510</b>
<b>TOTAL Project Costs</b>			
Construction Costs	\$5,790	\$5,930	\$4,180
Soft Costs	\$830	\$860	\$510
<b>TOTAL</b>	<b>\$6,620</b>	<b>\$6,790</b>	<b>\$4,690</b>

### Columbus

Columbus ATES - CAPEX	Scen. A (k\$)	Scen. B1 (k\$)	Scen. B2 (k\$)
<b>Geothermal System</b>	<b>\$1,190</b>	<b>\$810</b>	<b>\$810</b>
Wells	\$510	\$340	\$340
Well housings, pumps & equipment	\$340	\$240	\$240
Utility Services - Electricity for well pumps & equipment	\$80	\$60	\$60
Piping and control cables between wells and ETS	\$260	\$170	\$170
<b>Energy Transfer Station</b>	<b>\$300</b>	<b>\$520</b>	<b>\$1,030</b>
Electrical	\$30	\$50	\$80
Mechanical	\$100	\$160	\$240
Major Equipment (HEX, HP,CT etc )	\$170	\$310	\$710
<b>Distribution Piping</b>	<b>\$0</b>	<b>\$80</b>	<b>\$80</b>
Underground HW DPS and control cables	\$0	\$80	\$80
<b>Customer Buildings</b>	<b>\$60</b>	<b>\$150</b>	<b>\$150</b>
HW Piping and control cables within building	\$0	\$50	\$50
Building system modifications (delta T related)	\$60	\$100	\$100
<b>GC Admin, OH&amp;P, Constr. Supervision</b>	<b>\$230</b>	<b>\$230</b>	<b>\$310</b>
<b>Subtotal Construction</b>	<b>\$1,780</b>	<b>\$1,790</b>	<b>\$2,380</b>
<b>Soft Costs</b>			
Engineering	\$230	\$230	\$270
Owners Costs	\$130	\$130	\$180
<b>Subtotal Soft Costs</b>	<b>\$360</b>	<b>\$360</b>	<b>\$450</b>
<b>TOTAL Project Costs</b>			
Construction Costs	\$1,780	\$1,790	\$2,380
Soft Costs	\$360	\$360	\$450
<b>TOTAL</b>	<b>\$2,140</b>	<b>\$2,150</b>	<b>\$2,830</b>



# ATES Financial Evaluation

Present Value of Financial Benefit (25 yrs)

## Chillicothe

(kUSD)	Inv.	Avoided Exp.	Var. op. savings	Fix. op. savings	TOT
Concept A	-6,620	3,280	3,620	500	780
Concept B	-6,790	3,280	3,620	500	610
Concept C	-4,690	0	2,960	0	-1,730

## Columbus

(k\$)	Inv.	Avoided Exp.	Var. op. savings	Fix. op. savings	NET
Scenario A	-2,140	1,020	950	180	10
Scenario B1	-2,150	750	1,920	-50	470
Scenario B2	-2,830	750	2,950	-350	520

- Avoided expenditures
  - No need for immediate additional chiller capacity due to planned expansion of Buildings 30 and 31.
  - Reduction of future chiller replacements.
    - Due to reduced chiller loads and to refrigerant phase out schedule
- Operating savings
  - Electrical cost savings
  - Centralized chillers reduce the costs of operating and maintaining individual building chillers
- Potential for Utility Rebate from AEP Prescriptive Program
  - \$80/ton for ground-sourced heat pump systems with EER >17
  - \$30/hp for variable speed drives on chillers
  - Assistance with design fees

# ATES Regulatory Evaluation

- Underground Injection Control (UIC) program administered by the Ohio EPA. ATES wells are Class V wells requiring permits for construction and operation per [OAC Rule 3745-34-12](#) and [OAC Rule 3745-34-16](#).
- Any open-loop system with the capacity to withdraw 100,000 or more gallons per day (gpd) must register with the ODNR-DSWR's Water Withdrawal Facilities Registration Program as required by Section 1521.16 of the Ohio Revised Code.
- No significant problems or barriers to ATES project development have been identified by the regulatory evaluation.



# Phase I Conclusions

- ATES is feasible at both VAMC facilities, and no fatal flaws have been identified in Phase I.
- Buildings connected to the ATES system will need to be retrofitted to provide a higher return temperature and improve  $\Delta T$ s.
- Other than localized thermal impacts in the aquifer and temporary construction impacts, the ATES projects will have minimal adverse environmental impact.
- Subject to utility review and approval, a prescriptive program for a utility rebate from AEP could provide approximately \$50k toward new equipment, and also help offset design fees.
- Prior to Phase II FS work, a hydrogeologic investigation is being performed confirm aquifer extents, ATES well locations, yields, and to verify that the hydraulic gradient and geochemistry are suitable for ATES.

# Summary

## Phase I ATES Feasibility Study

	Chillicothe	Columbus
ATES System Size	450 tons cooling	380 tons cooling 5,260 MBH heating
ATES System Flow Rate	770 gpm	360-700 gpm
ATES Percent of Cooling Load	73%	43%
Reduction in Electricity Use	70%	28-49%
25-year CO <sub>2</sub> Reduction	34,000 metric tons	13,000-32,000 metric tons
Capital Cost	\$6.6 M	\$2.2 M
Capital cost / Ton Cooling	\$14,700/Ton	\$5,600/Ton
NPV	\$0.8 M	\$0.5 M



# Recommendations

- Evaluate ATES for cooling and/or heating modes where:
  - Large heating and cooling loads, and
  - Seasonably variable climate, and
  - An aquifer exists!
  - Consider BTES if no aquifer exists

Thank You!



Knowing is not enough; we must apply.  
Willing is not enough; we must do.

