District Chilled Water Optimization at Penn State Health Milton S. Hershey Medical Center



Kevin Kanoff, C.E.M. - Campus Energy Engineer, Penn State Health Hershey Medical Center Jonathan Kosobucki, P.E. – Director of Project Development, Optimum Energy





Milton S Hershey Medical Center

 Founded in 1963 through a \$50 Million gift from The Milton S Hershey Foundation.





Medical Center Overview

- 24 Academic Departments
- 6 Major Institutes
- 4 Hospitals
- 17 Hospital Affiliates
- 10,000 employees
- 35 ORs

Accredited as both adult and pediatric Level 1
Trauma Center







College of Medicine

- First Students enrolled 1967; First Graduate degrees 1969; First Doctors of Medicine 1971
- Portfolio of \$109M in funded research annually
- Research Equipment
- 400 Ultra Low Freezers
- Ultra Low Freezers (-80 C)





Milton S Hershey Medical Center



- 4.5M square feet of buildings
- 3.6M square feet of conditioned space
- 112,000,000 kWh annually
- 573,000 MMBtu natural gas annually




Infrastructure

- Central Plant provides steam and chilled water to central campus:
 - 3 Cleaver Brooks, dual fuel, water tube boilers (1967)
 - 7 chillers (1999-2017); 8,500 tons of cooling
- 2 Satellite Plants (2008, 2012)
 - 4 chillers; 4,800 tons of cooling
- 1.4 Million gallon Chilled water storage tank
- 155 air handling units across campus











Preventive Maintenance

- Over time the ability of the facility to meet chilled water needs of the facility become difficult.
 - Winter of 2010-11 an aggressive chilled water distribution PM program was instituted.
 - Strainer Cleaning/Replacement
 - Valve Replacement
 - Analog Thermometers added at Air Handler Coils



Hydraulic Study of Chilled Water Distribution System

- Hydraulic Modeling and Analysis
 - Central Plant Chilled Water
 - Central Plant Condenser (Tower) Water
 - Satellite Chiller Plants 1 & 2 Chilled Water




Chilled Water Optimization

- Intelligent Energy Solution
 - Lowering Energy Consumption
 - Reducing Chiller Plant Operating and Maintenance Costs
 - Contributing to Milton S. Hershey's Corporate Energy and Sustainability Goals
- Convert three chiller plants to variable-flow plants
- Implement optimization system powered by OptimumLOOP




Plant Layout - Site






Plant Layout – Satellite Plant 1








Plant Layout – Satellite Plant 2





Plant Layout – CUP (Commissioned mid-June 2016)






Optimization Foundation – Scope of Work

- VFDs added to 375 HP of primary chilled water pumps
- VFDs added to 1000 HP of secondary chilled water pumps
- VFDs added to 750 HP of condenser water pumps
- Power Monitoring for all chillers and auxiliary equipment
- Distribution Flow Meter and Temperature Sensors
- Deploy Optimum Energy Optimization Control Algorithms and Monitoring Platform





All Variable-Speed HVAC System



Total System Schematic



Additional Operational Requirements

- TES Must Remain available for Demand Response
 - Strategy Included hybrid mode of Optimization and Manual Demand Response Action.
- SAT plants elevation created negative return pressure conditions at high SAT plant flows.
 - Resolved through adjusting TES transition sequence changes and limiting SAT plant range
- Changing the Mindset
 - Shift from constant primary flow to variable primary flow
 - Variable chilled water temperatures
 - Variable distributions pressures
 - Variable condenser water flow through chillers
 - Wide range of tower water temperatures





Chilled Water Optimization

Table 1: Optimization Utility Savings

OPTIMIZATION UTILITY SAVINGS	
Electrical Energy Savings	3,406,337 kWh/year
Electrical Demand Reduction	183.7 kW
Cooling Tower Water Savings	1,444,831 gal/year
CO ₂ Emission Reduction	6,101,087 lbs/year


Table 2: Optimization Financial Savings

OPTIMIZATION FINANCIAL SAVINGS	
Utility Rebates and Incentives	\$340,634
Annual Operations Cost Reduction	\$260,656






Efficiency – Simulation during Analysis Phase






Efficiency – Prior to Optimization (2014)





Efficiency – Post Optimization (2016) - 0.709 kW/Ton




Total annual savings of 4,156,991 kWh (2016)






Efficiency – Post Optimization (2017) - 0.675 kW/Ton







Site Efficiency – Post Optimization





Utility Efficiency Analysis – Pre/Post (2016)





- Utility verified savings of 4,156,991 kWh (\$310,000) for 2016
 - \$415,699 Utility Incentive







Chilled Water Optimization – Phase 2





Chilled Water Optimization – Phase 2

- Replace oldest 2 chillers with Magnetic Bearing Chillers
- Projected additional Savings
 - 1,624,040 kWh
 - \$124,000/yr
 - One-Time Additional Incentive \$94,000 (approx.)



Questions?

