

LEADING THE WAY **CampusEnergy**2022

Feb. 15-18 | Westin Boston Seaport District Hotel | Boston, Mass.






BLACKSTONE COMBUSTION TURBINE INLET COOLING RETROFIT

Douglas Schmidt


Harvard University Engineering & Utilities

Harvard University's Electric Microgrid




Electric Distribution

- Provides electricity through Harvard-owned microgrid
- 180 buildings served in Cambridge/Allston
- Utility delivers at seven separate Harvard switching locations
- Each Harvard station supplies a different area of the campus
- Delivery from stations via underground duct and manhole system
- Over 50 circuit-miles though 300 manholes




Chilled Water Service

- Provides chilled water for space cooling, and process (equipment) cooling
- 77 buildings served in Cambridge/Allston
- Two below grade production plants
 - Science Center
 - Northwest Labs
- 19,000 Tons production capacity
 - Seven chillers (2,000 to 5,000 Tons)
 - All electric
- Common distribution network
 - Two plants feed common distribution
 - ~3 ½ miles direct buried supply and return piping




E&U Blackstone Steam



Steam Service

- Provides thermal energy for space heat, domestic hot water, and high pressure processes
- 170 buildings served in Cambridge/Allston
- One steam production plant, Blackstone
- 7.5 MW gas turbine/HRSG with 5 MW backpressure steam turbine for combined cycle CHP configuration
- Three direct-fired boilers with supply to steam turbine
- Multiple line distribution backbone through 2-1/2 miles of walkable tunnel

Blackstone Steam Plant, Utility Operation




1909 – Operation by Cambridge Electric Light Co.

1930 – Modernization project adds two boilers and replaces reciprocating steam engines with steam turbines. Initiates steam supply service to Harvard campus.

1962 – Two boilers added for additional steam production capacity.

1962 Onward – Operation continues with progressively diminished capability, efficiency and reliability.

Blackstone Steam Plant, Utility Operation



Reciprocating Engine-Generator



1930 Plant Modernization

Blackstone Steam Plant, Utility Operation



Blackstone Steam Plant, Harvard Operation



2004 – Acquired by Harvard to ensure security of campus steam supply.

2004 - Steam Plant Upgrade Project

- New boiler and 5 MW backpressure steam turbine for CHP capability.
- Replaced major BOP systems.
- Replaced plant electrical distribution.
- Critical structural repairs.

2014 - CHP Expansion Project

- 7.5 MW gas turbine and HRSG for combined cycle CHP operation
- Associated BOP additions and upgrades

Blackstone Steam Plant, Harvard Operation



Rigging In Boiler Economizer




Boiler Field Assembly

Blackstone Steam Plant, Harvard Operation



Steam Turbine Pedestal Steel



Steam Turbine Rigged to Pedestal

Blackstone Steam Plant, Harvard Operation




Taurus 70 Gas Turbine Rigged Into Turbine Hall

Blackstone Steam Plant, Harvard Operation



HRSG Delivered to Blackstone Street

Blackstone Steam Plant, CHP/Combined Cycle






Current Blackstone Operation

- ✓ Combined cycle/combined heat and power
- ✓ Up to 84% overall production efficiency
- ✓ Increased campus energy supply reliability
- ✓ Improved environmental performance
- ✓ Positive economic performance

What could be better?

CTG Capability and Campus Load vs. Dry Bulb Temperature



Room for Improvement

- Increased campus electrical load during warm weather
- CTG capability decreased by as much as 20% from 7.5 MW nominal rating as ambient temperature increases
- Increased need for costly import power characterized by decreased reliability

Potential Solution

- Gas turbine inlet cooling

Inlet Cooling Options

- Evaporative Cooling



- Low initial cost



- Cooling capability limited to within 1 to 2 degrees of wet bulb

- Chilled Water Cooling



- Extensively utilized, well proven technology



- Inlet air cooling to within the 45 to 50 deg-F range



- Existing campus chilled water production and distribution infrastructure



- CHW distribution nearby Blackstone steam distribution tunnel




- Original CTG project design provision for future inlet air cooling



- Ability to install indoors precludes Blackstone building structural and aesthetic concerns





Blackstone Inlet Cooling Dispatch Modeling

	No Inlet Cooling	Central CHW	Blackstone Chiller
Gross Power (kWh)	Base	696,203	696,203
Net Power (kWh)	Base	568,103	542,531
Steam Production (Lb)	Base	142,675	142,675
Steam Vented (Lb)	Base	398,032	398,032
Electric Demand (kW)	Base	-813	-719
Electric Purchased (kWh)	Base	-174,470	-148,898
Electric Sold (kWh)	Base	393,632	393,632
Chilled Water Use (Ton-Hrs)	Base	144,146	142,122
Heat Input (MMBtu)	Base	5,371	5,371

Hourly Dispatch Basis

- Dispatch for steam production
- Coil design at 90.6 F DB/ 72.7 F WB
- Air leaving coil = 59 F
- Coil operates when $T_{amb} \geq 75$ F
- 30 kW loss for coil delta-P
- 18 kW for Option 3 circ pump

Blackstone Inlet Cooling Economic Review

	Annual Saving	Payback (Yrs)
Without Additional Load		
Central Plant, Long Pipe Run	\$92,000	28.6
Central Plant, Short Pipe Run	\$92,000	20.8
Blackstone Chiller	\$78,000	20.6
With Central Plant Chiller Load Added		
Central Plant, Long Pipe Run	\$138,000	19.5
Central Plant, Short Pipe Run	\$138,000	14.2
Blackstone Chiller	\$120,000	13.1

Economic Basis


- 30-Year operating life
- Natural Gas \$8.19/MMBtu
- Import Power \$0.1506/kWh
- Export Power \$0.04/kWh
- Capacity \$120/kW-Yr

Blackstone Chiller



- 300 Ton Air Cooled Chiller
- 730 gpm coolant flow
- 42 deg-F supply/51 deg-F return temperature
- 309 kW power requirement
- Two separate refrigeration circuits, each with variable speed compressor
- 70% /40% water/glycol coolant
- Low noise design
 - 63 dBA at 30-feet
 - Low noise condenser fans
 - Full acoustic insulation including compressors


Blackstone Inlet Cooling Coil



- Standard OEM design for Taurus 70 turbine
 - 95 F DB/76 F WB air side in
 - 60 F DB/59 F WB air side out
 - 42 deg-F supply/51 deg-F return coolant
- OEM installation/operation guidelines
 - Minimum 8-feet straight duct at coil outlet
 - No coil operation below 55 F ambient
 - Add insulation to inlet air plenum within turbine enclosure


Blackstone Inlet Cooling Coil

CTG Gross kW vs. Inlet Temperature




— Gross kW w/o Cooling — Gross kW w Cooling

Coil Outlet Temperature vs. Ambient Temperature



- Diminished Inlet cooling benefit as ambient temperature decreases
- Risk of freezing and ice ingestion with coil operation below 55 deg-F ambient
 - Accelerated air flow at compressor inlet decreases dynamic temperature by 8 deg-F to 10 deg-F

Inlet Cooling Coil Installation Elevation



Chiller Installation and Final Setting





Coil Field Assembly



Coil Installation and Final Setting



Inlet Cooling Operation



JULY 21, 2020

7:00 AM, No Inlet Cooling

CTG Gross = 5,603 kW

Ambient Capability = 7,043 kW

Power Import = 1,376 kW

Power Export = 0 kW

Blackstone Aux = 700 kW

12:00 PM, Inlet Cooling

CTG Gross = 7,670 kW

Ambient Capability = 6,746 kW

Power Import = 478 kW

Power Export = 0 kW

Blackstone Aux = 841 kW

Lessons Learned

- ❑ Consider designing for inlet cooling even if not installing immediately.
- ❑ The seemingly obvious source for chilled water may not be the best.
- ❑ Work closely with turbine OEM during design and procurement.
- ❑ Added electric load maximizes inlet cooling benefit.
- ❑ Understand project goals and operating environment.





QUESTIONS



LEADING THE WAY
CampusEnergy2022

Feb.15-18 | Westin Boston Seaport District Hotel | Boston, MA



HARVARD
Campus Services
ENGINEERING & UTILITIES



THANK YOU

DOUGLAS SCHMIDT



HARVARD
Campus Services
ENGINEERING & UTILITIES