

Closed-Loop Steam Distribution



Andrew Kozak, PE, AEE Fellow

Director of Mechanical Engineering
646.205.7207

AKozak@brplusa.com



Patrick Lach

Steam Specialist | International Sales Manager
[Ca.Linkedin.com/in/ SteamSpecialist](https://www.linkedin.com/in/SteamSpecialist)
Patrick@Maxi-Therm.net



Maxi-Therm Client Pedigree



University
of Colorado
Denver



HARVARD
UNIVERSITY



GRAND VALLEY
STATE UNIVERSITY



THE UNIVERSITY
of
WISCONSIN
MADISON



THE UNIVERSITY OF
CHICAGO



University of
Connecticut



Penn



THE UNIVERSITY of
NEW MEXICO

- 1. Steam Basics**
- 2. Hydronic vs Steam**
- 3. Advantages of Closed-Loop Steam**
- 4. Vertically-Flooded Design**
- 5. Corrosion Prevention**
- 6. Hot Water Applications**
- 7. Example in Practice: Vassar Hospital**
- 8. What is Next? (GenSet)**

Cities With Central Steam

- New-York
- Philadelphia
- Boston
- Baltimore
- Washington DC
- Hartford
- Buffalo
- Rochester
- Minneapolis
- Milwaukee
- Denver
- Montreal
- Vancouver
- Pittsburg
- Saint-Louis
- Tulsa
- Kansas City
- San Francisco
- New Orleans
- Detroit
- Cambridge
- Los Angeles
- Houston
- San Antonio
- Austin
- Richmond
- San Diego
- Grand Rapids

Properties of Saturated Steam

Raising 1 lb. of **WATER** 1°F → **1 BTU** of Energy

Raising 1 lb. of **STEAM*** 1°F → **970 BTU** of Energy

*AT ATMOSPHERIC PRESSURE

Pressure (psig)	Temp. (°F)	Heat (BTU/lb)			Volume (ft ³ /lb)	
		Sensible	Latent	Total	Condensate	Steam
0	212	180	970	1150	0.01672	26.80
1	215	184	968	1152	0.01674	25.21
2	219	187	966	1153	0.01676	23.79
3	222	190	964	1154	0.01679	22.53
4	224	193	962	1155	0.01681	21.40
5	227	195	961	1156	0.01683	20.38
6	230	198	959	1157	0.01685	19.46
7	232	201	957	1158	0.01687	18.62
8	235	203	956	1159	0.01689	17.85
9	237	206	954	1160	0.0169	17.14
10	239	208	953	1161	0.01692	16.49
12	244	212	950	1162	0.01696	15.33
14	248	216	947	1163	0.01699	14.33
16	252	220	944	1164	0.01702	13.45
100	338	309	881	1190	0.01785	3.8910
105	341	312	878	1190	0.01789	3.7360
110	344	316	876	1192	0.01792	3.5940
115	347	319	873	1192	0.01796	3.4620
120	350	322	871	1193	0.01799	3.3400
125	353	325	868	1193	0.01803	3.2260

Hydronic (212°F)

$$35,140,000 \text{ Btu/hr} * \frac{1}{180} \text{ lb/Btu} * \frac{1}{8.33} \text{ Gal/lb} * \frac{1}{60} \text{ hr/min} = \mathbf{391 \text{ GPM}}$$

Steam (100psi)

$$35,140,000 \text{ Btu/hr} * \frac{1}{1,190} \text{ lb/Btu} * \frac{1}{8.33} \text{ Gal/lb} * \frac{1}{60} \text{ hr/min} = \mathbf{59 \text{ GPM}}$$

Lower flow rate → Smaller pipes required

Reduced Pump Energy

Steam



15 HP

Hydronic




90 HP


The pumps represent 3% of the overall energy needed for the hydronic loop

Hydronic Vs Steam


Conventional Method



Steam Method



BRA+ Advantages of Closed-Loop Steam



$$\dot{m}_{fs} = \frac{\dot{m}_c(h_c - h_{fc})}{h_{fg}} \quad R_{fs}(\%) = 100 \frac{\dot{m}_{fs}}{\dot{m}_c}$$

\dot{m}_{fs} = mass flow rate of flash steam

\dot{m}_c = mass flow rate of condensate

h_c = enthalpy of condensate

h_{fc} = enthalpy of flash condensate

h_{fg} = latent heat of flash steam

R_{fs} = flash steam ratio (%)

BRA+ Advantages of Closed-Loop Steam


- **No flash tank required → No Vent to roof**
- **Energy savings of 5-20%**
- **Safety and reliability**
 - No steam safety valve needed
- **Simplicity**
- **No acid contamination**
 - Up to 6 times less corrosive on condensate piping
- Can use **high** or **low pressure steam**



System and Size

BRA+ Advantages of Closed-Loop Steam


- **Less make-up water** required
- **No PRV** required for steam
- **No condensate receiver pump** needed to return steam through loop
- **Smaller pipe size** due to higher energy content
- **Lower maintenance costs**
- **Few chemicals** and **fewer return lines** (with longer lifespan)
- **40%-60% smaller footprint**
- **Fully automated** control system
- **Digital Energy readouts**
- **No Noise**



Digital Readout


- Vary % of shell flooded to avoid flash
- Can use **low, medium, or high** pressure steam
- **No PRV** downstream of boiler
- Acts as a *Condensing Heat Exchanger*

Process	Pressure (psig)	BTU/h	Sensible (BTU/lb)	Latent (BTU/lb)	Total (BTU/lb)	lbs/h	Savings
Conventional	6	4 000 000	-	959	959	4 171	-
Flooded	6	4 000 000	50	959	1 009	3 964	5,0%
Flooded	100	4 000 000	158	881	1 039	3 850	7,7%



0% FLASH, 200°F CONDENSATE RETURN

- Uses **latent** and **sensible** heat of steam to heat liquid
- Oversized vertical shell & tube heat exchanger
- Flooded condensate **subcooled** to **200°F**
- Level of condensate varied by control valve
 - Used to control temperature instead of throttling steam
- Improvements from comparable European models:
 - Steam can be **any pressure**
 - **Control set-point** of heated liquid outlet






Vertically Flooded Heat Exchangers



Heat Map Showing Tube Flooding to Avoid Flash

Make-Up Water Reduction

- Causes for make-up water to be added traditionally:
 - Boiler blow-down
 - Leaks
 - **Flash steam**
- Vertical heat exchanger **eliminates flash**
 - Condensate is subcooled below boiling point
 - Stays as a liquid
 - High pressure condensate eliminates need for condensate pump



Evaluation- Operating Cost Comparison: Exchanger with Full Load

	Conventional	Vertically-Flooded
Pressure (psig)	10	30
Energy Transferred (Mbtu/hr)	6.01	6.01
Steam Flow Rate (lbs/hr)	6,307	5,991
Percentage of Water Lost to Flash	2.85%	0%
Flash Loss Rate	180	-
Energy to Heat Condensate (Mbtu/hr)	0.38	0.44
Energy to Heat Make Up (Mbtu/hr)	0.04	-
Energy to Vaporize (Mbtu/hr)	5.86	5.57
Total (Mbtu/hr)	6.28	6.01

Savings		
Hours	Dollars	Tons of CO ₂ per Million BTUs
2,000	\$ 6,660.99	38.92
3,000	\$ 9,991.49	58.38

(0.05843 ton of CO₂ per Million BTUs)

- Traditional systems are 6.2 times more corrosive¹
- Deaerator uses low pressure steam to **drive out dissolved gases**
- Sensibly heats make-up water from 40°F to 205°F
 - Condensate reclamation reduces need for make-up water
- Cooler condensate **reduces cavitation**
 - Hot condensate cavitates as pump pulls it into the volute
- Lower make-up water requirement → **less chemicals** for treatment → cleaner steam running through pipes
 - Cuts surface blowdown in half
 - Delivers 97% quality steam (3% moisture)



1. Corrosion tests conducted independently at hospital in Montreal over 94 day period. Maxi-Therm has corrosion rate of 2.36 mills per year compared to 14.63 mills per year using conventional methods (both using alloy C1010 black iron)

Building Heat Application

- Can control liquid outlet temp to $\pm 2^{\circ}\text{F}$ for building heat
- Building heat applications:
 - Heating water/ glycol
 - Hot oil or other heat transfer fluids
 - Wash stations
 - Emergency showers
 - Reactors, pasteurizers, jacketing
 - Booster heaters for kitchens
 - Heat recirculation water at 250°F (no bacteria)
- Can handle liquid flow between 35 and 850 usgpm (and can go above 2,000 usgpm if needed)



Hot Water From Steam Generator

Domestic Hot Water Application

- Most facilities use **over 50% of steam for hot water** production
 - Service water
 - Domestic water
 - Reheat
 - Clean steam
- Can control liquid outlet temp to $\pm 4^{\circ}\text{F}$ for **domestic hot water**
- Uses Vertically Flooded Heat Exchanger (VFHX)
- **Smaller** than conventional storage tank heaters
 - Can be wheeled through a doorway
- Smaller reservoir and higher temperatures
 - Stops growth of Legionella bacteria

Example in Practice: Vassar Hospital




Flash Steam Loss Calc							
Flash Steam (lbs)	Make-Up Water (gal)	Flash Steam Heat Loss (Btu)	Additional Heat Vaporization (Btu)	Additional Gas to Heat Cond. (Btu)	Gas Consumed (Therms)	Cond. Flow Rate (GPM)	Pump Energy (kW)
1,000,406	120,097	157,063,776	1,308,848,422	15,362,907	17,000	50,126	1,309

Flash Steam Loss Cost	
Gas Savings:	\$ 14,960
Water Savings:	\$ 432
Chemical Savings:	\$ 480
Electrical Savings:	\$ 1,309
Total Savings:	\$ 15,873

- **Eliminating flash losses** to the atmosphere **saves energy and money**
 - Less gas to reheat make-up water to usable temperature
 - Less make-up water lost to high-pressure water flashing to steam
 - Lower volume of water to chemically treat
 - Less pump energy to pull in make-up water

Effective designs have positive environmental impacts

- 705,000 SF
- 264 patient beds
- 16 ORs (~800 SF each)
- LEED 2009 Silver rating
- Fuel gas load: 90,000 CFH
- Heating density: 65 Btu/SF




Heat Exchanger (Steam-Water) Schedule								
Unit	Service	EWT (°F)	LWT (°F)	GPM	Water Side (Tube)		Steam Side (Shell)	
					PD (ft. H2O)	Min MBH	Operating Pressure	Flow Rate (lbs/h)
1	Main HVAC Heating	172	220	2,275	5	31,850	85	31,640
2	Domestic Water Heater	40	140	40	3	2,000	85	1,969
3	Non-Potable Hot Water Heater	40	140	30	2	1,500	85	1,477
4	Snow Melt	105	130	111	10	1,388	85	1,992

Steam Boiler		
Number	Operating Pressure	Pounds/ Hour
BLR-1	85	24,150
BLR-2	85	24,150
BLR-3	85	24,150

Clean Steam Generator Schedule (Steam to Steam)						
Number	Service	Source Side (HPS)		Shell Side (Clean Steam)		
		PSIG	Pounds/Hour	PSIG	Pounds/Hour	EWT
1	AHU Humidifiers	85	10832	10	8500	40

GenSet Replaces PRV

- Potential Energy savings with a closed-loop steam system
- Self-contained, skid mounted
- No external oil lubrication needed
- Generator included
- Small footprint, lightweight
- **5 : 1 turndown**
- **Small Footprint**
- **Easy annual maintenance** (bearing and seals)
- **Monitors electric grid** and generator power for safe and easy use



GenSet Diagram

Design Specs

	250 PSI to 10 PSI outlet
50 KW	(2,500lbs./hr.) Office building
100 KW	(5,000lbs./hr.) Office building or large hotel
400 KW	(5,000lbs./hr.) Small campus or a small town



GenSet Skid

Savings (\$0.10/kW)

100 kW: $100 \text{ kW} * 8,700 \text{ hrs/yr} * \$0.10/\text{kW} - \$12,000 \text{ maintenance}$
 $= \$75,000/\text{yr}$

400 kW: $400 \text{ kW} * 8,700 \text{ hrs/yr} * \$0.10/\text{kW} - \$20,000 \text{ maintenance}$
 $= \$328,000/\text{yr}$

Return on Investment (ROI)

100 kW: $\frac{\$260,000 \text{ cost} + \$104,000 \text{ installation} + \$72,800 \text{ consultants} - \$43,680 \text{ incentives}}{\$75,000 \text{ savings}} = 5.24 \text{ years}$

400 kW: $\frac{\$450,000 \text{ cost} + \$180,000 \text{ installation} + \$126,000 \text{ consultants} - \$75,600 \text{ incentives}}{\$328,000 \text{ savings}} = 2.1 \text{ years}$

Thank you



Andrew Kozak, PE, AEE Fellow
Director of Mechanical Engineering
646.205.7207
AKozak@brplusa.com

105 Madison Ave, 10th Floor
New York, NY, USA 10016
www.brplusa.com



@BRplusA



www.linkedin.com/company/brplusa



Patrick Lach

Steam Specialist | International Sales Manager
[Ca.Linkedin.com/in/ SteamSpecialist](https://Ca.Linkedin.com/in/SteamSpecialist)
Patrick@Maxi-Therm.net

7559 MB Jodoin
Montreal, Quebec, Canada
www.maxi-therm.net



www.youtube.com/channel/UCdiWSCH7m1XnjsFOYm_GstQ



www.linkedin.com/company/maxi-therm-inc-/about/