



IDEA2022

Building Connections

June 6-9 | Sheraton Centre Toronto Hotel | Toronto, ON



INTERNATIONAL
DISTRICT ENERGY
ASSOCIATION

CHP as the Backbone of an Industrial Microgrid in Toronto

Steve Quinlan, CEM Engineering

Johnathan Coleman, Solar Turbines Canada Ltd.



Solar[®] Turbines

A Caterpillar Company



THE INTERNATIONAL GROUP, INC.

- The World's only dedicated Paraffin and Microcrystalline wax producer utilizing internally sourced materials
- Founded in Toronto, Ontario in 1943
- 9 plants across North America



Dorin Marian

- Manager of Energy, Engineering and Maintenance
- Over 20 years experience working at IGI
- Internal champion of CHP project



- Thermal Power project delivery firm, founded in Niagara Region in 2001
- Designed over 44 CHP Projects, with 3 offices across Canada
- Owner's Engineer on IGI Project



Steve Quinlan

- Manager of Electrical Engineering
- 15 years experience working at CEM
- Electrical Lead and EOR of CHP Project

Solar[®] Turbines

A Caterpillar Company

- World's largest manufacturer of combustion turbines (1 to 39 MW)
- Over 16,000 units installed with over 3 billion operating hours experience
- Turbine OEM on IGI Project



John Coleman

- Senior Account Manager for Canada, NY & New England
- 35 years experience in the power industry
- Principal Engineer for Solar Canada

Problem

Why did IGI consider a Microgrid with On-site Generation?

1. Resiliency

- Impact of power interruption on process (especially wax temperature)
- Improve continuous (24/7) operation & reduce/eliminate shutdowns

2. Economics

- Reduce energy (electricity and fuel) costs
 - Reduce process losses due to unplanned shutdowns
-
- IGI experienced a local electrical utility outage and a natural gas curtailment event at the same time, resulting in a complete 'freeze-up' of the plant.

Solution

- Cogen provides both electrical and steam resiliency while also reducing operating costs.
- Combustion turbine-based CHP to supply all electric (3 MW) and thermal (90,000 lb/hr) plant loads.
- Electrical and thermal generation capacity sized to supply all plant loads in islanded (grid disconnected) mode of operation.
- The Province of Ontario provided grants (up to 40% of the eligible project costs) for high-efficiency behind-the-meter cogeneration projects that result in a reduction in electricity consumption.
- IGI visited multiple GTG sites who raved about their GTGs and how well they islanded, demonstrating the capabilities of the solution.




Case Study: International Group Inc.

- 3.5 MW Gas Turbine (Centaur 40) with dual fuel
- Rentech Heat Recovery Steam Generator with supplementary firing
- Emerson Vilter Fuel Gas Booster Compressor
- New 5 kV & 27.6 kV Electrical Switchgear
- Automatic islanding capability
- Black start capability
- Installed inside new cogen building, located within existing plant footprint




THE INTERNATIONAL GROUP, INC.


Case Study: International Group Inc.



Case Study: International Group Inc.



Project Overview



Construction: GTG & HRSG



Major equipment installation in constrained urban operating plant



Construction: Cogen Building



GSU Substation

Construction: Fuel Systems



Fuel Gas Booster Compressor (FGBC)


Diesel Tank



Electrical Substation Upgrade

- Existing load was divided between two separate utility services, with one utility-owned transformer.
- Reconfiguration and new 27.6 kV switchgear was necessary to supply full plant load and allow for islanding.
- New substation to be built within existing substation footprint, while still in service, without shutdowns (minimal interruption).
- New substation must meet new utility standards, requirements, and approval process, in addition to generation interconnection approvals.


Electrical Substation Upgrade



The site plan illustrates the layout of a substation extension. Key features include:


- Existing Equipment:** T2 27.6 kV - 600V XFMR (EXISTING) and T1 27.6 kV - 600V XFMR (EXISTING).
- Proposed Construction:** NEW FOUNDATION AND 8" SOLID BLOCK FIRE WALL TO BE CONSTRUCTED FOR T1 TRANSFORMER (10'-0" LONG x 10'-0" HIGH).
- Fencing:** GATE (EXISTING), EXISTING PAD SWITCH PDSW#1, and EXISTING 36" CABLE TRAY.
- Demolition/Removal:** DEMOLISH EXISTING SUPPORT STRUCTURE AND FOOTINGS, DEMOLISH EXISTING CHAIN LINK FENCE, and REMOVE INTERIOR FENCING.
- Other Notes:** FOR CABLE TRAY SUPPORTS THIS DRAWING, SEE PYRAMIDS DRAWING IGI-CS-238 & -CS-241, and GATE SHALL INCLUDE YOKE WITH PROVISION FOR ACCEPTING BOTH TORONTO HYDRO AND CUSTOMER LOCKS.

Electrical Reconfiguration – Phase 2




Install new transformer, cable tray, cables, conduits, temporary pole

Electrical Reconfiguration – Phase 3



Swap incoming line to temporary pole & new transformer
Remove existing transformer, overhead structure, cable, tray

Electrical Reconfiguration – Phase 4



Electrical Reconfiguration – Phase 4




IDEA 2022: CHP as the Backbone of an Industrial Microgrid in Toronto

Lessons Learned

- Project Development
- Permits/Approvals
- Design Considerations
- Commissioning
- Plant Operation



Project Development



- Proper Front End Engineering and Design (FEED) is required to properly assess CAPEX estimates.
- Although smaller projects may have less development funds available to support this, **FEED effort focused on key risk factors is critical to project success**; avoids costly oversights or underestimation of project costs.

Permits/Approvals

- Authorities Having Jurisdiction
 - Develop permitting plan early.
 - Early and continuous engagement/communication, and documentation.
 - Coordination with multiple utility departments adds complexity.
 - Thorough awareness of utility standards is essential (may change over the course of the project).
- Equipment Certification
 - Establish certification requirements early.
 - Specify factory certification wherever possible (CSA/UL labels prior to shipment) to facilitate local inspector's approval at site.



Permits/Approvals



- Noise (residential area)
 - Incumbent air and noise consultant was hired to complete Emissions Summary Dispersion Model (ESDM) for air permit and Acoustic Assessment Report (AAR) for noise permitting.
 - Silencers were installed for gas turbine ventilation, gas turbine combustion inlet and HRSG exhaust.

- Municipality – given the nature of the site in an urban area, the City of Toronto was engaged early to support permitting and avoid the requirement for public consultation.
- Noise limits and local stakeholders drove the decision to build the whole plant in a building.

Design Considerations

- Site Specific Design Considerations
 - Protect air inlets from snow, ice, rain, bugs, pollen, dust
- Built-in Provision for Resiliency Upgrades
 - Black start transfer switch with connection box for diesel generator
 - Combustion turbine with dual fuel (natural gas & diesel) capability
- Even minor design issues/challenges can cause operational issues; high temperatures in the building due to insufficient HVAC can cause GTG/HRSG trips.
- Non-interruptible gas contract for GTG to guarantee grant contract obligations are met and ensure they could always make power and heat to keep the plant 'warm' at all times.

Commissioning

- Develop commissioning plan during engineering phase.
- Plan for load bank testing to avoid impact/risk to plant loads.
- Include sufficient contingency in commissioning schedule.
 - Especially when multiple entities need to participate in witness testing.




IGI CHP Plant
Combined Heat and Power Plant

Commissioning

- Ensure synchronization devices measuring different sides of a transformer account for phase shift ($\pm 30^\circ$).
- Unpredictable synchronization voltages may indicate a ferroresonance condition; damping system may be needed to stabilize voltages consistently.
- Generator import control should be tested for expected process load changes and tuned to ensure stable response.
 - Be aware of process operations that impact load and simulate risk of reverse power tripping.
 - Avoid overly sensitive power export protection to allow for smooth, efficient response to load transients.
- Use time-synchronized event data for troubleshooting.


Plant Operation – Planned Islanding

- Localized lightning strike can impact plant equipment faster than islanding can occur, leading to shutdowns.
- Proactively islanding the plant in response to predicted weather events can mitigate risk from exposure to the grid and increase resiliency.




Plant Operation – Planned Islanding

- Utility maintenance outages (switching to alternate feeder) necessitate cogen shutdown or planned islanding:
 - 3.5-hour planned outage: decided to island; outage became 5 days
 - 2 day planned outage: decided to shut down; outage became 8 days
- Experience from these outages increased IGI's confidence in the system's reliability as well as the economic benefits of islanding.



Plant Operation – Planned Islanding

- Subsequent 3-hour planned outage was extended to 24 days.
- Proactively islanding the plant saved considerable cost and further increased confidence.
- Now the plant islands continuously, except for maintenance.



Results

- Project efficiency target achieved in accordance with grant.
- Long Term Maintenance Contract maximizes reliability, ensures continuous operation, tracks performance, and identifies issues.
- Total Run Time: >22,000 hours
- Operational Statistics for April 2021 – March 2022:

Utilization

92.7%

Reliability

100%

Availability

98.3%

Questions?



Thank You!

Steve Quinlan

Manager of Electrical Engineering
Steve@cemeng.ca

Johnathan Coleman

Senior Account Manager
Power Generation

coleman_johnathan_a@solarturbines.com



Solar[®] Turbines

A Caterpillar Company