LEADING THE WAY CampusEnergy2022

Feb. 15-18 | Westin Boston Seaport District Hotel | Boston, Mass.



CHP Operation Where Resiliency, Carbon, and Cost Intersect

Siobhan Carr Jon Sepich Michael Webster Program Manager, Energy Efficiency, Massachusetts Institute of Technology Plant Manager, Central Utilities Plant, Massachusetts Institute of Technology Founder and Chief Technical Officer, ICETEC Energy Services





Massachusetts Institute of Technology





About MIT



Located in Cambridge, MA

Student population **11,000+** (undergraduate and graduate)



- **12,000+** faculty and staff
- Spans 168 acres



LEADING THE WAY CampusEnergy2022

190 buildings and 13 million gross square feet of building space





Source: Cambridge CDD Locator Map



UNSEEN SEEN **190 buildings** 16.5 miles of district energy infrastructure 7.3M GSF academics & research 3.5M GSF residential 2.2M GSF service ISSIOI since 2014 1.8 milli of new construction since 2011 efficient cost and emissi benefits since 2010 ertified projects with all new construction and major renovation projects equired to earn LEED Gold INTERNATIONAL DISTRICT ENERGY ASSOCIATION

MIT's District Energy System

- Central Utilities Plant (CUP) serves campus electrical, heating, and cooling needs
 - Peak electrical ~38MW

LEADING THE WAY

- Peak steam load ~365 kpph
- Peak chilled water load ~26,000 tons
- Ability to export to grid when excess power produced (rarely)





MIT CUP Expansion

- Construction commenced in 2017; new plant fully operational Dec. 2021
- Replace 20+ year turbine + add second turbine:
 - Two 22-MW combustion turbines
 - Two HRSG boilers
- Additional upgrades included:
 - New condensing economizer
 - New emergency engine
 - Chilled water plant upgrades
 - Fuel transition
 - Boiler modernization









MIT's "Bridge to Future"

- Upgrades provide increased capacity and resiliency, utilizing clean energy solution
- Operation is now carbon/resiliency driven
- <u>Benefits</u>
 - Reduce regulated pollutant & GHG emissions
 - 68,000 metric tons CO₂ emissions avoided since 1995
 - 25% reduction in pollutant emissions (2014 baseline)
 - Ability to export clean power to grid
 - Eliminate operation on oil except for testing emergencies
 - Flexible system to incorporate emerging technologies









Objectives

Identify

- How long will the CUP outperform the local grid's annual GHG metrics?
- How can the CUP provide a benefit to the local grid?
- With rising utility costs, can we see both the utility savings and GHG savings?
- How is resiliency impacted if we prioritize utility costs and GHG reductions?





Operating Principles and Dispatch Priorities

Retired 20MW	Upgraded 40MW
Resiliency	Carbon Reduction
Efficiency	Resiliency
Market Economics	Efficiency
	Market Economics





High-Level Dispatch Goals

- Optimize thermal load requirements for efficiency
- Coordinate chiller plant dispatch with cogeneration operation
- Carbon optimization for the thermal and power loads
- Market participation primarily ahead of the meter
- Carbon for load to serve the campus is valued at the cogeneration carbon rate at the time
- Utility power for the campus is valued at the grid average rate at the time
- Carbon for market dispatch and export or injection is valued at the difference between cogeneration carbon rate and the marginal carbon rate at the time

LEADING THE WAY CampusEnergy2022 Feb.15-18 Westin Boston Seaport District Hotel Boston, MA



Serving Campus / Exporting to Grid



Real Operational Scenarios

- **<u>Study 1</u>**: One GT online at full load, 20MW with duct burners
- **<u>Study 2</u>**: Two GTs online at 10MW per unit with duct burners
- <u>Study 3</u>: Two GTs online at 20MW per unit with duct burners and exporting power

	Study 1	Study 2	Study 3
Carbon	**	*	***
Resiliency	*	**	***
Cost Benefits	**	*	***





Calculating Grid Carbon Intensity

ISO New England Operating Parameters:

- Evaluates demand on grid every 5 minutes
- Matches grid demand by choosing lowest cost resources available to operate
- Resources are placed into supply stacks that are called upon to operate when needed
- Stack that is "next in line" to be called upon is referred to as the *marginal resource*
- ✤ Marginal resource sets price of electricity for every 5-minute interval

Load-Weighted Average Average Grid Emission Rate Time-Weighted Average Marginal Grid Emission Rate Marginal Grid Emission Rate Annual Grid Emissions Annual average emission rates Annual average emissions rates Total MWH Consumed (Grid) from marginal units on from marginal units over a calendar year basis. Method certain time period when load *Adoption of renewables does not is assumed to be split evenly weighs marginal emission rate directly displace fossil fuel burning by *share of load* served by that amongst all operating units resources, particularly in periods marginal resource. (i.e., % of hour marginal). of higher demand.

As the grid approaches decarbonization, the methodology for evaluating the grid's carbon intensity will evolve to consider the grid's carbon health during marginal periods of operation (historically more carbon-intensive).

LEADING THE WAY CampusEnergy2022 Feb.15-18: Westin Boston Seaport District Hotel: Boston, MA



Initial Operating Data – GHG Performance







Exporting Operation - GHG Evaluation



12/14/21 – 12/15/21 Real Time Trends



LEADING THE WAY CampusEnergy2022 Feb.15-18 Westin Boston Seaport District Hotel Boston, MA

Exporting Operation - GHG Evaluation

Timestamp	HR	Total_Generation	Cogen_co2_lbs	Generated for site	Carbon for Site Load	Utility_Export MW	Carbon for Expoer	Export Net Carbon	Cogen Carbon w/Export
2021-12-14 17:00:00	17	24.00	12,441.91	24.00	12,441.91	0.00	0.00	0.00	12,441.91
2021-12-14 18:00:00	18	24.01	12,496.53	24.01	12,496.53	0.00	0.00	0.00	12,496.53
2021-12-14 19:00:00	19	24.53	12,835.06	24.53	12,434.45	0.00	400.61	400.61	12,835.06
2021-12-14 20:00:00	20	24.72	12,871.74	24.18	12,275.41	0.54	596.33	-491.88	11,783.53
2021-12-14 21:00:00	21	24.70	12,950.90	23.94	12,216.72	0.76	734.18	-597.55	11,619.18
2021-12-14 22:00:00	22	24.70	12,931.74	23.64	11,997.54	1.06	934.19	-764.71	11,232.84
2021-12-14 23:00:00	23	24.97	13,429.36	23.65	11,939.11	1.32	1,490.25	-1,244.54	10,694.57
2021-12-15 00:00:00	0	35.08	20,777.65	27.39	11,690.11	7.69	9,087.54	-7,636.07	4,054.04
2021-12-15 01:00:00	1	40.20	20,790.26	27.88	11,634.03	12.32	9,156.24	-7,688.18	3,945.85
2021-12-15 02:00:00	2	40.20	20,800.19	27.77	11,492.91	12.43	9,307.28	-7,811.09	3,681.82
2021-12-15 03:00:00	3	40.20	21,050.33	27.58	11,550.01	12.62	9,500.32	-7,760.74	3,789.27
2021-12-15 04:00:00	4	40.20	21,043.41	27.53	11,528.86	12.67	9,514.55	-7,775.04	3,753.82
2021-12-15 05:00:00	5	31.30	13,378.62	23.52	11,284.34	7.78	2,094.28	-1,721.12	9,563.23
2021-12-15 06:00:00	6	21.93	11,428.90	21.93	11,428.90	0.00	0.00	0.00	11,428.90
2021-12-15 07:00:00	7	21.69	11,725.74	21.69	11,725.74	0.00	0.00	0.00	11,725.74
2021-12-15 08:00:00	8	21.69	11,049.89	21.69	11,049.89	0.00	0.00	0.00	11,049.89
2021-12-15 09:00:00	9	22.14	11,468.89	22.14	11,468.89	0.00	0.00	0.00	11,468.89
2021-12-15 10:00:00	10	22.84	11,754.09	22.84	11,754.09	0.00	0.00	0.00	11,754.09
2021-12-15 11:00:00	11	23.36	12,051.62	23.36	12,051.62	0.00	0.00	0.00	12,051.62
2021-12-15 12:00:00	12	23.58	12,042.34	23.58	12,042.34	0.00	0.00	0.00	12,042.34
2021-12-15 13:00:00	13	23.42	11,944.92	23.42	11,944.92	0.00	0.00	0.00	11,944.92
2021-12-15 14:00:00	14	23.66	11,957.23	23.66	11,957.23	0.00	0.00	0.00	11,957.23
2021-12-15 15:00:00	15	23.59	12,028.42	23.59	12,028.42	0.00	0.00	0.00	12,028.42
2021-12-15 16:00:00	16	23.49	12,015.26	23.49	12,015.26	0.00	0.00	0.00	12,015.26
Totals		650.20	337,265.02	581.01	284,449.25	69.19	52,815.77	-43,090.29	241,358.96



12/14/21 – 12/15/21 Dispatch Example



Exporting Operation - GHG Evaluation

Total Generation	mW	650.20
Total Carbon For Generation	Lbs	337,265.02
Generated for Site	mW	581.01
Cogeneration Carbon For Site	Lbs	284,449.25
Export Power	mW	69.19
Cogeneration Carbon For Export	Lbs	52,815.77
Net Export Cargon	Lbs	-43,090.29
Site Plus Export Carbon	Lbs	241,358.96

Net Export Carbon is equal to Cogeneration Carbon for Export minus Export Power times marginal rate

LEADING THE WAY CampusEnergy2022 Feb.15-18 Westin Boston Seaport District Hotel Boston, MA 12/14/21 – 12/15/21 Dispatch Example



ISO NE Grid Emissions Projections



TODAY CUP ~457 lbs CO2/MWH Grid ~600 lbs CO2/MWH

Avg ISONE Grid Grid ↔ CUP ~2030

Time-Weighted <u>Methodology</u> Grid \leftrightarrow CUP \sim 2030+

Load-Weighted <u>Methodology</u>

Grid \leftrightarrow CUP ~2034+

Avg MA Grid Grid ↔ CUP ~2040+



Looking to the Future: Additional Considerations

- How will climate change events affect the plant's resiliency/contingency for the campus?
- How do the conversations regarding electrification affect the plant's operation?
- How can we begin to think about incorporating MIT-based gateway technologies (MIT Research – Micro Turbine, Magnetic Fusion Reactors...)?

LEADING THE WAY CampusEnergy2022 Feb.15-18 Westin Boston Seaport District Hotel Boston, MA



High-Level Conclusions

- Based on current understanding and assuming a 3% reduction per year, we anticipate that the CUP will outperform the grid's average emissions for the next 7-8 years. However, there are a lot of factors, and we will have to monitor the situation yearly.
- During peak demand times, the CUP can help offset the marginal unit, which is typically more GHG-intensive.
- Currently, the market costs and GHG values are aligned.
- If done appropriately, we can optimize costs and GHG without compromising resiliency for the campus.

LEADING THE WAY CampusEnergy2022 Feb.15-18 Westin Boston Seaport District Hotel Boston, MA



Questions?

LEADING THE WAY CampusEnergy2022 Feb.15-18 Westin Boston Scaport District Hotel Boston, MA





