



# District Energy Performance and Savings

## Approaches to Maximize End Use Performance

Kevin Fox, PE, CEM | Jacobs Engineering Group Inc.

**JACOBS**<sup>®</sup>

# Context

District energy is usually the ideal solution for serving thermal and electrical loads in dense environments

District Energy projects are highly scrutinized, and must demonstrate multiple facets of performance for approval

**Opportunities for dropping 15 to 25% (or more) of the energy usage in a system likely exist right now!**


# The Challenge

**Division** in ownership

**Delegation** of responsibility

Air Side **vs.** Plant side

Blissful **ignorance**



# The **Opportunity**

**Leadership** in holistic performance

**Demonstration** of sustainability

**Extend** useful capacity of infrastructure

**Maximize** carbon reduction

**Reduce** deferred maintenance

Let district energy be the **HERO**




# Start Somewhere

Campus/portfolio level  
energy strategy

Building level energy audits

System retro-commissioning

Evaluate maintenance  
program



# Campus Level **Energy Strategy**

Strategic Energy Plan

Energy Usage Intensity (EUI)

Peer Benchmarking

“

**If you don't know where  
you're going, you'll end  
up someplace else.**

”

# Scenario Analysis Tool

## Robust multi-level calculations



Complex variables – (direct / indirect)

Efficient input variables

- Slider bars, buttons, typed inputs, validation




Intuitive outputs – (quantitative / qualitative)

- Meaningful graphs, tables, concise dashboard gauges



# Scenario Analysis Tool

Too much automation can conceal insight...




# Strategic Energy Plan

## Campus Approach

- 2030 Target
- 1990 Energy Usage
- 36% SF Growth

Stage	Year	Floor Area Added per Phase(sf)	Campus Floor Area (sf)	Total Combined Annual Consumption (kBtu/yr)	% Site Energy Change	Site EUI (kBtu/sf/yr)	% EUI Change
Baseline	2009/10	-	3,948,096	271,404,067	-	68.7	-
Phase 1	2014/15	1,114,200	5,062,296	305,993,170	12.74%	60.4	-12.07%
Phase 2	2019/20	285,200	5,347,496	278,861,412	-8.87%	52.1	-13.73%
Phase 3	2024/25	539,000	5,886,496	258,126,031	-7.44%	43.9	-15.91%
Phase 4	2029/30	330,000	6,216,496	221,015,363	-14.38%	35.6	-18.92%




# Benchmarking

## Energy Usage Intensity (EUI)

*Energy*  

---

*Square Foot*



Broad Category	Primary Function	Further Breakdown (where needed)	Source EUI (kBtu/ft <sup>2</sup> )	Site EUI (kBtu/ft <sup>2</sup> )	Reference Data Source - Peer Group Comparison
Healthcare	Ambulatory Surgical Center		138.3	62.0	CBECS - Outpatient Healthcare
	Hospital	Hospital (General Medical & Surgical)*	426.9	234.3	Industry Survey
		Other/Specialty Hospital	433.9	206.7	CBECS - Inpatient Healthcare
	Medical Office*		121.7	51.2	CBECS - Medical Office
	Outpatient Rehabilitation/Physical Therapy		138.3	62.0	CBECS - Outpatient Healthcare
	Residential Care Facility		213.2	99.0	Industry Survey
	Senior Care Community*		213.2	99.0	Industry Survey
Urgent Care/Clinic/Other Outpatient		145.8	64.5	CBECS - Clinic/Outpatient	
Lodging/Residential	Barracks*		107.5	57.9	CBECS - Dormitory
	Hotel*		146.7	63.0	CBECS - Hotel & Motel/Inn
	Multifamily Housing*		118.1	59.6	Fannie Mae Industry Survey
	Prison/Incarceration		156.4	69.9	CBECS - Public Order and Safety
	Residence Hall/Dormitory*		107.5	57.9	CBECS - Dormitory
	Residential Care Facility		213.2	99.0	Industry Survey
	Senior Care Community*		213.2	99.0	Industry Survey
	Single Family Home		N/A	N/A	None Available
	Other - Lodging/Residential		143.6	63.6	CBECS - Lodging
Manufacturing/Industrial	Manufacturing/Industrial Plant		N/A	N/A	None Available
Mixed Use	Mixed Use Property		89.3	40.1	CBECS - Other
Office	Medical Office*		121.7	51.2	CBECS - Medical Office
	Office*		116.4	52.9	CBECS - Office & Bank/Financial
	Veterinary Office		145.8	64.5	CBECS - Clinic/Outpatient
Parking	Parking		N/A	N/A	None Available

# Goal Setting

Energy efficiency offers the **most affordable opportunity** to reduce carbon footprint

Buildings often have **waste designed-in** – a lot!

Entrenched culture of overdesign and **tolerated energy waste**, defended as “margin of safety” and “best practice”

Concept of **“smart” buildings often oversold**, underdeveloped


**AIM HIGH TO GO LOW!**

# Attitude Drives Results

## UC Example – 50% Reduction Goal

Facility Type	Goal	Realized
Laboratories	50%	61%
Classrooms/Offices	50%	50%
Housing	40%	23%
Lighting	50%	60%
Parking	50%	79%

# Attitude Drives Results



# Attitude Drives Results

60% of efficiency opportunities were in **buildings**

**Challenge** all accepted design practices

Use software and sensors to make systems “**smart**”

Whole-building retrofits enable **savings >50%**

**Digital-savvy tradespeople** essential to keep smart buildings smart

**Beliefs and attitudes** are as important to success as technology, financing, and management

# Building Energy Audits

## ASHRAE Level 1 Audit


- High-level audit to identify potential energy conservation measures

## ASHRAE Level 2 Audit

- Detailed investigation of all energy consuming systems and operations
- Spreadsheet based calculations along with probable cost estimates

## ASHRAE Level 3 Audit



- ECMs developed in detail for accurate cost estimating
- Detailed, hourly based, computer modeling to determine savings



# Building Energy Audits

## Develop list of potential ECMs

- Issues log with recommendations and priority
- Develop description, cost, estimated annual savings and ROI
- Bundle ECM opportunities



# Building **Energy Audits**

## NAVFAC example

- 10 weeks, 60 auditors
- Average payback 2.7 years

Facility	SF Audited	# Buildings	# ECMs	# Bundles	Total Project
Hill AFB, UT	5.5M	234	670	154	\$ 12,553,137
Wright Pat. OH	7.5M	101	625	146	\$ 75,623,108
Whiteman, MO	1.2M	27	123	62	\$ 11,251,017
<b><u>TOTALS</u></b>	<b><u>14.2M</u></b>	<b><u>362</u></b>	<b><u>1,418</u></b>	<b><u>362</u></b>	<b><u>\$ 99,427,262</u></b>

# Building **Retro-Commissioning**

## **Purpose and Benefits**

- Address problems never identified during initial building start-up
- Resolve systemic problems in building operation
- Address environmental deficiencies
- Correct excessive equipment run times due to changes in occupancy or use
- Identify and correct malfunctioning equipment or sensors
- Implement control optimization issues
- Extend equipment life
- Improve operations

# RCx **Focus Areas**

Temperature and humidity sensors out of calibration

BAS programming vs. actual operation

Simultaneous heating and cooling

Correct and efficient air damper sequencing

Chilled water bypasses and leaks

Corroded condenser coils

Incorrect head pressure control and hot gas bypass connections


Poor equipment access (maintenance)

Equipment not responding to control system

Control sequence not operating correctly

Incorrect cooling load calculations

# RCx Process



# RCx Process



Investigation

Diagnostic monitoring

Functional testing

Energy analysis

Implementation




```
MZII: 01:005  DEVICE: AH1  APPL: MZ-5AH-1
```

INPUTS:			
1	AH1SFFLO	ON	<input type="checkbox"/>
2	AH1EFFLO	ON	<input type="checkbox"/>
3	AH1.SAT	83.2 DEG F	<input type="checkbox"/>
4	AH1.RAT	71.0 DEG F	<input type="checkbox"/>
5	AH1.MAT	54.9 DEG F	<input type="checkbox"/>
6	AH1.EAT	58.6 DEG F	<input type="checkbox"/>
7	AH1.SMK	OFF	<input type="checkbox"/>
8	---	---	<input type="checkbox"/>

INPUT RANGE: 0.0, 100.0

ANALOG OUTPUTS:			
1	AH1_MAD	24.0%	<input type="checkbox"/>
2	AH1_FBD	100.0%	<input type="checkbox"/>
3	AH1_EAD	24.0%	<input type="checkbox"/>
4	AH1_VLV	100.0%	<input type="checkbox"/>

DIGITAL OUTPUTS:					
1	AH1SF_SS	ON	<input type="checkbox"/>	5	---
2	AH1EF_SS	ON	<input type="checkbox"/>	6	---
3	---	---	---	7	---
4	---	---	---	8	---



# RCx **Lessons Learned**

**Inadequate** building documentation

**Poor access** to BAS data

**Systems** “never ran right from day one”

Zone level **adjustments made** but never tracked

Changes made during **construction**

**“Improving performance”** may not always reduce energy consumption

# RCx **Results**

**Our experience: average 15% to 25% savings in energy; can be higher**

**LBNL study of 643 buildings: over 10,000 energy-related problems, resulting in 16% median whole-building energy savings, with payback of 1.1 years**

**LBNL: High-Tech building - saved \$127,800 Hospital: saved \$6,700 – simple payback of 1 year**

**LBNL: Office - saved \$90,900 with immediate payback**

# Capitalize on the **Opportunity**

- ✓ **Develop an energy strategy**
- ✓ **Benchmark**
- ✓ **Goal + mind setting**
- ✓ **Building energy audits**
- ✓ **Building retro-commissioning**

**JACOBS<sup>®</sup>**

**Kevin Fox, PE, CEM**

**Booth #65**

