



CampusEnergy2021

BRIDGE TO THE FUTURE

Feb. 16-18 | CONNECTING VIRTUALLY

WORKSHOPS | Thermal Distribution: March 2 | Microgrid: March 16

Smith College's Life with Our Combined Heat and Power Plant

Stephen H. Slocomb, PE, Principal, Epsilon Associates, Inc.



CampusEnergy2021
BRIDGE TO THE FUTURE
Feb. 16-18 | CONNECTING VIRTUALLY
WORKSHOPS | Thermal Distribution: March 2 | Microgrid: March 16




Smith College



Q&A Will Not Be Answered Live

**Please submit questions in the Q&A box.
The presenters will respond to questions off-line.**



Smith College's Energy Needs

- Smith College
 - Private Liberal Arts college located in Northampton MA
 - Total enrollment of 2,400 women
 - Aging Physical Plant that provided steam, hot water and cooling (via steam)
 - Three smaller boilers that were 1950s vintage
 - Two larger boilers that were installed in early 1970s

Smith College's Energy Needs



- Smith Physical Plant
 - Boilers 1-3: 50.4 MMBtu/hr firing No. 6 oil only
 - ~15,000 lb/hr of steam at 125 psi
 - NOx 0.37 lb/MMBtu PM 0.13 lb/MMBtu
 - SO₂ 0.5-2.2%S VOC 0.02 lb/MMBtu
 - Boiler 4-5: 68.1 MMBtu/hr firing natural gas and No. 6 as backup (when natural gas interrupted – allowed for interruptible contract)
 - 20,000 lb/hr of steam at 125 psi
 - | | | |
|-------------------|-----------------|-----------------------|
| • Fuel | Gas | Oil |
| • NOx | 0.1 lb/MMBtu | 0.37 lb/MMBtu |
| • SO ₂ | 0.0006 lb/MMBtu | 0.5-2.2%S when on oil |
| • PM | 0.014 lb/MMBtu | 0.13 lb/MMBtu |
| • VOC | 0.003 lb/MMBtu | 0.02 lb/MMBtu |
 - Cooling provided by separate facility using steam-driven and electrical chillers providing 2,500 tons of chilling
 - Multiple water heaters scattered around campus providing hot water during summer and shoulder seasons
 - Dozens of emergency generators located around campus



Smith College's Permitting Status

- Permitting Situation
 - Both Restricted Emissions Status Approval and an Operating Permit
 - RES for NOx
 - major for SO2 since it was firing 2.2%S fuel oil as one of the fuels
- Permitting Situation
 - Both Restricted Emissions Status Approval (RES) and an Operating Permit
 - RES for NOx to avoid Reasonably Available Control Technology
 - Major for SO2 since it was firing 0.5-2.2%S fuel oil as their backup fuel
 - Fuel sulfur content had been reduced in order to comply with PM limits

Smith College's Emissions and Fuel Inputs/Outputs

- Typical Emissions
 - NOx 40 tpy
 - SO2 160 tpy
 - PM 14 tpy
 - VOC 0.3 tpy
 - CO2 21,000 tpy
- Typical Inputs/Output
 - No. 6 oil averaged 83% of fuel input, ranging from 60-98%
 - Needed to balance natural gas and No. 6 oil to maintain NOx emission limits
 - 65,000 lb/hr of steam output to the campus demand



Smith College's Energy Needs





Figure 2: Existing Campus Thermal Energy & Electricity Demand (MWh)



CampusEnergy2021
BRIDGE TO THE FUTURE
Feb. 16-18 | CONNECTING VIRTUALLY
WORKSHOPS | Thermal Distribution: March 2 | Microgrid: March 16



Smith College's New Cogen System



- In 2008, Smith modified its Physical Plant as follows:
 - Gas turbine capable of producing 3.5 MW of electricity and 20,000 lbs/hr of steam
 - 46.9 MMBtu/hr heat input
 - Capable of firing natural gas and No. 2 fuel oil (not installed yet)
 - Operates using Selective Catalytic Reduction (SCR) and an Oxidation Catalyst to reduce emissions
 - New Boiler 3 added, designed to produce 65,000 lb/hr of steam
 - 79 MMBtu/hr heat input
 - Equipped with dry low NOx burners reducing overall emissions
 - Capable of operating on natural gas, No. 6 fuel oil and “yellow grease”
 - Only achieved 50,000 lb/hr in actual operation
 - Old Boilers 1-3 removed
- Overall cost of the project was \$11.5 million



Permitting the New Cogen System


- Gas turbine approved using MassDEP's Environmental Results Program
 - Applicable for Non-Emergency Turbines greater than 50 kW
 - No air permit needed provided it meets all design criteria
 - Need to meet specific emission limits
 - Fuel Gas ULSD
 - NOx 0.14 0.34 lb/MW-hr
 - CO 0.09 0.18 lb/MW-hr
 - CO2 1,650 1,650 lb/MW-hr
 - NH3 2 ppm @ 15% O2
 - Detailed stack and sound level requirements
 - Air quality modeling analysis
- Also required a 750-kW emergency generator for black start capability
 - Approved using the ERP certification process for emergency engines
 - Tier 2 Non-Road engine certification
 - Stack design and operational limitations



Permitting the New Boiler

- Boiler approved using MassDEP's Air Plan Approval Application
 - For boilers greater than 40 MMBtu/hr
 - Requires top-down Best Available Control Technology (BACT) Analysis determining whether more stringent emission limits were cost-effective
 - SCR, ultra-low NOx burners (with enhanced flue gas recirculation (FGR)) and an oxidation catalyst were evaluated and determined to be not cost effective
 - The Project substantially reduced SO2 emissions capacity

Smith College's Electrical Consumption



CampusEnergy2021
BRIDGE TO THE FUTURE
Feb. 16-18 | CONNECTING VIRTUALLY
WORKSHOPS | Thermal Distribution: March 2 | Microgrid: March 16



Smith College's Energy Needs

- Turbine has had a high availability since installed
- Although Campus electrical demand did not increase significantly, the Cogen substantially displaced the quantity of electricity purchased from the grid
- Furthermore, in 2014, Smith began to sell some of its generated power to the grid
 - Smith receives the standard LMP pricing, which can add up to \$25,000 each month
- Smith's cost to generate power is \$0.04/kW-hr while its average cost to buy power from the grid is \$0.14/kW-hr
- The daily average amount of power generated throughout 2020 was 2 MW from Oct-Apr, 1.1 MW year-round.

Smith College's Emissions Reductions

- Overall emissions reductions for the Physical Plant are as follows:

Year	NOx	SO2	PM	VOC	CO2
2001	40.00	160	14	0.3	21,000
2019	5.27	0.08	2.81	0.9	18,929
Reduction	34.73	159.92	11.19	-0.6	2,071
%	87%	99.9%	80%	-200%	10%

- Reductions are substantial are from switching to natural gas, pollutions controls, and unit efficiencies
- NOx and SO2 had the largest reductions
- Campus became a minor source, reducing overall emissions fees and compliance requirements



Smith College's Economic Benefits

- Receives Alternative Energy Credit since Massachusetts was encouraging CHP facilities
 - Up until last year, these payments were averaging \$100,000 per quarter
 - Does not operate in the summer due to lack of electrical demand
 - Last year, due to large expansion of renewables, export payments have been reduced by 20-25%

Smith College's O&M Costs

- Smith is in a Full-Service Contract with Solar
 - Based on the turbine output
 - Currently at \$225,000 per year providing:
 - 100% parts coverage
 - 100% labor coverage
 - Diagnostics with unlimited services calls
 - Provides a new engine every 50,000 hours
 - In last 10 years, Smith has not paid a dime outside of its contract

Conclusions

- This project has been great for Smith
- The CHP has provided a huge amount economic benefit by:
 - Switching fuel costs
 - Self-generating electricity at a fraction of the cost
 - Selling power to the grid
 - Provided Alternative Energy Credits
- The CHP has reduced emissions dramatically
- The Project replaced the oldest campus boilers, providing alternative fuel options
 - Natural gas in lieu of No. 6 oil
 - Option of yellow grease