

# *LEADING THE WAY* **CampusEnergy**2022

Feb. 15-18 | Westin Boston Seaport District Hotel | Boston, Mass.



INTERNATIONAL  
DISTRICT ENERGY  
ASSOCIATION

# Absorption Chillers in District Cooling Plants

Amit Vatsa, BROAD USA INC.



# District Cooling Plants

- District Cooling Plants mostly have Cogen to meet Electricity, Cooling and Heating demands of their clientele.
- Cogen offers great economics with electricity cost lower than utility and as a by product provides steam too.
- Heating BTUs are provided directly by steam
- Cooling BTUs can be generated from steam in different ways:
  - Single Effect Steam Absorbers [if there is a combined cycle plant]
  - Double Effect Steam Absorbers [in case of Cogen with L.P/H.P HRSG]
  - Steam Turbine driven Centrifugal chillers [in case of Cogen with H.P HRSG]

*[HRSG: Heat Recovery Steam Generator, L.P: low pressure, H.P: high pressure]*

# 1. Single Stage Absorption Chillers in Dis. Cooling Plant



- Combined Cycle Power Plant (condensing turbine)






## 2. Two Stage Absorption Chillers in Dis. Cooling Plant

- Cogen with L.P HRSG



# 3. Turbine Centrifugal in Dis. Cooling Plants

- Cogen with H.P HRSG



# We focus today on the 3<sup>rd</sup> option:


District cooling Cogen plant with Steam Turbine driven Centrifugal:

- Demands steam to run the centrifugal compressor: **250 psi/ ~9 lbs./hr/ton**
- Delivers low chilled water to the loop: **40F**
- Saves Electricity: **560kw/1000 tons**
- Reduces Co2 emissions: **900lbs/mWh saved**
- Turbine's backpressure steam **is condensed** for HRSG' optimum efficiency

This steam energy could be used to drive a Single Stage Absorber!

# Case Study: Santa Ana (OC) CUF, California

Pictures Courtesy: OC website



- Central Utility Facility (CUF) is owned & operated by Orange county since 1968 in Santa Ana.
- Distributes electricity, steam and chilled water 24x7 to various government office buildings in the sprawled Civic Center area.
- Serves 215 facilities comprising 9 mill. sq. ft area including County Courts and Jails vide several miles of underground piping network.
- On-site electricity and high-pressure steam generations from 2x 5.2 MW COGEN and imports grid electricity too. *Total Steam: 128,000 lbs./hr at 265 psi.*
- Maintains its peak grid electricity demand using thermal heat source driven cooling technology.
- Peak Cooling Load is around 10,000 Tons.



# Energy Savings: District Cooling Plant's priority

- Cooling Load: 10,000 Tons
- Installed: Steam Turbine Centrifugal @ 2500 Tons x 3 *[on Cogen steam]*

## Options for adding balance 2500 tons

- 2500 Tons Turbine Centrifugal: 22,500 lbs./hr. extra steam at 150 psi  
**[HRSG In-duct firing required; extra gas cost]**  
**[Condenser cooling will require extra water]**
- 2500 Tons Electric Centrifugal: 1.4 mWh extra grid connection  
**[Electricity infra update; extra investment]**
- 1250 Tons x 2 Single Stage Steam Absorption chillers


# Target and Challenges

## Target



Add 2500 Tons

## Challenges



Avoid extra grid connection

Avoid in-duct gas burning

Justify any extra water usage

## A tall, illuminated cable-stayed bridge at night, with its lights reflecting in the water below. The bridge features a central pylon with a red light at the top, and numerous stay cables fanning out to the deck. The scene is captured in a vertical orientation, emphasizing the height of the structure.



## A tall, illuminated cable-stayed bridge at night, with its lights reflecting in the water below. The bridge features a central pylon and numerous stay cables, all brightly lit against the dark sky. The reflection of the bridge is clearly visible in the calm water in the foreground.

LEADING THE WAY  
**CampusEnergy2022**  
Feb.15-18 | Westin Boston Seaport District Hotel | Boston, MA





# Result

- **Electricity savings:** 4.2 gWh /year by each Steam Absorber
- **Co2 emission reduction:** 1831 Metric Ton / year\* per set
- **Water savings:** Condenser cooling of steam avoided. Tower make-up water justified with extra cooling addition
- **Gas savings:** Auxiliary gas firing avoided as extra steam not required

*\*436gm Co2/kWh emitted by Gas Turbine with HRSG/COGEN. Citation: iopscience.iop.org;*

***Project Owners and Engineers:** Jacobs were the MEP Engineers of the CUF Upgradation Project. West Coast Air Conditioning were the GCC & Mechanical Contractors. Project is owned and funded by Orange County.*

# Questions?

Thank You !

Amit Vatsa

