

Innovation During the First 25 Years!

- In the early 1990's Temple's Energy Team knew they wanted to take full advantage of newly created interruptible electric rates
- Engineering calculations showed an immediate reduction of about 50% (\$3million/year) in electric bills were achievable
- Analysis showed a new generator plant would pay off in about 4 years
- Largely uncharted territory, but decisive action was taken!

Innovation During the First 25 Years! (Cont...)


- Temple started-up its \$16million Standby Electric Generating Facility (SEGF) in 1993, to form its first 16MW microgrid
- Facility has saved Temple about \$67million in electricity costs since 1993 against the pre-construction predictions of approximately \$75million over the same 25 years
- The following slides go into more detail about how this was achieved, changes along the way, and lessons learned

Introduction to Temple University

- Temple operates two large campuses in economically challenged North Philadelphia (plus several satellites both US and international)
 - Main Campus 78 bldgs., 8,561,032 GSF
 - Health Sciences Campus 2 miles north of Main, 30 bldgs. 3,844,221 GSF (including hospital)
- Total undergraduate enrollment of 29,550 students
- State-related university receiving some portion of funding from Commonwealth of Pennsylvania
- Continued growth in all areas

Growth in Square Footage

MAIN CAMPUS GROWTH




Note: non-linear scale!

Temple – Part of Main Campus Nestled in the Neighborhoods of North Philly



**Temple's
Position
Relative to
Center City
Philadelphia –
about 2 miles
north of City
Hall, short trip
to the
Constitution
Center and
Liberty Bell.**



Introduction

- This microgrid predates my time at Temple by over 22 years and is a testament to long-range planning
- Why is it a microgrid (and not just an emergency generator)?
 - It can black start and can operate in island mode
 - It can carry much of the electric load of Main Campus, not just life safety equipment
 - Connects to approximately 47 large educational, research and dormitory buildings 6.3million gross square feet (and their support infrastructure such as boiler and chiller plants)
 - Some large loads are covered using emergency generators

Why Was It Needed?

- Up to deregulation in the 1990s Philadelphia's HT electric tariffs carried massive penalties for summer peak kW
- Temple used mostly steam absorption chillers to avoid the kW charges
- One (1) additional kW on a summer day (or night) could cost \$124 over the following year due to:
 - Demand ratchets
 - Declining kWh block structure based on the peak (ratcheted) kW



Why Was It Needed? (cont...)

- Pennsylvania's industrials had been hurting badly for decades under this tariff
- Partial relief came with the Large Interruptible Load Rider ("LILR") which created an interruptible electric service
- Kurt Bresser (Temple's previous Energy Manager and now Temple's Director of Utilities and Energy Management) helped hatch "The Solution"
- Used LILR to take advantage of interruptible electric rates!



What Was Built?

- Conceived at the outset to allow Main Campus operations to continue in the event of a PECO “LILR” interruptible electric event
- A 16 MW natural-gas fired generator plant – twenty 16-cylinder recip engines paired up through common crankshafts driving 10 x 1600 kW electric generators
- Campus peak at the time was 12 MW – room to grow
- No heat recovery – designed only to operate as a standby electric generating facility. Today, 25 years on, there are less than 2500 hours of runtime on each engine.




Generator Plant Control Room

(Construction picture taken in 1993)



TEMPLE
UNIVERSITY®

Generator Plant – Tandem Engines and End-Mount 1600kW Generator



(Construction picture taken in 1993)



TEMPE
UNIVERSITY®

What Was Built? (cont...)

- Cost of implementation was initially projected at about \$12million in 1990 but changes in scope made actual cost around \$16million with operation commencing in June 1993
- Electric cost savings were projected to be about \$3million/year using interruptible LILR rate rider
- Bonds were issued for this and other major projects



What Was Built? (cont...)

- Net present value in 1993 dollars of 25-years savings stream \$33,880,705 using bond coupon rate of 7.25% as discount rate
- Add back in initial investment of \$16,000,000
- Yields net present value of plant after investment of \$17,880,705 in 1993 dollars
 - Numbers are somewhat simplified
 - Maintenance, financing, and fuel costs are called out where pertinent
 - Demand response payments are not included



Original 1990 Analysis – Engineering Numbers

These numbers
exclude operating
costs but fuel and
maintenance costs
have been low
compared to savings

MAIN CAMPUS ELECTRIC: HT vs. NIGHT RIDER (Major account # 024-12-94-160015)

FY	HT (Base Rates)	Night Rider (Base Rates)	Cost Avoidance
90/91	\$5,745,812	\$2,706,800	\$3,039,012
91/92	\$5,934,124	\$2,485,433	\$3,448,691
92/93	\$5,816,297	\$2,572,031	\$3,244,266
93/94	\$5,652,511	\$2,622,361	\$3,030,150

Night Rider average annual cost avoidance = 55 %

Part of Original 1990 Analysis – Bonding Projection

=====		TRANSFER	
WITH		FUND ADDITIONS	
30 YEARS			
OF			
NIGHTRIDER			
=====		-----	
		TRNSF OF	
		GENERATOR	
		COST	
		SAVINGS	

BALANCE 7/31/91			
06/30/92	1	0	
06/30/93	2	2,427	
06/30/94	3	2,521	
06/30/95	4	2,619	
06/30/96	5	2,721	
06/30/97	6	2,827	
06/30/98	7	2,937	
06/30/99	8	3,051	
06/30/2000	9	3,169	
06/30/2001	10	3,292	
06/30/2002	11	3,420	
06/30/2003	12	3,553	
06/30/2004	13	3,691	
06/30/2005	14	3,834	
06/30/2006	15	3,982	
06/30/2007	16	4,137	
06/30/2008	17	4,297	
06/30/2009	18	4,463	
06/30/2010	19	4,636	
06/30/2011	20	4,815	
06/30/2012	21	5,002	
06/30/2013	22	5,195	
06/30/2014	23	5,396	
06/30/2015	24	5,604	
06/30/2016	25	5,821	
06/30/2017	26	6,046	
06/30/2018	27	6,279	
06/30/2019	28	6,521	
06/30/2020	29	6,772	
07/01/2021	30	7,033	
		126,063	

Note that these estimates included 4% electricity inflation and therefore escalated rapidly towards the end




Entering the Deregulated Era

- In 1997 small steps were taken to deregulate PA's electric market, starting with residential service
- By 2009 Temple and most large commercial and industrial users were buying commodity from third party suppliers
- But high demand charges at the local Electric Distribution Company (EDC) level (PECO) were largely swapped for capacity charges at the Regional Transmission Organization (RTO) level (PJM in Temple's case)
- Capacity has to be paid for one way or another



PJM Zonal Capacity Rate (\$/MW-Year) (The 2020-2022 rates are subject to change)



The Deregulated Era (Cont...)

- The plant also earns substantial demand response payments simply for being available at short notice
- The deregulated era created or expanded new markets which were not previously available to end-users like Temple



Innovative Aspects

- In the 1990s most engineers (including me!) were evaluating and recommending CHP (combined heat and power) systems
- Temple bucked the trend, the team noted that the LILR interruptible rates would yield excellent savings with far less runtime!
- Less runtime meant less sensitivity to fuel prices
- Maintenance is easier to schedule because air permits are only for 500 hours/yr, leaves 8260 hours/yr for maintenance

Innovative Aspects (Cont...)

- Currently, after 26 years the engine run-hour meters show about 2500 hours, or about 100 hours/year on average
- A CHP of similar vintage would be registering over 200,000 hours by now
- The penalties for under-performance or non-performance are significant for either a CHP plant or Temple's SEGF

Innovative Aspects (Cont...)


- In summary, the novel aspects, especially in 1992, were:
 - Creating a quiet plant suitable for a residential neighborhood
 - A high electrical output per dollar of investment
 - Flexible operating modes
 - Black start capabilities
 - Operate islanded from utility or in parallel with utility
 - No heat recovery due to limited hours of operation
 - All fueled on natural gas

Results

- The Temple Standby Electrical Generating Facility provides Societal Good
- The plant competes directly in the PJM markets
- Its continued operation helps avoid “gold-plating” of the grid by providing redundancy
- Its operation potentially displaces electric generated by other dirtier fuels including diesel (the Temple plant operates on natural gas)

Results – View of Typical “Red Days” w/Generators

Energy Profiling 08/27/2018 - 08/30/2018



Viewing data as 1 Hour Interval ☐ Weekend


☒ Energy Profiling: Temple University
— Electricity Electricity Demand (kW)

Max: 24,896.16 Aug 29, 2018 1:00PM
Min: 2,401.92 Aug 27, 2018 6:00PM
Avg: 18,056.04
Load Factor: 0.73


Results (cont...)

- The contrast between Temple's Health Sciences Campus/Hospital and Main Campus only 2 miles apart and in the same PJM zone is telling
- Health Campus has no generator plant (designed but never built)
- Both campuses have similar daily peaks until "Red Days"
- Peak Load Contributions (PLCs) for 2018/2019
 - Health Campus = 17,672 kW
 - Main Campus = 1,923 kW


Cumulative Actual vs Predicted Savings with Generator Plant




Expected vs Actual Savings with Generator Plant



Comparison of Spend w/o Gen Plant and w/Gen Plant



Actual Electric Expenditure vs Main Campus Gross Square Footage



What Have We Learned?

- The uncertainties and changes to tariffs over the years demonstrate that flexibility is key
- It was far from certain that the interruptible electric rate rider would persist. Deregulation was on the horizon but its format was unknown
- When deregulation did arrive electric prices were driven down, capping the available universe of savings for a standby plant like Temple's (but Temple's plant had already paid for itself at that point)

What Have We Learned? (Cont...)

- Electric deregulation opened new markets. Temple's microgrid infrastructure allows us to participate in multiple RTO and EDC programs and markets including:
 - Peak Load Contribution (PLC) limits (our favorite, no revenue sharing!)
 - PJM Synchronous Reserves (short notice, short duration, lucrative)
 - PJM Emergency Load Response
 - PJM Economic Program (becoming ever more restrictive)
 - PECO Act 129 Demand Response at local level

**Presentation is available by email.
Scan the QR Code or email me at
andrew.holden@temple.edu**



Acknowledgement and thanks to:

- IDEA for this forum
- Kurt Bresser, Temple's Director of Utilities and Energy Management for the historic data and insight
- Joe Monahan, Temple's Associate Vice President, Facilities and Operations for valuable feedback and edits