



Incremental Expansion yields Incremental Efficiency for UMass Medical School

February 19, 2014

Darrell R. Sandlin

Nexant Clean Energy Markets

Director, Engineering Services

Joseph Collins

UMass Medical School

Director, Energy Resources


Evolution in the Central Energy Plant UMMS

- **1972 - Initial Cogeneration plant**
 - Campus - 1.6 million ft² (School + Hospital)
 - Steam 70kpqh, CW 5k tons, Electric 5MW
 - Plant Efficiency (no extraction) – 32%
 - Plant Efficiency (with extraction) – 38%

- **2000 - Plant / Campus Expansion**
 - Campus - 2.5 million ft²
 - Steam 95kpqh, CW 7k tons, Electric 7.5MW
 - First Environmental Reduction
 - Plant Efficiency 51%


- **2010 - Plant / Campus Expansion**
 - Campus – 3.3 million ft²
 - Steam 170kpqh, CW 12.7k tons, Electric 12MW
 - Accelerated Environmental Reduction
 - Maximize Financial Incentives
 - Plant Efficiency ~ 66%

1972 - Central Energy Plant UMMS




1972 - Central Energy Plant UMMS


#50 Extraction Added



1999 - Central Energy Plant UMMS



2000 - Central Energy Plant UMMS




UMMS Goals - 2010 Expansion – Central Plant

- **Prepare future campus energy needs**
- **Maintain N+1 Redundancy for each energy loads**
- **Create controls using BAT with ease of use**
- **Diversified steam mix / chilled water production**
- **Reduce Environmental impact (Nox, CO2, etc.)**
- **Reduce unit cost of energy input**


2010 Equipment Selection

- **7.5 MW Combustion Turbine**
 - Natural Gas + #2 Oil back up
- **60 KPPH / 1100 psig HRSG**
 - Duct-Fired on natural gas
 - SCR Emissions Control
- **4K Ton VFD Industrial Electric Chiller**

2012 - Central Energy Plant UMMS




2014 - Central Energy Plant UMMS



Incentive Opportunity – Massachusetts

■ **Electric Utility Install Rebates**

- Minimal load data = to \$750 /kW
- ASHRAE Level 1 audit = to \$950 /kW
- ASHRAE Level 2 audit = to \$1100 /kW



■ **Mass DOER Efficiency Certificates ~ 21\$/credit**

- AEC Formula is Efficiency-based
- 2013 Under Supplied Market
- Increasing Requirements (Utility Purchases)
- Inflation-adjusted ACP 2014 = \$21.72 / Credit (MWh)

Incentives “Capitalized” by UMMS Project

■ **Electric Utility**

- Installation Incentive \$750 / kW

■ **Massachusetts Alternative Portfolio Standard**

- Credits based on net fuel savings Vs. SHP
- Credits create cash flow from measured performance
- Typical CHP with net electric efficiency of 30% + overall efficiency of 75% will generate ~ 3¢ / net kWhe.
- UMMS will need qualify under “Incremental” definition
- Program has no end date – “Annual Cash Flow”

Nexant - Clean Energy Markets

- **2010 UMass Medical selects Nexant “Authorized Representative” for Mass APS program**
- **UMMS first true “Incremental CHP plant” in APS**
 - Credit production from fuel savings above previous baseline operating efficiency, Vs. separate heat and power.
Computed fuel savings = Mass AECs.
- **Nexant establishes monthly baseline from CY 2009 metered data**
 - (Total Fuel, Net Electric & Useful Thermal)
- **2012 UMMS awarded APS approval by MA DOER**

CY 2013 Performance Vs. 2009 Baseline

- **Net Electric Generation – 81,859 MWh**
 - 114.5% increase (baseline 38,162 MWh)
 - 80% increase in electric generating efficiency
- **Useful Thermal (steam) to Campus – 235,311 MWh**
 - 803,113 MMBtuh
 - 2.5% less thermal load to campus
- **Fuel Consumption (Gas + Oil) – 462,907 MWh**
 - 18.4% increase total fuel input
 - 88% reduction oil consumption

CY 2013 Performance Results Vs. Baseline

■ **Stack Emissions Reduction**

- Positive Impact from CGT generation
- Reduction in fuel oil consumption

■ **Overall Fuel Efficiency – Year 1**

- 68.5%
- 52,103 MWh fuel savings from Cogen mode Vs. Separate Heat & Power generation

(What are these MWh savings called in Massachusetts?)

Alternative Energy Credits!!!

■ 1 AEC = 1 MWh of net source Fuel Savings

- $\text{AECs} = (\text{MWh elec}/0.33 + \text{MWh useful thermal}/0.8) - \text{MWh Fuel}$


■ UMMS 2013 Incremental Vs. Baseline

- 2.5% less useful thermal load to campus
- Generated 115% more electric
- Consumed 18% more fuel
- Created 52,103 MWh of Energy Efficiency = “AEC’s”
- \$1 million income ~ 1.3¢/kWh total or 2.5¢/kWh incremental

■ UMMS Looking Forward

- No sunset for Mass APS program
- Improved operating efficiency will increase AEC production
- As campus load increases AEC production increases
- Annual cash flow available for ROI or O&M

States with EECs & Electric Decoupling



Conclusion for UMass Medical

- First Year operating efficiency ahead of projections
- Combustion Turbine/HRSG now primary boiler
- Stack emissions below 2009 levels
- Thermal Plant owner's who purchase majority of electricity from a utility will benefit from incremental addition of a CTG/HRSG and a steam turbine generator.



Contacts

Darrell Sandlin
dsandlin@nexant.com

Nexant Clean Energy Markets
1805 Old Alabama Rd, Suite 315
Roswell, GA 30076

Joseph Collins
joseph.collins@umassmed.edu

Umass Medical School
55 Lake Avenue North
Worcester, MA 01655

