

De-Carbonizing the Campus: Planning, Tools & Technologies

CampusEnergy2023

February 27 – March 2, 2023

Gaylord Texan Resort & Convention Center | Grapevine, Texas



INTERNATIONAL
DISTRICT ENERGY
ASSOCIATION




Brian Clifford, P.E.
Don Guan Ph.D., P.E.

2

[illegible]

Houses a world-class 240-bed research hospital



NIH Central Utility Plant (CUP) Overview

One of the largest CUPs under one roof in the USA

Provides campus with chilled water, steam, electricity, and compressed air

CUP Components

Twelve 5,000 Ton capacity chillers

8-million-gal CHW thermal storage tank

5-million-gal Industrial Water System

Five gas/diesel dual fuel fired boilers

800 KPPH, 980 KPPH with Cogen

Cogeneration Power Plant

One of the largest US government Cogen plants

One of the cleanest Cogen plants in the world

23 MW, 180KPPH steam (40% of campus demand)






















TES tank




IWS tank

















Boiler Plant Water Treatment : Contaminates




CONTAMINATE LEGEND			
Color Legend		Shape Legend	
 Fe Added to System	 Dissolved Gas	Scale/Deposit Forming	Consequences
 Solid/ion	 Alkalinity	 SiO₂ Silica  Steam Turbine	 O₂ Oxygen
		 Ca Calcium	 CO₂ Carbon Dioxide
		 Mg Magnesium	 HCO₃⁻ Bicarbonate
		 Cu Copper	 CO₃⁻² Carbonate
		 Fe Iron	 Cl Chlorine  Reverse Osmosis
			 Na Sodium  Decrease Co









Boiler Plant Water Treatment : Contaminates




CONTAMINATE LEGEND						
Color Legend		Shape Legend		Consequences		
 Fe	Added to System		Dissolved Gas			
 Fe	Removed from System		Solid/ion			
			Alkalinity			
				Scale/Deposit Forming		
				 SiO₂	Silica	<div>Steam Turbine</div>
				 Ca	Calcium	
				 Mg	Magnesium	
				 Cu	Copper	
				 Fe	Iron	
				Corrosion Forming		
				 O₂	Oxygen	
				 CO₂	Carbon Dioxide	
				 HCO₃⁻	Bicarbonate	
				 CO₃⁻²	Carbonate	
				Hurt Equipment		
				 Cl	Chlorine	<div>Reverse Osmosis</div>
				 Na	Sodium	<div>Decrease CoC</div>

Boiler Plant Water Treatment : Chemical Injection



CONTAMINATE LEGEND		
Color Legend		Shape Legend
 Added to System	 Dissolved Gas	
 Removed from System	 Solid/ion	
 Consumed	 Alkalinity	
 Prevent agglomeration		
 Prevent corrosion		

CUP Water Treatment Dashboard with built-in Auto Fault Detection



*Not actual data

Digitization Plant Operations - Mobile Friendly Round Data Entry

Version: 1/14/2019								NIH CENTRAL UTILITY PLANT - BOILER WATER TREATMENT LOG							
Date: 6/17/19															
				SS Signature											
				Actual Time		10:00				2:20					
				Oper Initials		AK				JC					
						Scheduled Time									
Location/ Parameter				Units	Spec Limit	Freq	0400	1000	1600	2200	COMMENTS				
City Water											Please obtain sample from softener inlet				
Conductivity				µS/cm	Record	1/D		360							
Hardness				ppm	Record	1/D		100							
Total Alkalinity				ppm	Record	1/D		90							
Soft Water Common Outlet															
Conductivity				µS/cm	Record	4/D		361		377					
Hardness				ppm	0	2/D		0		0					
Water Softener 1						Circle One →	ON / OFF	ON / OFF	ON / OFF	ON / OFF	Compare to soft water common outlet				
Conductivity				µS/cm	Record	4/D					Measure when common hardness is greater than 0 ppm				
Hardness				ppm	0	2/D					Measure when common hardness is greater than 0 ppm				
Analyzer Hardness				ppm	Record	2/D		0.000		2.441					
Throughput				Gallons	Record	2/D		79974		150000					
Water Softener 2						Circle One →	ON / OFF	ON / OFF	ON / OFF	ON / OFF	Compare to soft water common outlet				
Conductivity				µS/cm	Record	4/D					Measure when common hardness is greater than 0 ppm				
Hardness				ppm	0	2/D					Measure when common hardness is greater than 0 ppm				
Analyzer Hardness				ppm	Record	2/D		0.096		0.098					
Throughput				Gallons	Record	2/D		131769		57527					
Water Softener 3						Circle One →	ON / OFF	ON / OFF	ON / OFF	ON / OFF	Compare to soft water common outlet				
Conductivity				µS/cm	Record	4/D					Measure when common hardness is greater than 0 ppm				
Hardness				ppm	0	2/D					Measure when common hardness is greater than 0 ppm				
Analyzer Hardness				ppm	Record	2/D		0.000		0.041					
Throughput				Gallons	Record	2/D		150000		145247					
Treated Water Tank															
Conductivity				µS/cm	Record	4/D		21		24					
pH				pH	8.2-9.0	4/D		8.5		8.17					
Hardness				ppm	0-0.5	2/D		0		0					



Water Chemistry Data Entry

Rounds
 Select Round: *

Value Date/Time: *



Parameters

City Water					
Parameter	Units	Range	Value	Comments	Action
Conductivity	(µS/cm)	200 - 600	<input type="text"/>	<input type="text"/>	Recommendations View History
Hardness	(ppm)	-	<input type="text"/>	<input type="text"/>	Recommendations View History
Total Alkalinity	(ppm)	-	<input type="text"/>	<input type="text"/>	Recommendations View History

Soft Water Common Outlet					
Parameter	Units	Range	Value	Comments	Action
Conductivity	(µS/cm)	-	<input type="text"/>	<input type="text"/>	Recommendations View History
Hardness	(ppm)	0 - 0	<input type="text"/>	<input type="text"/>	Recommendations View History

Water Softener 1					
Parameter	Units	Range	Value	Comments	Action
Conductivity	(µS/cm)	-	<input type="text"/>	<input type="text"/>	Recommendations View History
Hardness	(ppm)	0 - 0	<input type="text"/>	<input type="text"/>	Recommendations View History



Digitization Plant Operations - Mobile Friendly Round Data Entry



*Not actual data

Web-based Executive Level Summaries and Reporting

High level, executive daily performance data accessible with 1 click



*Not actual data

- Rationalization of existing alarms**
- Identification and Implementation of new alarms**
- Alarm Notification and Escalation**



Identifies protentional Bad Actor alarms for Advanced alarm design to reduce nuisance alarms

Chattering alarm Suspects

Total Number of Chattering Alarms:6

Occurrences	Tag
27	TV_WT_CHEM_CT22_HI_CIO2_Warn
21	TV_WT_CHEM_CT22_HI_CIO2_Alm
19	TV_WT_CHEM_CT27_HI_CIO2_Warn
18	TV_WT_CHEM_CT26_HI_CIO2_Alm
15	TV_WT_CHEM_CT27_HI_CIO2_Alm
14	TV_WT_CHEM_CHW_HI_CIO2_Alm

Fleeting alarm Suspects


Total Number of Fleeting Alarms:54

Tag	Duration Min
TV_WT_CHEM_CT26_HI_CIO2_Alm	0.1
TV_WT_CHEM_CHW_HI_CIO2_Alm	0.12
TV_WT_CHEM_CHW_HI_CIO2_Alm	0.13
TV_WT_CHEM_CT26_HI_CIO2_Warn	0.13
TV_WT_CHEM_CHW_HI_CIO2_Alm	0.15
TV_WT_CHEM_CT22_HI_CIO2_Alm	0.15

14


Dynamic Alarm Setpoints

KPI limits set up to automatically adjust based on control factors (e.g., equipment status, makeup water fluctuations)






*Not actual data

Identifies incorrect or irrational data errors that may lead to poor misjudgment



Data Quality Notification



smartsheet gov													
File Automation Forms													
Data quality monitoring and troubleshooting													
Grid View True DQ Alarm													
	Tag tier	Type	Tag name	Initial Alarm Date	Request by	Assigned to	Troubleshooting Start Date	Status	Task Completion %	Actual Completed Date	Issues	True DQ alarm	Progress Update
5	Tier 1	Missing rate	CopierCTD_Turn_Speed_1	08/15/22	Chengyang Yu	Aimeesh, Binman					This tag keep getting "Conn Fail" or "Not sent" errors	True	Copier still working on it
8	Tier 1	Static rate	CopierCTD_Turn_Speed_1	08/15/22	Binman.arnest@gnh.gov	Binman.arnest@gnh.gov	08/15/22	In Progress	100%		Copier having issues with the Sensors to log Modbus gateway based on Modbus error	True	Copier still working on it
15	Tier 1	Missing rate	CopierCTD_Turn_Speed_1	08/20/22	Binman.arnest@gnh.gov	Binman.arnest@gnh.gov	08/20/22	In Progress			Copier still having issues with the Modbus gateway based on Scott's email	True	Copier still working on it
30	Tier 1	Missing rate	DRF_CODE/NAP/Default1/GES851TC1200A	10/12/22	Binman.arnest@gnh.gov	Binman.arnest@gnh.gov	10/12/22	Completed	100%		Missing data probably from server updates on 10/12. We are experiencing missing data from GE8500 relay	True	based on EDT, the missing data probably from server updates on 10/12. We are experiencing missing data from GE8500 relay
69	Tier 1	Out of range	WOPF_CODE/NAP/Default1/CP30B/B00F/weldwire_flow	10/26/22	Binman.arnest@gnh.gov	Binman.arnest@gnh.gov	Completed				Out of range, waiting answers from UGB	True	based on instrumentation team, they passed the line down and it seems workflow now. UGB will monitor

[illegible]

Thank You

Many thanks to NIH Office of Research Facilities Director Mr. Dan Wheeland, Division of Technical Resources (DTR) Director Dr. Farhad Memarzadeh, Chris Lyon, Dr. Abdul Bhuiyan, Dr. Andrew Gomes and all our colleagues in DTR to make all of this happen!

Contact Information

Brian Clifford, P.E.

brian.clifford@nih.gov

Mechanical Engineer

Division of Technical Resources

Don Guan Ph.D. P.E.

don.guan@nih.gov

Lead Engineer, Technical Support Branch

Division of Technical Resources