



CampusEnergy2021

BRIDGE TO THE FUTURE

Feb. 16-18 | CONNECTING VIRTUALLY

WORKSHOPS | Thermal Distribution: March 2 | Microgrid: March 16





Variable Speed Drive for High Load Chiller Operation

Neelraj Sambasivam




CampusEnergy2021
BRIDGE TO THE FUTURE
Feb. 16-18 | CONNECTING VIRTUALLY
WORKSHOPS | Thermal Distribution: March 2 | Microgrid: March 16





Trekking in a Dam




Trekking in a Dam




Height to Climb vs Height of Water Level




Height to Climb vs Height of Water Level



Height to Climb vs Height of Water Level




Height to Climb vs Height of Water Level




Energy spend

Load



Capacity - Weight

Climb



Lift - Height


Energy spend \propto

Capacity & Lift (Chiller)

Weight & Height (Person)

Lift – Mother Nature

Dubai weather profile



Capacity

Low Delta T syndrome

Design Delta T = 9°C							
Delta T (deg C)	9.0	8.7	8.4	8.2	7.9	7.6	7.3
Reduction	0.0	-0.3	-0.6	-0.8	-1.1	-1.4	-1.7
Chiller load	100%	97%	94%	91%	88%	85%	81%

Sequencing

Plant load	25,000	24,500	24,000	23,500	23,000	22,500	22,000	21,500	21,000	20,500	20,000	19,500	19,000	18,500	18,000
	100%	98%	96%	94%	92%	90%	88%	86%	84%	82%	80%	78%	76%	74%	72%
No. Running Chiller	10	10	10	10	10	9	9	9	9	9	8	8	8	8	8
Each Chiller loading	2,500	2,450	2,400	2,350	2,300	2,500	2,444	2,389	2,333	2,278	2,500	2,438	2,375	2,313	2,250
	100%	98%	96%	94%	92%	100%	98%	96%	93%	91%	100%	98%	95%	93%	90%


99% of chiller lifetime spend at off-design condition

Real-world conditions – Search for solution

- ANSI/ASHRAE & AHRI
- IPLV / NPLV

IPLV/NPLV	
Load	Time
100%	1%
75%	42%
50%	45%
25%	12%

In summary, it is best to use a comprehensive analysis that reflects the actual weather data, operational hours, economizer capabilities and energy drawn by auxiliaries such as pumps and co the chiller and system efficiency. The intended use of the IPLV.IP (NPLV.IP) rating is to compare technologies, enabling a side-by-side relative comparison, and to provide a second certifiable rating by energy codes. A single metric, such as design efficiency or IPLV.IP shall not be used to qu




99% of chiller lifetime spend at off-design condition


Why to focus Chiller?

- Chillers have the biggest impact
- Operational cost has become a major criterion

Total Chiller Plant Energy Use



Lifetime chiller cost



Solution for off-design chiller efficiency

Entering Cond water temp (°F)	% Input power saving with VSD Chiller compared over CSD chiller									
	100%	98%	96%	94%	92%	90%	88%	86%	84%	82%
95°	-3%	-2%	-2%	-2%	-1%	-1%	-2%	-1%	-2%	-1%
93°	-2%	-2%	-1%	-1%	0%	0%	-1%	-1%	0%	0%
91°	-1%	-1%	0%	0%	0%	1%	1%	1%	1%	1%
89°	-1%	0%	0%	1%	1%	2%	2%	2%	3%	2%
87°	0%	1%	1%	2%	2%	3%	3%	3%	4%	4%
85°	1%	2%	3%	3%	4%	4%	5%	5%	5%	5%
83°	3%	4%	4%	5%	5%	6%	6%	7%	7%	7%
81°	5%	5%	6%	6%	7%	7%	8%	8%	9%	9%
79°	6%	7%	7%	8%	9%	9%	10%	10%	11%	11%
77°	8%	8%	9%	10%	10%	11%	11%	12%	12%	13%
75°	9%	10%	11%	12%	12%	13%	13%	14%	15%	15%
73°	11%	12%	13%	13%	14%	15%	15%	16%	17%	17%
71°	13%	14%	15%	15%	16%	17%	18%	18%	19%	20%
69°	15%	16%	17%	17%	18%	19%	20%	20%	21%	22%
67°	17%	18%	19%	19%	20%	21%	22%	22%	23%	24%
65°	19%	19%	20%	21%	22%	23%	24%	24%	25%	26%
63°	20%	21%	22%	23%	24%	25%	26%	26%	27%	28%
61°	22%	22%	23%	24%	26%	27%	28%	29%	30%	31%

Typical operation

Typical % energy saving for Chiller with VSD

Real-world conditions – Search for solution – High load plant

Annual Specific Power Input

- How can an off-design conditions be taken into efficiency calculation?
- ASPI will help System designers accurately evaluate the performance of different equipment against each other

Capacity	ECWT in DegF	% hours in Year	Number of Hours in year	Performance of the Chiller
Design Point Load (Full Load)	95	10	876	A
	85	25	2190	B
	80	30	2628	C
	75	25	2190	D
	65	10	876	E
Annual Specific Power Input (ASPI) =			$\frac{A \times 876 + B \times 2190 + C \times 2628 + D \times 2190 + E \times 876}{8760}$	

Capacity	ECWT in DegF	% hours in Year	Number of Hours in year	Performance of the Chiller
80% Design Point Load	95	10	876	A
	85	25	2190	B
	80	30	2628	C
	75	25	2190	D
	65	10	876	E
Annual Specific Power Input (ASPI) =			$\frac{A \times 876 + B \times 2190 + C \times 2628 + D \times 2190 + E \times 876}{8760}$	

Case Study



Past & Present


- DC Plant snapshot
 - ✓ 7 - 1800TR Constant Speed MV Chillers
 - ✓ 7 - Constant Speed Primary Pump
 - ✓ 7 - Constant Speed Condenser Pump
 - ✓ 7 - Constant Speed Cooling Tower motor

Past & Present

- DC Plant snapshot (Past)
 - ✓ 7 - 1800TR Constant Speed MV Chillers
 - ✓ 7 - Constant Speed Primary Pump
 - ✓ 7 - Constant Speed Condenser Pump
 - ✓ 7 - Constant Speed Cooling Tower motor
- DC Plant snapshot (Present)
 - ✓ 7 - 1800TR Variable Speed MV Chillers (1300 kW)
 - ✓ 7 - Variable Speed Primary Pump (45 kW)
 - ✓ 7 - Variable Speed Condenser Pump (110 kW)
 - ✓ 7 - Variable Speed Cooling Tower motor (75 kW)
 - ✓ Advanced Chiller Plant Optimization Programs

Retrofit


- 1790TR centrifugal WC chiller – 1300kW (11kV) motor
- LV VSD's on Primary, Condenser, CT motor
- Custom logic / advanced sequences in plant automation system
- Auto-Adaptive Process + Machine learning



PREDICTIVE
COST-BASED
OPTIMIZATION



REVENUE
GENERATION




RESILIENCY &
RELIABILITY


Retrofit - Truly minimizing utility cost





Total System Cooling Output




Cooling Tower Fan Speed Condenser Pump Speed Chiller Vane & Speed Primary Pumps Secondary Pumps



Total System Energy Input



Saving & Return on Investment - Estimate



Pay back: 3.7 Year

Industry standard
Measurement and
verification program




Saving & Return on Investment - Actual



11.9
GWh
Saving
per year

Retrofit


Pay back:
3.2 Year






Can we see the data?

Year around comparisons – kw / ton & saving



Base Line estimation in 2016/17 and measurement & verification was done in 2019/20

Year around comparisons – Plant utilization & saving



Base Line estimation in 2016/17 and measurement & verification was done in 2019/20

Myth Busted !

- VSD chillers helps only in winter month
 - Variable Speed Drives are expensive, with un-attractive payback
 - Plant with Thermal Storage will be operating at design load.
 - Chillers must be evaluated for Full Load Efficiency at “Design” Conditions
- VSD chillers reduces power consumption year around
 - Latest VSDs are available with reduced cost & size. It's viable for both retrofit & new projects
 - Thermal Storage charging is at off-peak time i.e. lower WB temp – VSD will be more beneficial
 - ASPI is critical parameter to evaluate chillers

Additional benefits of a VSD

- ✔ Improved and Constant **PF of 0.96**
 - Eliminates PF correction capacitors
- ✔ Eliminates **Inrush Current** (<100% FLA)
 - Enhances motor life
 - Reduces emergency power generator size (if required).
- ✔ Reduced **driveline wear**
- ✔ Reduced **sound level** at lower loads.
- ✔ Eliminates inefficiency of **over designing** due to safety.
 - Higher Condenser Water Temp
 - Higher Fouling



Future

- Evaluate plant with ASPI
- Design plant for real world efficiency not full load efficiency
- Reduce carbon footprint



