

Fuel Cell Waste Heat Utilization *at the University of Bridgeport*



IDEA Conference
March 9, 2018


*Linfeng Zhang, Department of Electrical Engineering
Junling(Joyce) Hu and Nouman Kan, Department of Mechanical Engineering
David P. Cote, P.E., Executive Director – Facilities Planning and Operations*

University of Bridgeport:

- The University of Bridgeport, an independent and non-sectarian institution, offers career-oriented undergraduate and graduate degrees.
- Comprised of 5,500 students with 1,250 on-campus residents.
- 52 buildings including Academic, Administrative, Dormitory and Apartments equaling approximately 1.5M square feet.
- Over 53 acres crossing several city streets



Why Fuel Cells at UB?



- Efficiency: 47% for electrical power, higher for CHP
- Energy security and reliability for a microgrid (point of common coupling)
- Low emission as a clean energy source
- Quiet generator

- ❖ Another entity owns and operates the fuel cell
- ❖ We purchase the electric power while the heat is available for free.



UNIVERSITY OF
BRIDGEPORT

RAMBOLL



UNIVERSITY OF
BRIDGEPORT


126 Park Avenue, Bridgeport, CT 06604

Tel: 1-800-EXCEL-UB (392-3582)

Fax: (203) 576-4941

Email: admit@bridgeport.edu

Website: www.bridgeport.edu





FC Overview

- 1.4 MW combined heat & power fuel cell power plant
- Space requirement ~ 40 ft x 60 ft
- Electric production ~ 11 million kWh per year
- Utilities needed: natural gas or bio gas fuel, potable water, sewer
- Supplies 80% of campus power needs
- Waste heat converted to hot water and supplied to three locations on campus
- Connecticut Microgrid Program Award

Benefits

- Cost savings during normal operations
- In a grid outage, power to critical facilities – shelter ~2700 persons, security, dining
- Emissions reductions:
7,000 tons CO₂, 64 tons SO_x, 28 tons NO_x
- Renewable Energy Research Lab –
“practice what we teach”

SureSource 1500 1.4 Mega Watts Fuel Cell Power Plant

PERFORMANCE

Gross Power Output

Power @ Plant Rating	1,400 kW
Standard Output AC voltage	480 V
Standard Frequency	60 Hz
Optional Output AC Voltages	By Request
Optional Output Frequency	50 Hz

Efficiency

LHV	47 +/- 2 %
-----	------------

Available Heat

Exhaust Temperature	700 +/- 50 °F
Exhaust Flow	18,300 lb/h
Allowable Backpressure	5 iwc

Heat Energy Available for Recovery

(to 250 °F)	2,216,000 Btu/h
(to 120 °F)	3,730,000 Btu/h

Fuel Consumption

Natural gas (at 930 Btu/ft ³)	181 scfm
Heat rate, LHV	7,260 Btu/kWh

Water Consumption

Average	4.5 gpm
Peak during WTS backflush	15 gpm

Water Discharge

Average	2.25 gpm
Peak during WTS backflush	15 gpm

Pollutant Emissions

NO _x	0.01 lb/MWh
SO _x	0.0001 lb/MWh
PM ₁₀	0.00002 lb/MWh


Greenhouse Gas Emissions

CO ₂	980 lb/MWh
CO ₂ (with waste heat recovery)	520-680 lb/MWh


Sound Level


Standard	72 dB(A) at 10 feet
----------	---------------------

A Study of Fuel Cell Waste Heat Utilization



1BTU=252Calories





Fuel Cell Heat for Current and Potential Connections :

- The heat demand of University Apartments and Wheeler Recreation Center is less than half of the total Fuel Cell recovered heat
 - 24% in the summer season
 - 54% in the winter season
- Switching on University Hall
 - Connection has been built
 - Expansion tank size is questionable
- Connecting Cooper Three buildings
 - The total heat demand exceeds the total heat recovered from Fuel Cell in winter

The goal: identify costs and benefits of expanding hot water network to provide heat from fuel cell to additional buildings

Life cycle cost

#	Components	Life span (years)	Initial cost (\$)	Present worth (\$)
1	Heat Exchanger	25	5,000	5,000
600 ft	4" Pex piping	25	16,587	16,587
1	Pump	10	2,500	2,500
1	Pump (10 year)			2487.5
1	Pump (20 year)			2,475
57	Installation	N/A	159,000	159,000
N/A	Miscellaneous	N/A	5,000	5,000
7	Annual Maintenance		300	7,451
Life cycle cost				200,500

Inflation rate is set as 2.3%, Interest rate is set as 2.35%
 The cumulative present worth **factor**

Saving in 25 years

Heat (MMBTU)	Annual saving (k\$)	25 years (k\$)
6630	79	1,965

\$12 for 1MBTU

2.5 yr payback

Social cost

Heat (MMBTU)	Natural gas (ton HHV)	CO ₂ (ton)	Annual Social cost (k\$)	25 years (k\$)
6630	126	347	13.9	345.2