

# Future Proofing Dalhousie's Energy Platforms for the 21<sup>st</sup> Century

Darrell Boutilier, Director – Operations, Facilities Management  
Rochelle Owen, Executive Director - Office of Sustainability  
Michael Conte, Project Manager – FVB



# Agenda:

- Sustainability Drivers
- Operational Drivers
- AC Project Implementation
- Halifax Plant
- Q&A

# Where are we?



# Dalhousie University Campuses




Founded in 1818

100+ buildings/houses on 79-acres in downtown Halifax.

50+ buildings AC campus

Includes 5.8 million gross square feet of building space.



A campus population of approximately 26,500 (19,000 students, 7500 faculty and staff).

Four Campuses: Studley, Carleton, Sexton – Downtown Halifax, AC – Truro Bible Hill



Two Heating Plants & District Heating Systems that connect 96% of the load



# Dalhousie University - Studley, Carleton & Sexton – Halifax Campuses





# Dalhousie University - Agricultural Campus



# Sustainability Drivers

- Ethical and social ramifications
- Environmental implications – air pollution, climate change
- Economic – carbon policies, life-cycle savings, security, hedge against rising utility pricing
- Leadership role
- Reputation
- Student and employee recruitment
- Teaching, learning, and research role

# Key Goals

- reduce life-cycle costs
- increase energy-water efficiency
- conserve energy and water
- reduce air quality contaminants and greenhouses gases
- improve energy security





# Planning Context for Energy and Renewables



Inspiration and  
IMPACT

DALHOUSIE STRATEGIC  
DIRECTION 2014-2018

## SOLAR ENERGY FOR ACADEMIC INSTITUTIONS

Solar Suitability Assessment  
of Dalhousie University, Halifax, NS  
Prepared for IBI Group/WHW Architects and Dalhousie University

Green Power Labs Inc

One Research Drive,  
Dartmouth, Nova Scotia,  
Canada, B2Y 4M9  
Phone: (902) 466-6475  
Fax: (902) 466-6889



Report completed on: February 20, 2009

SEPTEMBER 2010

## DALHOUSIE UNIVERSITY CAMPUS MASTER PLAN FRAMEWORK PLAN



## Dalhousie University Climate Change Plan 2010



## Dalhousie University Sustainability Plan

Building a sustainable community




June 2010. Dalhousie University Office of Sustainability  
[www.sustainability.dal.ca](http://www.sustainability.dal.ca)



## Campus Energy Master Plan Dalhousie University

February 2012

FINAL



McWor Energy Solutions Ltd  
1001 Argyle Road, Suite 100  
Halifax, Nova Scotia  
B3H 2C1  
A subsidiary of IBI  
IBI Group of Companies  
[www.ibi.com](http://www.ibi.com)



## Dalhousie University Agricultural Campus, Truro, Nova Scotia Renewable Energy Master Plan Draft Report



Updated 10/10/10 • North Research Station 1 • March 2010

ISO 9001  
Registered Company



# Climate Change


## MITIGATION

- Reduce GHG emissions and carbon footprint
  - Energy and water efficiency
  - Conserve energy
  - Fuel switching and renewable energy
  - Bike/walk/bus to campus
  - Carbon sinks

## ADAPTATION

- Planning for inevitable climate changes (warmer, wetter, wilder)
  - Energy Security
  - Flooding
  - Resilient skins
  - Emergency centre


# GHG Reduction Strategies





# AC Campus

In the fall of 2012, Dalhousie and the Agriculture College merged. A basic audit of electrical opportunities had been done for the College in 2010. To supplement this work, a report was completed in 2014 on renewable energy opportunities including pursuing biomass co-generation.



# Background

- The current biomass boiler (28 years old) is at the end of its useful life.
- Small scale efficient biomass co-generation one of the 10 projects in the AC Renewable Energy Master Plan (2014). Other projects being explored solar, anaerobic digestion, wind partnership.

# Background

- A COMFIT rate (17.5 cents a kW for electricity) was approved for this project in June 10, 2014 (Amended April 19, 2016 – to be 1 MW).
- A report on the life cycle of a number of heating systems for the campus was completed. (October 2014).
- A report on stakeholders' perceptions of biomass fuel and plant operations was completed. (October 2014).



# COMFIT

- Operational Date – No later than June 10, 2018 (4 yrs)
- Directive 2 & 4:
  - Priority on wood waste; descriptions of types and environmental conditions
  - Air quality requirements – 35 pm mg/m<sup>3</sup> based on total thermal input – ESP needed
  - High efficiency

# Project Goal

- Address facilities renewal costs of an existing end-of-life system
- Support university and community carbon reduction goals
- Promote and support existing and new sustainable biomass supply
- Connect research, teaching and operations
- Support local economic development


# Fuel Supply

- Created Fuel Values Statement
- Engaged Stakeholders in open houses, RFI, and RFP
- RFP – included reference to type of supply wanted and allocation of up to 5000 tonnes for research type fuel
- Supply – Main amount waste wood residue (bark, shavings from local sawmill); Yard waste; willow and selective harvesting (research fuel)
- Silviculture – directed to selective thinning to increase biomass





# What is special about Nova Scotia?



# Agricultural Campus Heating Plant





**DALHOUSIE  
UNIVERSITY**





# Agricultural Campus – Heating Plant



Boiler #1 – 20,000 pph, HP steam boiler (furnace oil), 48 yrs old

Boiler #2 – 20,000 pph, HP steam boiler (furnace oil), 5 yrs old



Boiler # 3 – 12,000 pph, HP steam boiler (furnace oil), 36 yrs old

Boiler # 4 – 15,000 pph, HP steam boiler (Biomass), 28 yrs old

# Agricultural Campus – Heating Plant

Peak Steam load – 27,500 pph

Annual Steam Production – 72,000,000 lbs

Annual biomass consumption – 8000 tons

June – Sept – 14hrs per day

Oct – May – 24/7 operation



# AC Heating Plant – Operational Drivers for Renewal

Age – Biomass boiler is 28 years old

February 2014:

- Biomass boiler experienced internal cracks
- Out of operation for over 2 months
- AHJ imposed operating restrictions
- Significant additional cost of burning furnace oil





# AC Heating Plant – Operational Drivers for Renewal



## Biomass Storage & handling

- Poor access to chip bin
- chopping and sawing frozen chips
- auger blockages
- Ash disposal is cumbersome





# DAL AC- Biomass CHP: Initial Concept


- Feasibility Study Concept: 1.7 MWe, 600 psi, Extraction Steam Turbine
- Enlarge the Existing Fuel Bin
- Larger Steam Boiler, Increased Operating Pressure
- Install the Turbine in a New Adjacent Building
- Sound Technical Concept
- **Fatal Flaw(s):**
  - A large capital investment in Steam Based Infrastructure
  - Complexity of Operating a High Pressure Steam Turbine
  - Changes to Staffing Requirement



# DAL AC- Biomass CHP Screening Report: Options

➤ Five (5) Options were evaluated:

- 1) Replace Biomass Steam Boiler (Status Quo)
- 2) Biomass Superheated Steam Boiler w/ Extraction Steam Turbine
- 3) Biomass Thermal Oil Boiler w/ 700 kWe Organic Rankine Cycle CHP
- 4) Biomass Thermal Oil Boiler w/ 968 kWe Organic Rankine Cycle CHP
- 5) Biomass Superheated Steam Boiler w/ Back Pressure Steam Turbine



# DAL AC- Biomass CHP

## Screening Report- Quantitative

No.	Description	Alt 1	Alt 2	Alt 3	Alt 4	Alt 5
1	Construction Capital	\$6,100,000	\$18,700,000	\$15,900,000	\$16,800,000	\$12,500,000
2	Steam to HW Conversion Cost	\$0	\$0	\$6,720,000	\$6,720,000	\$6,720,000
3	Steam Upgrades	\$6,720,000	\$6,720,000	\$0	\$0	\$0
4	Sum: Total Capital [1+2+3]	\$12,820,000	\$25,420,000	\$22,620,000	\$23,520,000	\$19,220,000
5	<b>Incremental Capital (Compared to Alt 1)</b>		<b>\$12,600,000</b>	<b>\$9,800,000</b>	<b>\$10,700,000</b>	<b>\$6,400,000</b>
6	Annual Operating Costs	-\$1,853,000	-\$3,501,000	-\$1,908,000	-\$2,252,000	-\$2,120,000
7	Incremental Operating Cost (Compared to Alt 1)	NA	-\$1,648,000	-\$55,000	-\$399,000	-\$267,000
8	Power Generation Sales Revenue	\$0	\$2,100,000	\$980,000	\$1,360,000	\$770,000
9	<b>Net Revenue (Compared to Alt 1) [7+8]</b>	<b>NA</b>	<b>\$452,000</b>	<b>\$925,000</b>	<b>\$961,000</b>	<b>\$503,000</b>
10	<b>Simple Payback (Compared to Alt 1) [5+9]</b>	<b>-</b>	<b>27.8 yrs</b>	<b>10.6 yrs</b>	<b>11.2 yrs</b>	<b>12.7 yrs</b>
11	GHG Emission Reductions (Compared to Alt 1)	-	8,900 tCO <sub>2e</sub>	4,900 tCO <sub>2e</sub>	6,300 tCO <sub>2e</sub>	3,800 tCO <sub>2e</sub>
12	<b>Net Present Value</b>	<b>-\$60,086,343</b>	<b>-\$66,515,519</b>	<b>-\$50,174,381</b>	<b>-\$51,802,956</b>	<b>-\$56,660,690</b>
13	<b>Net Present Value Compared to Alt 1</b>	<b>-</b>	<b>-\$6,429,177</b>	<b>\$9,911,961</b>	<b>\$8,283,386</b>	<b>\$3,425,652</b>

# DAL AC- Biomass CHP

## Screening Report- Qualitative

Criteria Descriptions	Weight	Alt 1	Alt 2	Alt 3	Alt 4	Alt 5
Efficiency: Cogeneration + Heat	3	15	9	15	12	12
Environmental Impact / Carbon Footprint Reduction	3	6	15	9	12	9
Reliability of Supply (Elect & Thermal)	3	3	9	12	15	9
Safety	3	9	6	15	15	6
Energy Security / Fuel Flexibility	2	2	10	6	6	8
Support Sustainable / Local Bioenergy	3	9	15	12	12	12
Lowest Capital Cost	2	10	6	6	6	8
Revenue Generation	3	0	15	9	12	9
Non Labour Annual Operating Cost	2	10	2	8	6	6
All In Net Annual Operating Cost	2	2	6	8	10	4
Simple Payback vs. Oil	1	5	4	3	3	3
Simple Payback vs. Biomass	3	0	6	12	12	12
Transition from Existing Plant / Minimize Downtime	2	10	6	8	8	6
Future Adaptability	3	3	0	15	15	9
<b>Total</b>		<b>84</b>	<b>109</b>	<b>138</b>	<b>144</b>	<b>113</b>
<b>Ranking</b>		<b>5</b>	<b>4</b>	<b>2</b>	<b>1</b>	<b>3</b>




# DAL AC- Biomass CHP: Revised Concept


- Revised concept:  
1.0 MWe Organic Rankine Cycle Generator
- Build a New Fuel Bin; Improve Delivery Logistics
- New Upsized Thermal Oil Boiler
- Install the ORC Turbine in New Adjacent Building
- Convert the Backup Boilers and Distribution Network to Hot Water
- No Change to Current Staffing Requirements



# DAL AC- ORC Layout




# DAL AC- Organic Rankine Cycle Generator




# DAL AC- Why an ORC Generator at DAL?

- High Turbine / Thermodynamic Cycle Efficiency
- Low Working Pressures; Unattended Operation
- Long Operational Life
- Large Turn Down
- Proven Technology





# DAL AC- Biomass CHP LDC



# DAL AC: Hot Water Conversion

- Hot Water Conversion was part of the Long Term Campus Energy Plan
- The Existing Campus Already used Hot Water for >95% of Campus Heating Requirement
- The Steam Distribution System was Nearing End of Useful Life
- Existing Oil Steam Boilers Could be Converted
- Twined Steam Lines Could Be Repurposed

