



# CampusEnergy2021

BRIDGE TO THE FUTURE

Feb. 16-18 | CONNECTING VIRTUALLY

WORKSHOPS | Thermal Distribution: March 2 | Microgrid: March 16



# Thermal Energy Corporation (TECO) – the Energy Behind What's Next


Mike Manoucheri, P.E., TECO

Ben Erpelding, P.E., Optimum Energy



# Q&A Will Not Be Answered Live

**Please submit questions in the Q&A box.  
The presenters will respond to questions off-line.**








# TECO and the Texas Medical Center

- 120,000 tons of chilled water (300,000,000+ ton-hrs /yr)
- 27 chillers, 35+ miles of thermal piping
- 48 MW combined heat and power plant
- 23.7 million sq ft of conditioned space
- 50 buildings
- 10 million patient encounters annually
- 180,000+ surgeries annually
- 9,200 patient beds




**CampusEnergy2021**  
BRIDGE TO THE FUTURE  
Feb. 16-18 | CONNECTING VIRTUALLY  
WORKSHOPS | Thermal Distribution: March 2 | Microgrid: March 16






INTERNATIONAL  
DISTRICT ENERGY  
ASSOCIATION







## Central Pant, "CP" Condenser Water Side



# Growth

Peak chilled water demand has increased ~ 9000 tons over last 4 years

Projected chilled water demand to increase ~9000 tons over next 3 years

2020 Peak Load at 78,600 tons



**CampusEnergy2021**  
BRIDGE TO THE FUTURE  
Feb. 16-18 | CONNECTING VIRTUALLY  
WORKSHOPS | Thermal Distribution: March 2 | Microgrid: March 16





# Solution – it is much more cost effective to be more efficient than to add power production capacity

Through energy efficiency, reduce 2 Megawatts of load during Peak Grid days

1. Lower kW allowing entire plant to stay within load capacity of Co-Gen
2. Avoid spot purchasing of kW
3. Avoid unreliable grid power
4. kWh savings every day of year with < 2 year simple payback
5. Avoid demand charges associated with Coincident Peak Days \$14,350/MW

# Optimization

- Phase 1
  - ECHB chiller panel tuning
  - ECHB lift optimization
  - ECHB – cooling tower fan speed and staging optimization

Lift = Leaving condenser water temperature minus the leaving chilled water supply temperature

For example, a chiller selected at 40 deg F at 85-95 deg F would have a design lift calculated as  $95 - 40 = 55$  deg F


# Optimization

- Phase 2
  - CP lift optimization
  - Updated chiller staging
  - Update chilled water pump control
  - Updated tower and condenser water pump staging
  - Compliance and Health Reporting



# Reducing Lift – lowering condenser water delta T

Maintaining a 16,000 gpm CDW flow set point




Before (11.1 deg F delta T)



After (9.1 deg F delta T)

# Reducing Lift




Reduction in Lift by 2 deg F

kW/ton savings =  $0.0106 \times 2 = 0.0212$  kW/ton

$3 \times 6000\text{-tons} \times 0.0212 \text{ kW/ton} = 382 \text{ kW}$

# Optimization of Tower Fan Speed Using Power Relationships





# Phase 1 Energy Savings – spot reading

Running 6 cells at 70% speed instead of 3 cells at 100% speed to achieve the same or better approach temperature (~ 5 deg F)

6 x 70 kW fans = 420 kW

3 x 185 kW fans = 555 kW


Tower Fan Savings = 555 – 420 = 135 kW

Previous slide (reducing throttling) = 382 kW

Condenser Pumps' Savings = -15 kW x 3 = -45 kW

**Total savings = 135 + 382 - 45 = 472 kW**

# Staging Chillers




**CampusEnergy2021**  
BRIDGE TO THE FUTURE  
Feb. 16-18 | CONNECTING VIRTUALLY  
WORKSHOPS | Thermal Distribution: March 2 | Microgrid: March 16



# Staging Chillers


- Efficiency at low vs. higher loads is nearly identical per deg F of lift





Run 4 ECHB chillers at 7050 tons instead of 4 ECHB chillers at 5600 tons and CH8 at 5800 tons (86 deg F ECWT).

York OM-8000 R-22 Electric Drive Titan Chiller  
 Predicted Full & Part Load Performance  
 Motor KW vs Capacity (% Tons)



ECHB chiller at 7050 tons and 4600 kW = 0.652 kW/ton

ECHB chiller at 5600 tons and 3600 kW = 0.643 kW/ton

CH8 at 0.615 kW/ton and 5800-tons is 3567 kW.

4 x ECHB chillers at 7050 tons (4600 kW) = 18,400 kW

4 x ECHB chillers at 5600 tons (3600 kW) plus CH8 at 5800 tons (3567 kW) = 17,967 kW


18,400 kW - 17,967 kW = 433 kW

But adding CH8, instead of keeping ECHB chillers loaded higher, would add another ~700 kW condenser pump and another ~490 kW of CHWP (total of 1190 kW plus additional CP cooling tower fan energy minus some CHW pumping energy at ECHB)

Net savings is roughly 1190 – 433 = 757 kW



# Actual Results at CP – June 2020 (staging, lift reduction, and optimized condenser pumping and tower control)





# Optimization Compliance

Algorithm	SV	PV	Compliance
ECWB Maximum Cooling Tower Fan Speed	74	74	
ECWB Number of Cooling Towers to Run	6	6	
ECWB Number of Condenser Water Pumps to Run	3	3	

Algorithm	SV	PV	Compliance
ECWB CH1 Condenser Water Flow	19000	0	
ECWB CH2 Condenser Water Flow	19000	19011	
ECWB CH3 Condenser Water Flow	19000	18951	
ECWB CH4 Condenser Water Flow	19000	19002	

Algorithm	Yes/No	Next Chiller to Add/Shed	Compliance
Add a Chiller	FALSE	CP2	
Shed a Chiller	FALSE	CP4	
Chiller Rank	Click Here for Chiller Rank		

Algorithm	OE	SV	PV	Compliance
CP CH1 Evaporator Flow Set Point	9500	8000	8044	
CP CH2 Evaporator Flow Set Point	0	0	0	
CP CH3 Evaporator Flow Set Point	0	0	0	
CP CH4 Evaporator Flow Set Point	11500	10700	10638	
CP CH5 Evaporator Flow Set Point	0	0	0	
CP CH6 Evaporator Flow Set Point	0	0	0	
CP CH7 Evaporator Flow Set Point	12500	12800	12872	
CP CH8 Evaporator Flow Set Point	14000	13400	13405	
CP CH9 Evaporator Flow Set Point	16500	15050	14644	
CP CH10 Evaporator Flow Set Point	16500	15100	14989	

Algorithm	OE	SV	PV	Compliance
CP CH1 Condenser Flow Set Point	15000	14912	14912	
CP CH2 Condenser Flow Set Point	0	0	0	
CP CH3 Condenser Flow Set Point	0	0	0	
CP CH4 Condenser Flow Set Point	15500	15300	15285	
CP CH5 Condenser Flow Set Point	0	0	0	
CP CH6 Condenser Flow Set Point	0	0	0	
CP CH7 Condenser Flow Set Point	21000	21200	21223	
CP CH8 Condenser Flow Set Point	21000	20000	19955	
CP CH9 Condenser Flow Set Point	24500	23800	23931	
CP CH10 Condenser Flow Set Point	23000	23000	22243	



Counter has started for chiller add (click here)

Counter has started for chiller shed (click here)

OE ChillerOverview (click here)

Algorithm	OE	PV	Compliance
CP Number of Cooling Towers to Run	7	8	
CP Number of Condenser Water Pumps to Run	6	6	
CHWP 10 SPEED %	85.4	>65%	88
CP WCU With Most Open Valve	4		

# Health Reports





# Savings to Date – 6%

Month	Actual Ton Hours	Actual kW/Ton	Average Demand Reduction (kW)	Actual kWh Saved
Jun-20	36,339,945	0.76	1,802	1,297,296
Jul-20	44,465,023	0.79	2,305	1,714,576
Aug-20	41,482,745	0.78	2,460	1,830,344
Sep-20	32,805,074	0.76	2,120	1,526,382
Oct-20	26,295,248	0.71	1,911	1,421,481
Nov-20	22,794,551	0.62	1,982	1,427,048
Dec-20	16,055,010	0.58	1,706	1,269,568
<b>YTD</b>	220,237,595	0.74	2,041	11,449,950



# Questions?

# Thank you!

**Mike Manoucheri, P.E.**



**Ben Erpelding, P.E.**

