

Finding the Least Cost Mix of Renewables, and Storage with CHP

Andrew Kruse

Business Development Manager

UL Renewables

The Evolution of the grid






Fig. 1. The IEEE's version of the Smart Grid involves distributed generation, information networks, and system coordination, a drastic change from the existing utility configurations.

Renewables & Storage are the Disruptors for Modern Microgrids


Hybrid microgrids and DER's are growing today because of one primary reason: **Economics**



SOLAR



WIND




STORAGE


In the last decade, the cost of solar and wind have declined by as much as 80% and storage over 50%. They are fast becoming mature, bankable technologies.

The Potential Impact of Solar+Storage on CHP

- Solar plus storage is having an impact on most forms of I.C. engines used in electricity generation.
- Within this presentation, sensitivities were run on projected future costs of energy storage to better understand the impact of solar plus storage
- This is a simulated example of a small hotel in Massachusetts using HOMER Grid simulation software

Modeling Process






Architecture



The image is used for demonstration purposes only. This system was not actually built.

Load Profile of the Hotel




Breakdown of Components (CHP)

Generator: Generic Gas Microturbine with CHP (size-your-own) (Natural Gas)

Power output from the Generic generator system, rated at 4,000 kW using Natural Gas as fuel, is 8,796,645 kWh/yr.


Capacity	4,000 kW	Generator Fuel	Natural Gas
Operational Life	25.7 yr	Generator Fuel Price	0.200 \$/m ³
Capital Cost	\$6.00M	Maintenance Cost	140,160 \$/yr
Fuel Consumption	2,262,233 m ³	Electrical Production	8,796,645 kWh/yr
Thermal Production	8,125,745 kWh/yr	Hours of Operation	3,504 hrs/yr



Boiler: Generic Boiler


Power output from the Generic boiler system is 20,438,139 kWh/yr.

Total production	20,438,138 kWh/yr	Hours of operation	6,052 h/yr
Boiler Fuel	Natural Gas	Boiler Fuel Price	0.200 \$/m ³
Boiler Fuel Consumption	2,434,924 m ³ /yr		



Model using a .25 capital cost multiplier. Suggested component sizes will vary with changes to model

Cost Breakdown of Components (Solar + Storage)



Model using a .25 capital cost multiplier. Suggested component sizes will vary with changes to model

Energy Storage Sensitivities

Generic 1kWh Li-Ion [ASM] ✕

Name: Generic 1kWh Li-Ion [ASM] Abbreviation: LI ASM

Costs

Quantity	Capital (\$)	Replacement (\$)	O&M (\$/year)		Per Unit	Total Cost
5	4250	4250	0	✕	\$900	
10	8500	8500	0	✕		
200	100000	100000	1800			
2000	900000	900000	16000			
8000	3400000	3400000	64000			
16000	6592000	6592000	112000			

Click here to add new item

Multiplier: 4 4

Site Specific Input

LI ASM: Capital Cost Multiplier (*)

Variable: LI ASM: Capital Cost Multiplier (*)




Link with: (LI ASM: Capital Cost Multiplier (*), LI ASM: R: ▼)

Values:





LI ASM Capital Cost Multiplier (*)	LI ASM Replacement Multiplier (*)
1.0	1.0
0.75	0.75
0.5	0.5
0.25	0.25

OK Cancel

Model One - .25 multiplier for storage


CURRENT SYSTEM  +  + 

The electric needs of 1 Cambridge St, Boston, MA 02114, USA are met with a grid connection. You currently spend \$2.57M on your utility bill per year. 26% of your utility bill are demand charges.

PROPOSED SYSTEM  +  +  + 

We propose adding 25,116 kW of PV. This would reduce your annual utility bill to \$261,571. Your investment has a payback of 4.43 years and an IRR of 22.12%.

Simple payback:	4.43 yr	Net Present Value:	\$32.1M
Return on Investment:	17.7 %	Capital Investment:	\$30.1M
Internal Rate of Return:	22.1 %	Annualized Savings:	\$3.79M



Model Two- .50 multiplier for storage

CURRENT SYSTEM



The electric needs of 1 Cambridge St, Boston, MA 02114, USA are met with a grid connection. You currently spend \$2.57M on your utility bill per year. 26% of your utility bill are demand charges.


PROPOSED SYSTEM



We propose adding 26,881 kW of PV. This would reduce your annual utility bill to \$378,685. Your investment has a payback of 3.42 years and an IRR of 28.70%.

Simple payback:	3.42 yr
Return on Investment:	25.0 %
Internal Rate of Return:	28.7 %

Net Present Value:	\$37.1M
Capital Investment:	\$32.9M
Annualized Savings:	\$3.86M



Model Three - .75 multiplier for storage


CURRENT SYSTEM + +

The electric needs of 1 Cambridge St, Boston, MA 02114, USA are met with a grid connection. You currently spend \$2.57M on your utility bill per year. 26% of your utility bill are demand charges.

PROPOSED SYSTEM + + +

We propose adding 26,013 kW of PV. This would reduce your annual utility bill to \$467,026. Your investment has a payback of 1.93 years and an IRR of 49.76%.

Simple payback:	1.93 yr	Net Present Value:	\$42.8M
Return on Investment:	48.7 %	Capital Investment:	\$33.7M
Internal Rate of Return:	49.8 %	Annualized Savings:	\$3.85M



What was not Considered in this Model

- Property constraints for the solar PV
- Balance of system, permitting and construction costs
- No assumptions were made for the decrease in the cost of solar PV
- Other CHP technologies may have improved cost efficiency curves.
- This model is specific to the Northeastern United States. Location will have an impact on the economics

Conclusions

- The falling cost of solar plus storage will have an impact on future CHP plants
- CHP can demonstrate capabilities that are beyond solar and storage. These include:
 - Energy density (footprint) of a CHP plant
 - Solar PV is not practical for campus heating
- Solar and storage without fossil fuel generation such as CHP has limited resilience capability when long term outages are expected
- CHP remains an excellent solution for critical backup

Thank You!

Andy Kruse

Business Development Manager

Underwriters Laboratories

Andy.Kruse@UL.com

www.homerenergy.com

